Quality Control Manual

for

| | Manufacture, | [M] |
|--------------|-----------------------|--------------|
| | Modification, | [Mod] |
| | Repair, | [R] |
| | Assembly, | [A] |
| \checkmark | Inspection, Test, and | Retest [IT] |

of


Highway Tanks and Portable Tanks

for the

Transportation of Dangerous Goods by Road

in accordance with CSA B620-14 or the most current version (based on Transport Canada TDG regulations)

Facility Address: 46A Haniak Road, Rosslyn Ontario P7K 0C8



This manual is electronically controlled, if for any reason hard copies are produced they are: "NOT CONTROLLED IF PRINTED"

This manual must not be reproduced, distributed, amended or loaned, in whole or in part, without prior written consent of the National Quality Systems Manager or the Quality Assurance Specialist

This manual is in accordance with CSA B620-14 or the most current version (based on Transport Canada TDG regulations) and is for the following facility of National Energy Equipment Inc..

| Facility Address | Registration No. | Activities: |
|--|------------------|----------------------------|
| 46A Haniak Road, Rosslyn Ontario P7K 0C8 | 25-1239 | Inspection, Test, & Retest |

National Energy Equipment Inc.'s National Quality Systems Manager ensures the quality system meets the requirements of the CSA B620-14 or the most current version.

In this manual anywhere mentioned CSA B620, it means CSA B620-14 or the most current version - (based on Transport Canada TDG regulations)

| | National Energy Equipment Inc. Authorization | | | | | | |
|-----------------|--|---|--------------------|-----------------|--|--|--|
| Approved by: | | | | | | | |
| Name: | Zanyar Farhadi | | | | | | |
| Title: | National Quality Systems | Manager | | | | | |
| Phone: | (778) 588 7739 | | | | | | |
| Email address: | zfarhadi@nee.ca | | | | | | |
| Signature: | | | | | | | |
| Date: | | | | | | | |
| | | | | | | | |
| | | Quality Control Ma | anual in accordanc | e with CSA B620 | | | |
| ZEQUIPMENT INC. | | Prepared by / Approved by: Arash Navidan / Zanyar Farhadi | | | | | |
| | MENT INC. | Control Number: NEE-QCM-THB-001 | | | | | |
| | | Date of Issue: 2019/04/29 | Page: 2 of 150 | | | | |

| tem No. | Subject | | Page No | | | |
|---------|---|--------------------------------------|---------------|--|--|--|
| 1 | Scope | | | | | |
| 2 | Definitions and glossary of abbreviations | | 8 | | | |
| 3 | Statement of authority | | 10 | | | |
| 3-1 | Responsibilities | | 10 | | | |
| 3-2 | Codes and Standards | | 10 | | | |
| 3-3 | Signature | | 10 | | | |
| 4 | Organization chart | | 11 | | | |
| 5 | Manual control | | 11 | | | |
| 6 | Drawing and design control | | N/A | | | |
| 7 | Manufacture | | N/A | | | |
| 8 | Assembly | | N/A | | | |
| 9 | Modification | Modification | | | | |
| 10 | Repairs | | N/A | | | |
| 11 | Material Control | | | | | |
| 12 | Inspection and testing - examination | | 22 | | | |
| 12-1 | Inspection program | | 23 | | | |
| 12-2 | External visual inspection (V) | | 24 | | | |
| 12-3 | Internal visual inspection(I) | | N/A | | | |
| 12-4 | Upper Coupler area inspection(UC) | | N/A | | | |
| 12-5 | Leakage inspection (K) | | | | | |
| 12-6 | Thickness test (T) | | | | | |
| 12-7 | Pressure tests (P) | | N/A | | | |
| | | Quality Control Manual in accordance | with CSA B62(| | | |
| 2 | | | | | | |

Date of Issue: 2019/04/29

Rev. No.: 04

Page: 3 of 150

| Item No. | TABLE OF C Subject | | Page No | | |
|----------|---|--|----------------|--|--|
| | | | | | |
| 12-8 | Product hose testing procedure | | 53 | | |
| 12-9 | Internal inspection by wet fluorescent magnet | ic particle inspection | NA | | |
| 12-10 | References | | 54 | | |
| 13 | Test and inspection marking | | 56 | | |
| 14 | Nonconformities – corrective action | | 57 | | |
| 14-1 | Identification of non-conformities | | 57 | | |
| 14-2 | Examples of tank non-conformities | | 57 | | |
| 14-3 | Retest | | 57 | | |
| 14-4 | Calibrated equipment | | 58 | | |
| 15 | Welding/ brazing control | | | | |
| 16 | Calibration | | | | |
| 16-1 | General | | 62 | | |
| 16-2 | Procedure | | 62 | | |
| 16-3 | References | | 62 | | |
| 17 | Quality audits | | 63 | | |
| 17-1 | General | | 63 | | |
| 17-2 | Reference | | 63 | | |
| 18 | Registration – facilities and personnel | | 64 | | |
| 18-1 | Facility registration | | | | |
| 18-2 | Personnel registration | | | | |
| 18-3 | Reference | | | | |
| 19 | Mobile units | | 66 | | |
| | 1 | Quality Control Manual in accordance w | ith CSA B620 | | |
| | NATIONAL ENERGY | Prepared by / Approved by: Arash Navidan / | Zanyar Farhadi | | |
| E | NATIONAL ENERGY | Control Number: NEE-QCM-THB-001 | | | |

Date of Issue: 2019/04/29 **Rev. No.:** 04

Page: 4 of 150

| TABLE OF CONTENT | | | | | | |
|--|---------------------------------------|--|--------------|--|--|--|
| Item No. | Subject | | Page No. | | | |
| 19-1 | General | | 66 | | | |
| 19-2 | Mobile Equipment | | 66 | | | |
| 20 | Records retention | | 67 | | | |
| 20-1 | General | | 67 | | | |
| 20-2 | Reference | | 68 | | | |
| 21 | Exhibits | | 69 | | | |
| 21-1 | Reference forms and documents | | 69 | | | |
| 21-2 | Equipment, signs and decals | | 139 | | | |
| 21-3 | Samples of actual completed documents | | 141 | | | |
| 22 | Revision control sheet | | 149 | | | |
| | | | | | | |
| | | | | | | |
| NATIONAL ENERGY EQUIPMENT INC. | | Quality Control Manual in accordance B620 Prepared by / Approved by: Arash Navidan / Zar Control Number: NEE-QCM-THB-001 | | | | |
| | | Date of Issue: 2019/04/29 Rev. No.: 04 Pa | ge: 5 of 150 | | | |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 6 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 7 of 150 |

SECTION - 1 Scope

This manual applies to the National Energy Equipment Inc. (NEEI) facility with the registration number of **25-1239**, located at **46A Haniak Road, Rosslyn Ontario P7K 0C8**, only to those Highway Transport tanks manufactured in accordance with the specifications contained in the CSA B620.

Work is including all or some of the followings: inspection, test and retest of highway tanks.

| | Tank Specification | Inspection - External | Inspection - Internal | Inspection - Lining | Inspection - Upper coupler | Test/Retest - Hydrostatic | Test/Retest - Pneumatic | Test/Retest - Leak Test | Test/Retest - Fluorescent Test | Test/Retest - Thickness Test | Tanks - Repair | Tanks - Manufacture | Tanks - Assembly | Tanks - Modification | Piping - Repair | Piping - Manufacture | Piping - Modification |
|---------------|-----------------------|--------------------------|--------------------------|------------------------|-------------------------------|------------------------------|----------------------------|----------------------------|-----------------------------------|---------------------------------|-------------------|------------------------|---------------------|-------------------------|--------------------|-------------------------|--------------------------|
| Highway Tanks | TC 406 TC 306 | M | | | | | | M | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |

| Z NATIONAL ENERGY EQUIPMENT INC. | | Quality Control Manual in accordance with CSA B620 | | | | |
|---|--|---|--|--|--|--|
| Document Numb | er: NEE-QCM-THB-001 | Revision Number: 04 | | | | |
| Prepared by / Approved by: Date of Issue: 2019/04/29 | | Arash Navidan / Zanyar Farhadi | | | | |
| | | Page Number: 8 of 150 | | | | |
| SECTION - 2 | 2 Glossary of Abbreviations | and Definitions | | | | |
| ASME | American Society of Mechanical Engineers (generally refers to boiler and pressure vessel codes) | | | | | |
| AWS | American Welding Society | | | | | |
| CODE | The code or specification that the ta | nk is built to (eg. MC 306, TC 406) | | | | |
| CSA | Canadian Standards Association | | | | | |
| CSA B620 | The Canadian Standard that include requirements (Revision 14 or most | s highway tank specifications and inspection and testing current version) | | | | |
| DOT | United States Department of Transp | portation | | | | |
| Field welding | Any welding performed at locations | s other than the facility address | | | | |
| FRP | Fibre-reinforced plastic. | | | | | |
| HAWP | Hose assembly working pressure (the anticipated working pressure of the hose assembly, which does not exceed the maximum working pressure of the hose assembly's lowest-rated component.) | | | | | |
| Hot work | Any work involving welding, cuttin | g, grinding, drilling, or exposure to open flame. | | | | |
| "Г" | The cargo tank marking that indicat | es an INTERNAL visual inspection | | | | |
| ISC | Internal Self Closing (valve) | | | | | |
| "К" | The cargo tank marking that indicat | es a LEAK test | | | | |
| MAWP | The maximum allowable working p | ressure of a cargo tank as indicated on the data plate | | | | |
| MDIN | Manufactures Design Identification | Number | | | | |
| MC | Motor Carrier as used in code desig | nations (eg. MC 306) | | | | |
| NEEI | National Energy Equipment Inc. | | | | | |
| "P" | lining the cargo tank marking that in | ndicates a PRESSURE test | | | | |
| PSI | Pounds per square inch | | | | | |
| Remount | Mounting a previously certified highway tank onto a different vehicle chassis or vehicle suspension component, or a change to the original means of securement or tank mounting system. A remount is a modification. | | | | | |
| Repair | . | gn and specification by welding on the tank wall, on the tank such as the rollover dam, tank sill, or baffles, and ing. This term does not include: | | | | |
| | components, steering and bra | ipment, such as lights, truck or tractor power train ke systems, and suspension parts; ch as fender attachments, lighting brackets, and ladder | | | | |

| | NATIONAL ENERCY |
|---|-------------------------------------|
| 7 | I NATIONAL ENERGY EQUIPMENT INC. |
| | EQUITMENT INC. |

Quality Control Manual in accordance with CSA B620

| Document Number: NEE-QCM-THB-001 Revision Number: 04 Prepared by / Approved by: Arash Navidan / Zanyar Farhadi Date of Issue: 2019/04/29 Page Number: 9 of 150 ic: 0 replacement of components, such as valves, vents, or fittings, with components of a similar design and of the same size and capacity; and (d) replacement of an attachment other than an integral structural component of the tank by welding to a mounting pad. Retrofit A change to a previously certified highway or portable tank that brings the tank into compliance with the latest revision of the specification to which the tank was originally constructed. Depending on the scope of the change, the retrofit can involve a modification of the highway or portable tank (see Modification). SRV Safety Relief Valve "T" The cargo tank marking that indicates a THICKNESS test TC Transport Canada TDG Transport Canada Registration Number UC Upper Coupler "V" The cargo tank marking that indicates an EXTERNAL visual inspection WPS Weld Procedure Specification | | | | | | | |
|---|----------------|---|----------------------------------|--|--|--|--|
| Date of Issue: 2019/04/29 Page Number: 9 of 150 (c) replacement of components, such as valves, vents, or fittings, with components of a similar design and of the same size and capacity; and (d) replacement of an attachment other than an integral structural component of the tank by welding to a mounting pad. Retrofit A change to a previously certified highway or portable tank that brings the tank into compliance with the latest revision of the specification to which the tank was originally constructed. Depending on the scope of the change, the retrofit can involve a modification of the highway or portable tank (see Modification). SRV Safety Relief Valve "T" The cargo tank marking that indicates a THICKNESS test TC Transport Canada TDG Transport Canada Registration Number UC Upper Coupler "V" The cargo tank marking that indicates an EXTERNAL visual inspection | Document Nu | mber: NEE-QCM-THB-001 | Revision Number: 04 | | | | |
| (c) replacement of components, such as valves, vents, or fittings, with components of a similar design and of the same size and capacity; and (d) replacement of an attachment other than an integral structural component of the tank by welding to a mounting pad.RetrofitA change to a previously certified highway or portable tank that brings the tank into compliance with the latest revision of the specification to which the tank was originally constructed. Depending on the scope of the change, the retrofit can involve a modification of the highway or portable tank (see Modification).SRVSafety Relief Valve "T"The cargo tank marking that indicates a THICKNESS testTCTransport CanadaTDGTransport Canada Registration NumberUCUpper Coupler "V""V"The cargo tank marking that indicates an EXTERNAL visual inspection | Prepared by / | Approved by: | Arash Navidan / Zanyar Farhadi | | | | |
| similar design and of the same size and capacity; and (d) replacement of an attachment other than an integral structural component of the tank by welding to a mounting pad.RetrofitA change to a previously certified highway or portable tank that brings the tank into compliance with the latest revision of the specification to which the tank was originally constructed. Depending on the scope of the change, the retrofit can involve a modification of the highway or portable tank (see Modification).SRVSafety Relief Valve "T""T"The cargo tank marking that indicates a THICKNESS testTCTransport CanadaTDGTransport Canada Registration NumberUCUpper Coupler "V""V"The cargo tank marking that indicates an EXTERNAL visual inspection | Date of Issue: | 2019/04/29 | Page Number: 9 of 150 | | | | |
| compliance with the latest revision of the specification to which the tank was originally constructed. Depending on the scope of the change, the retrofit can involve a modification of the highway or portable tank (see Modification).SRVSafety Relief Valve"T"The cargo tank marking that indicates a THICKNESS testTCTransport CanadaTDGTransport ada Registration NumberUCUpper Coupler"V"The cargo tank marking that indicates an EXTERNAL visual inspection | | similar design and of the same (d) replacement of an attachment | e size and capacity; and | | | | |
| "T" The cargo tank marking that indicates a THICKNESS test TC Transport Canada TDG Transportation of dangerous goods TCRN Transport Canada Registration Number UC Upper Coupler "V" The cargo tank marking that indicates an EXTERNAL visual inspection | Retrofit | compliance with the latest revision of the specification to which the tank was originally constructed. Depending on the scope of the change, the retrofit can involve a modification of | | | | | |
| TCTransport CanadaTDGTransportation of dangerous goodsTCRNTransport Canada Registration NumberUCUpper Coupler"V"The cargo tank marking that indicates an EXTERNAL visual inspection | SRV | Safety Relief Valve | | | | | |
| TDGTransportation of dangerous goodsTCRNTransport Canada Registration NumberUCUpper Coupler"V"The cargo tank marking that indicates an EXTERNAL visual inspection | "T" | The cargo tank marking that indicate | es a THICKNESS test | | | | |
| TCRNTransport Canada Registration NumberUCUpper Coupler"V"The cargo tank marking that indicates an EXTERNAL visual inspection | TC | Transport Canada | | | | | |
| UCUpper Coupler"V"The cargo tank marking that indicates an EXTERNAL visual inspection | TDG | Transportation of dangerous goods | | | | | |
| "V" The cargo tank marking that indicates an EXTERNAL visual inspection | TCRN | Transport Canada Registration Num | ber | | | | |
| | UC | Upper Coupler | | | | | |
| WPS Weld Procedure Specification | "V" | The cargo tank marking that indicate | es an EXTERNAL visual inspection | | | | |
| | WPS | | | | | | |
| | | | | | | | |

| Quality Control Manual in accordance with CSA B620 |
|---|
| Revision Number: 04 |
| Arash Navidan / Zanyar Farhadi |
| Page Number: 10 of 150 |
| |

SECTION - 3 **Statement of Authority**

This manual outlines the requirements for the activities, as detailed in Section 1. In addition, this program addresses the National Quality Systems Manager's responsibility, which details the support of the management of National Energy Equipment Inc. (NEEI), for administrating the quality control program and the various related standards to be used for the activities.

3-1 Responsibilities:

All involved personnel are totally committed to meeting the requirements of CSA B620, NEEI policies, and the quality control system outlined in this manual.

The National Quality Systems Manager (NQSM) is responsible for the preparation, revision, approval and issuance of the quality control manual. The NQSM and Quality Assurance Specialist (QAS) are responsible for the administration and implementation of the quality control program in the shops. Each NEEI branch's Process Owner, shall help them in accordance with the quality control program. The NQSM has the responsibility and authority to control production, and the organizational freedom to:

- Identify quality control problems;
- Initiate action, which results in solutions to those problems;
- Verify implementation of solutions to those problems; and
- Control further processing, delivery or unsatisfactory condition until proper disposition has been made.

Process Owners will be responsible for their assigned activities. They may delegate the performance of their assigned duties to qualified individuals but they shall retain the responsibility for those assigned activities.


In the event of a disagreement between the responsible person and the Process Owner, the problem shall be brought to the NQSM for resolution. Any resolution shall not negate the requirements of CSA B620, or this Manual

3-2 Codes and standards

The latest edition of codes and standards of Canadian Standards Association (CSA) which are specified in Transportation of Dangerous Goods of Transport Canada shall be applied for B620 program. Any other standards which are mentioned in Transport Canada website, also shall be used.

3-3 Signature

Signed: Title: Date:



SECTION- 5 Manual Control

This Manual and its revisions shall be prepared, issued, maintained, and approved by the National Quality Systems Manager. The approval and acceptance of the National Quality Systems Manager are shown on each page of the manual.

This Manual shall be reviewed at least once a year at the management review meeting to ensure all procedures are current and in conformance with CSA B620 or most current version and be revised at that time if required.

If revisions are required to this Manual they shall be implemented at the date the changes in regulation take effect. The only controlled copy of the latest revision of Manual is placed in the NEEI's intranet.

Revision shall be described in the revision control sheet (section22) and noted on the Table of Contents and each page of the Quality Control Manual.

The National Quality Systems Manager shall issue, distribute and maintain copies of this Quality Control Manual and its revisions. The same person is responsible for removal of superseded versions from circulation.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 12 of 150 |

SECTION- 6 Drawing and design control

N/A

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 13 of 150 |

SECTION- 7 Manufacture

N/A

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 14 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 15 of 150 |

SECTION- 8 Assembly

N/A

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 16 of 150 |

| NATIONAL ENERGY | |
|-------------------------|--|
| Z EQUIPMENT INC. | |

Quality Control Manual in accordance with CSA B620

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 17 of 150 |

SECTION-9 Modification

N/A

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 18 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 19 of 150 |

SECTION- 10 Repairs

N/A

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 20 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 21 of 150 |

SECTION - 11 Material Control

N/A

| I NATIONAL ENERGY | , |
|-----------------------------------|---|
| NATIONAL ENERGY EQUIPMENT INC. | |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Date of Issue: 2019/04/29

Page Number: 22 of 150

Arash Navidan / Zanyar Farhadi

Revision Number: 04

SECTION - 12 Inspection and testing – Examination

For each tank design, all drawings, design calculations, and specifications shall be in accordance with CSA B620, and selected by B621 or B622 Standards (the most current version),

As applicable, the NEEI plans and carries out production and service provisions under controlled conditions. Controlled conditions include:

1) the availability of information that describes the characteristics of the product,

2) the availability of work instructions, as necessary,

3) the use of suitable equipment,

4) the availability and use of monitoring and measuring devices,

5) the implementation of monitoring and measurement activities, and

6) the implementation of product release, delivery and post-delivery activities.

The Inspector shall have free access to such parts of all plants involved in the repair/modification. These shall include, but shall not be limited to the following:

- a) Shop (Plant)
- b) Quality Control Manual
- c) Warehousing

The Process Owner shall be responsible for:

1) Ensuring that all required examinations and inspections are performed in compliance with the current edition of CSA B620 and TDG regulations and shall ensure that these examinations and inspections are done in accordance with approved procedures,

2) Collecting all related documentation such as design changes, calculations, specifications, repairs, examination and test reports, travel sheets into the Job File for each Highway Tank being recertified,

3) Maintaining the Job File (by job number and/or serial number).

4) Inspection prior to assembly of a new Tank, or reassembly of a modified tank,

5) Collecting the Manufacturer's Partial Certificate of Compliance, plus any test reports generated during manufacture or modification, and verify that all functions have been completed.

6) Maintenance of reports and certificates to be kept in the Job File and final copies issued to tank owner.

| NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 23 of 150 |

For all tanks that are to be inspected or tested, the inspector or tester shall ensure that all precautions are taken to ensure that there is no hazard to personnel performing the inspection and test.

Prior to any examination or inspection being performed, each tank shall be cleaned and decontaminated.

12.1 Inspection Program

All tanks shall be inspected and tested in accordance with CSA-B620 subject to the annotations to the tables. (Section 21.1)

The inspection reports shall be documented on the Test and Inspection Report (Form No. NEE-FRM-007).

12.1.1 Periodic and obligatory inspection and testing.

Periodic inspection and test intervals are based on tables 7.1 and 7.2 of CSA-B620. (Section 21.1)

If more than one test or inspection interval is prescribed for a given tank in a particular service, then the shortest interval shall apply. The due dates for the first periodic retest and inspection are measured from the original test and inspection date marked on the tank, or if no test date is marked, the certification date.

In addition to the periodic retesting or inspection requirements, hydrostatic or pneumatic retesting and inspection shall be required prior to further use if:

1) a tank shows evidence of bad dents, corroded or abraded areas, leakage, or any other condition that might render the tank unsafe for transportation service;

2) the tank has been involved in an accident in which it may have been dented, torn, or otherwise damaged so as to affect its lading retention capability;

3) the tank has not been used for transporting dangerous goods for 1 year or more; or

4) the tank is new or modified from its original design, and the modification involves work on product-retaining components.


| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 24 of 150 |
| | |

12.2 External Visual Inspection (V)

Typical interval is every year (annually)

12.2.1 Highway tanks for the transportation of dangerous goods other than liquefied compressed gases TC406(306)

TC406, Older version:TC306



Highway tank for flammable liquids and low hazard chemicals (e.g. gasoline, diesel); Steel or aluminum shell or reinforced plastic (FRP tanks is not in the scope); MAWP between 18 and 28 kPa (2.65 and 4 psi); If transporting crude, MAWP between 18 and 100 kPa (2.65 and 14.7 psi);

- 1) Inspect all tank markings for legibility. Markings must not be faded, defaced or torn.
- 2) Inspect to ensure that all information on the tank data plate are concise and legible. If data plate or on the tank is illegible or information is incomplete, note on the Inspection Report and reject tank. For complete list of the required information, refer to 'Required information on the Identification Plate checklist'.
- 3) Inspect to ensure each manhole cover is permanently marked with
 - a. the manufacturer's name;
 - b. the test pressure XXX kPa (psi); and
 - c. a statement certifying that the manhole cover meets the testing requirements of
 - i. clause 5.6.6 of CSA B620; or
 - ii. §178.345-5 of 49 CFR
- 4) Inspect entire exterior surface area including heads for signs of corrosion, abrasion, gouges, dents or repairs made using overlay patches. Inspect surfaces of all welds for signs of defects or cracks visually by checking with hand and using flashlight if needed, especially in areas around tank nozzles.
- 5) Corroded or abraded areas of the tank shell will be thickness tested. <u>Measure with the thickness tester</u>: 1. Remove rubber cap from probe; 2. Single drop of couplant (Gel) must be applied to the surface to be tested; 3. Zero the probe according to the manufacturer instructions; 4. Place the probe flat on the surface and use moderate pressure to press against the top of the probe with the thumb or index finger and read the result on the display, which shall be indicated on, or attached to the report.
- 6) Ensure manhole tightening devices are operative, and the covers are leak-tight, with no signs of product stains.
- 7) Ensuring proper functioning of all valves, vents, and emergency devices, including pressure relief valves, self-closing stop-valves, excess-flow valves, and remote closure devices, and connections are properly identified (emergency closure, liquid and vapour, etc.) ensuring that they are free of corrosion, distortion, or any other damage that would prevent their normal operation.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 | |
|--|---|--|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | Page Number: 25 of 150 | |
| Shall be externally inspected for any corrosion or damage that might prevent their safe operation. On tanks that carry lading corrosive to the valves, either replace or test to ensure that they open at the required set to discharge pressure for the tank's MAWP and reseat them to a leak-tight condition at not less than 90% of that pressure, or to the re-seat pressure prescribed for the tank specification. | | |
| 9) Ensuring that all bolts or nuts on any flanged connection or blank flange are in place and properly tightened by checking with a proper wrench. | | |
| 10) Ensuring that all major appurtenances, piping, attachments, connecting structures, and those elements of the | | |

- 10) Ensuring that all major appurtenances, piping, attachments, connecting structures, and those elements of the upper coupler assembly (if applicable) that can be inspected without dismantling the assembly are not damaged or corroded so as to affect safe operation of the vehicle.
- If upper coupler is due for removal, drop upper coupler and inspect areas covered by upper coupler for corrosion, abrasion dents, distortion, weld defects or any other condition that might render the tank unsafe. Inspect upper coupler area for cracks or distortions.
- 12) Ensure that hose assemblies mounted on or accompanying the tank do not display any defects, have legible markings, and where required, have been pressure tested, indicating that they were pressure tested.
- 13) Ensure any void drains are unplugged and inspect for signs of product residue or leakage.
- 14) Ensure that all bolts used to secure tank to the frame are present. Use a proper wrench to confirm bolts are tight.
- 15) Rollover protection facilities are properly installed on the tank. The welding of any appurtenance to the shell or head must be made by attachment of a mounting pad.
- 16) Bumpers of the cargo tank is properly installed to the specified dimensions, and it will successfully absorb the impact of the vehicle with rated payload. The clearance between the effective bottom of the bumpers or devices and the ground is less than 76cm (30in) when the vehicle is empty;
- 17) The original metal identification plate in any condition shall not be removed.
- 18) NEEI Thunder Bay's Certificate of Registration does not include manufacture, assembly, modify, or repair on TC406/TC306 tank specifications. Therefore, NEEI Thunder Bay cannot stamp or install a replacement metal ID plate on a TC406/TC306 tank as outlined in clause 7.7.3.1 of CSA-B620-14.
- 19) Ensure that the tank is equipped with one or more dry chemical fire extinguishers accessible from the ground, with a combined total effective rating of not less than 40BC. Each of them shall be recharged immediately after each use.
- 20) Ensure that the tank is equipped with an automatic engine air intake shut off device that prevent engine runaway in case of exposure to flammable vapours. The device shall activate automatically if engine runaway is detected and remain activated until manually reset.
- 21) In addition to the rejection criteria (as stated in Clause 7.2.1.8 of CSA B620), reject the tanks when the following defects are found during an external inspection:



Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Date of Issue: 2019/04/29

Page Number: 26 of 150

- When the thickness remaining under a cut, dig, or gouge is either below the minimum thickness specified on the nameplate; or

Revision Number: 04

Arash Navidan / Zanyar Farhadi

- Any dent with a depth of more than 12.7 mm (0.5 in) where it includes a weld;
- Any dent with a depth of greater than 10% of the length of the dent,
- Any weld defect, including a crack, pinhole, or incomplete fusion of the weld;
- Any structural defect; and
- Any source of leakage, or
- Repairs made to liquid-retaining components using overlay patches.
- When any noted CSA B620 design requirements are not met such as impact protection or rear bumper restrictions, etc.
- 22) Ensure all outlets, valves, closures, piping, or any devices that if damaged in an accident could result in a loss of lading, are protected by accident damage protection.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 27 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 28 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 29 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 30 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 31 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 32 of 150 |

12.2.2 Highway tanks for the transportation of liquefied compressed gases and refrigerated liquefied gases NA

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 33 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 34 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 35 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 36 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 37 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 38 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 39 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 40 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 41 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 42 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 43 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 44 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 45 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 46 of 150 |

12.3 Internal Visual Inspection (I)

NA

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 47 of 150 |

12.4 Upper Coupler Inspection (UC)

NA

12.5 Leakage Test (K) - Typical interval is every year (annually)

The tank shall successfully pass an External Visual Inspection prior to performing this test and if this test is being conducted at the frequency a pressure re-test is due, the pressure re-test shall be conducted first.

All product piping valves and accessories shall be in place with the exception of any normal breathing vents (vents set to release at less than test pressure), which shall be rendered inoperative.

Test pressure shall be not less than 80% of the tank design test pressure or MAWP, whichever is less, and marked on the certification plate, except if a tank with a MAWP of 690 kPa (100 psig) or more is used in dedicated service or services, the test pressure shall be the maximum normal operating pressure of the tank.

1) Put in place a Pressure Safety Relief valve and set at MAWP.

2) Test each valve and closure in sequence, with the tank laden under normal operating conditions

3) Close internal valve and open manifold valve (if equipped) and all other valves in discharge line, including external valve.

4) Ensure any adjacent compartments and void spaces are empty and open to atmosphere i.e. double walled tanks.

5) Fill compartment with enough test medium to cover the valve sump and fill the piping. Close all remaining openings.

- One of the following shall be used as the test medium:
 - (i) the normal lading of the tank;
 - (ii) a less hazardous lading of equal or less viscosity;
 - (iii) water;
 - (iv) inert gas;
 - (v) air.

Note: When using air as a test medium, the tester should be aware of the need for proper purging and ensure that there is no possibility of creating a mixture of product and air within the explosive limits of the product.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 48 of 150 |

6) Pressurize the tank to the correct pressure with regulated air. Once the test pressure is reached, shut off the supply. The test pressure must be maintained for at least 5 minutes with no loss. If a tank is in dedicated service and over 100 psi the normally lading of the product will be used at the maximum of the normal operating pressure. MC 331 or TC 331 in LPG or NH3 service shall be tested at no less than 60 PSI.

7) With tank under pressure, check all weld seams with soap and water mix. Check for signs of any leakage. Inspect gaskets at internal valves and manhole covers, and venting devices.

8) Close first value or closure in discharge system and open internal value, leaving all other values in discharge line open including external value. Adjust pressure to the correct pressure for the tank being tested and shut off the supply. The piping and the first value in discharge system will now be pressurized in addition to the tank shell; test pressure must hold for 5 minutes with a 0 psig drop.

9) Repeat the above procedure (8) for each valve and closure in discharge line, until all valves and closures have been tested. If piping includes pumps and meters these should be tested at the tank leak test pressure in sequence with the immediate downstream valve or closure closed and all upstream valves and closures open. Carefully inspect all joints in pumps and meter for signs of leakage. If piping system includes hose reel, unreel the hose to its full length and carefully inspect hose connections for leakage.

10) Relieve pressure in tank and ensure normal breathing vent is returned to operative status.

11) Indicate all defects found and methods used to repair on the Test and Inspection Report (Form No.: NEE-FRM-007) in accordance with clause 7.3 of CSA B620.

12) All leaks must be repaired and retested prior to marking tank.

13) During the test, precautions shall be taken to prevent overpressurization of the tank.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 49 of 150 |

12.6 Thickness Test (T) (Only at periodic inspections)

| NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 50 of 150 |

12.7 Pressure Tests (P)

NA

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 51 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 52 of 150 |

| - | NATIONAL ENERGY | |
|---|-----------------|--|
| | EQUIPMENT INC. | |

| / | |
|----------------------------------|--------------------------------|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 53 of 150 |

12.8 Product hose testing procedure

12.8.1 Scope This procedure covers hose testing requirements in accordance to B620, Clause 7.2.10., and applies to hose assemblies connected to the tank or any tank-mounted accessory during loading or off-loading, but do not apply to hose assemblies less than 1.5 m (5 ft) in length that are part of the piping system and are pressure tested in accordance with Clause 7.2.7.

Hoses may be tested annually on or off the vehicle.

Hoses may be tested by other qualified hose testing organizations.

- 12.8.2 Frequency All hoses shall be tested once per year
- 12.8.3 Safety Hose testing shall be performed in a manner that ensures provisions will be made to protect personnel during testing in the event of a hose failure.

12.8.4 Training All employees involved in hose testing shall be trained in testing procedures and rejection criteria. Records of training shall be kept in the related employment files.

- 12.8.5 Procedure (a) A hose assembly having any damage identified in Clause 7.2.10.4 shall be taken out of service and not be pressure tested until repaired.
 - (b) The test pressure shall be
 - (i) for CSA-certified hose assemblies, not less than 2400 kPa (350 psi);
 - (ii) for gravity off-load hose assemblies (drop hoses), not less than 69 kPa (10 psi);
 - (iii) for vapour recovery hose assemblies on TC 406 tanks and the equivalent and substitute tanks identified in CSA B621, not less than 69 kPa (10 psi);
 - (iv) for vacuum hose assemblies on tanks loaded by vacuum, used exclusively for vacuum loading, and marked "vacuum only" in place of HAWP as specified in Clause 7.2.10.6, not be less than 69 kPa (10 psi); and
 - (v) not applicable to vacuum hoses that are
 - (1) an integral part of a boom assembly or vacuum system on tanks loaded by vacuum;
 - (2) used exclusively for vacuum loading; and
 - (vi) for all other hose assemblies, the greater of 120% of the marked HAWP of the hose assembly and 518 kPa (75 psi).
 - (c) The following shall not be used to pressurize the hose assembly:
 - (i) compressed gas;
 - (ii) compressed air;
 - (iii) flammable liquid; or
 - (iv) corrosive liquid.
 - Note: Water is the recommended test fluid.
 - (d) The requirements of Item (c) shall not apply to
 - (i) hose assemblies used to handle aircraft fuel;
 - (ii) CSA-certified hose assemblies; or
 - (iii) hose assemblies used in refrigerated liquefied gas service that are manufactured and documented as conforming to CSA B51 or ASME B31.3 and marked "CSA B51" or "ASME B31.3" by the hose assembly manufacturer.

| | AL ENERGY ENT INC. | Quality Control M in accordance with C | |
|---|---|---|---|
| Document Number: NEE-QCM-THB-001 | | Revision Number: 04 | |
| Prepared by / Approved by: | | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | | Page Number: 54 of 150 | |
| (e) P | provisions shall be made to p | protect personnel during testing should | failure occur. |
| | 1 1 | e hose assembly shall hold the pressu t 5 min when isolated from the pressu | 0.01 |
| 12.8.6 Hose Markings | shall be either tagged with to affect the integrity of t with the month and year already marked may be de hose and coupling manufa for markings applied dur pressure for the component tested. Hose assemblies for If not already marked or | on of the Hose Inspection and Testi a metal tag or stamped on the couplin he hose, with letters/numbers of not of the test. The HAWP for a hose a etermined by referring to documentat cturer or supplier or by inspecting the ing manufacturing that indicate the it. A HAWP shall be marked on a hose r which ratings cannot be determined in the hose assembly, markings shall or identification number of the hose as | g, in such a way not less that 5mm high, assembly that is not ion provided by the base and couplings maximum working that is successfully shall not be marked. also be applied to |
| 12.8.7 Test Report12.9 Internal inspec | the hose assembly serial of | | ne date and nature of |
| 12.9 References | | | |
| NEE-FRM-007 | Test and Inspection R | leport | (See 21.1) |
| NEE-FRM-012 | Hose Assembly Test | and Inspection Report | (See 21.1) |
| Table 7.1 of CSA B620 | Periodic inspection and | nd test intervals | (See 21.1) |
| Table 7.2 of CSA B620 | Additional periodic in | nspection and test intervals | (See 21.1) |
| Table 7.3 of CSA B620 | Pressures for periodic | retesting | (See 21.1) |
| Table 7.4 of CSA B620 | Minimum thickness f manufactured with ste | or TC and MC 306, 307, and 312 speceel and steel alloys. | ification tanks (See 21.1) |
| Table 7.5 of CSA B620 | | or TC and MC306,307, and 312 specif iminum and aluminum alloys. | ication tanks (See 21.1) |
| Required information on the Identification Plate che | | ecklist | (See 21.1) |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 55 of 150 |

| NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 56 of 150 |

SECTION-13 Test and inspection marking

Upon successful completion of a test or registered activities in compliance with CSA B620, the tank inspector shall mark the tank in accordance with this section.

The markings shall be a minimum of 32mm high and clearly contrast with the background and shall be located on the tank front head or jacketing or above the identification plate, or anywhere on the front head where it is clearly visible from the ground. The markings shall be printed on durable labels and affixed to tanks firmly.

The markings shall consist of:

- The month and year of the inspection or test
- The letter indicating the type of inspection or test performed (in accordance with Clause 7.4 of CSA B620)
- The last four digits of the Facility Registration Number, as shown on the TC Certificate of Registration for the facility

The letters indicating the types of test of inspection shall be as follows:

"V" - External Visual Inspection

"K" - Leakage Test

Typical Marking: 02/19 VK 1239

where: 02/19 indicates Inspection and Test performed February 2019; VK indicates External Visual and Leakage Tests were successfully completed; 1239 indicates the last digits of the Transport Canada Facility Registration number

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 57 of 150 |

<u>SECTION - 14</u> Nonconformities – Corrective action

A non-conformity is any condition in process, equipment, material, fabrication or attachment that does not meet all the requirements of the specifications the Highway Tank is constructed to, or the requirements of this Quality Control Manual.

When a nonconformity or a quality control problem happens or is probable to happen, it will be reported to the national quality system manager, who makes sure the specified root cause analysis and the related corrective / preventive action(s) are taken to avoid repetition of the nonconformity.

14.1 Identification of Nonconformities

It is the duty of all employees to report non-conformities to their supervisors. Non-conforming condition shall be notified to the national quality systems manager. All corrective actions start with an investigation to determine the root cause(s) of the problem. A thorough analysis of all related processes, operations, quality records, and specifications, which may have contributed to the deficiency, is conducted by the responsible function(s). All potential corrective actions are identified and the action(s) most likely to eliminate the problem and to prevent recurrence is selected. The investigation and analysis of the root cause and preventive measures shall be documented in Non Conformance Corrective and Preventative Action Report form (Form No. NEE-FRM-017). The analysis shall include review of all applicable data to determine the extent and cause of the problem and analysis of trends in processes or performance of work to prevent nonconformities.

All problems are evaluated in terms of potential impact on quality, performance, reliability, safety, and customer satisfaction. Resolutions to all corrective and preventive actions are to a degree appropriate to the magnitude and the risk of the problem. Resolutions are reviewed and approved by the national quality systems manager **or** his designated representative.

14.2 Examples of Tank Nonconformities

- Routine maintenance Items when the non-conformity is of a routine maintenance nature (eg. leaking gasket seized remote release, etc.)

- Repair or rework when the non-conformity requires repair work (eg. severe corrosion between dissimilar materials, distortion in the tank shell or abrasions, etc.), the procedures for repair will be discussed with the Process Owner. No repairs or rework shall be performed on non-metallic tanks.

- Repairs of the tank liquid retention components by welding/ brazing where defects are found that require welding/ brazing it will be written on a Welding Inspection Report, which include details of area welded, welding/ brazing procedure and welder/ brazer identification.

- All repairs shall be performed in compliance with the specification of the original design of the tank, in a facility registered with Transport Canada to perform that scope of work.

- All repairs shall be such that there will be no increase in the probability of cracking due to areas of increased stress due to shrinkage of cooling weldments.

- All welding/ brazing of lading retention components shall only be performed on tanks with design pressures less than 103 kpa (15 psig). Upon completion a welding/ brazing inspection shall be completed.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 58 of 150 |

- Any non-conformance that becomes recurring shall be brought to the attention of the Process Owner who shall bring it to the attention of a Registered Design Engineer where appropriate.

- Any non-conformance that is discovered related to Test and Inspection activities shall be brought to the attention of the Process Owner. The non-conformance shall be reviewed.

14.3 Retest

Upon correction of any tank non-conformity, the tank shall be re-tested in accordance with the requirements for the new construction of a tank of the same specification or by pressure testing of repaired lading retention components.

14.4 Calibrated Equipment

Any non-conformity discovered in the Calibrated Equipment shall be resolved in accordance with Section 16 (Calibration) of this Manual.

14.5 Reference

- NEE-FRM-017 Nonconformance corrective and preventative action report form (See 21.1)

| NATIONAL ENERGY | , |
|--|---|
| Z NATIONAL ENERGY EQUIPMENT INC. | |

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 59 of 150 |

SECTION - 15 Welding control

NA

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 | |
|--|---|--|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | Page Number: 60 of 150 | |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 | |
|--|---|--|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | Page Number: 61 of 150 | |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 | |
|--|---|--|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | Page Number: 62 of 150 | |

SECTION - 16 Calibration

16.1 General

All test and inspection equipment used in Inspection and Testing procedures of this Manual shall be calibrated in accordance with this section.

The Process Owner is responsible for maintaining all equipment in calibration.

Calibration may be performed by the Process Owner, or a qualified individual who has been assigned to the task and trained,

Pressure gauges or Digital Manometer used for pressure tests are calibrated to a certified calibrated master gauge weekly, or when there is reason to question their accuracy. The master gauge shall also be re-calibrated annually and the certificate keep on file. All gauge calibrations shall be documented on the Gauge Calibration Log (Form No. NEE-FRM-014). All equipment calibrations shall be documented on the Equipment Calibration Log (Form No. NEE-FRM-015)

The frequency of calibration for other equipment is as recommended by the equipment manufacturer or from experience with the equipment.

Material thickness shall be gauged using a micrometer, or ultrasonic thickness tester. The micrometer shall be calibrated prior to each use against a coupon or step block of known thickness. The ultrasonic thickness tester shall be calibrated against a step block of known thickness and compared against the micrometer. The step block shall be verified every 5 years or at any indication of damage or wear by a qualified inspection service.

When equipment requiring calibration is found to be out of calibration it shall be removed from the work area, repaired, re-calibrated or replaced.

All items checked without calibration equipment shall be considered as non-conforming until the Process Owner verifies that they meet all Specification requirements or, the items have been re-checked with appropriately calibrated equipment.

16.2 Procedure

Connect the gauge to be calibrated to the master gauge and pressure source.

Apply the pressure to the gauge to be calibrated in increments over the full range of the gauge.

Compare the value of pressure indicated by the master gauge with the corresponding value of the pressure indicated by the gauge being calibrated for each pressure increment. The values should be same with accuracy class of 1.6. limits of permissible error of this class is $\pm 1.6\%$ of gauge's full scale.

If necessary, adjust the gauge and repeat the above paragraph until the values are same in accuracy class 1.6.

After three trials, if the values are not same, the gauge is rejected and shall be removed from the work area.

16.3 References

| - | NEE-FRM-014 | Gauge Calibration Log | (See 21.1) |
|---|-------------|---------------------------|------------|
| - | NEE-FRM-015 | Equipment Calibration Log | (See 21.1) |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 63 of 150 |

SECTION - 17 Quality Audits

17.1 General

National quality systems manager is responsible for coordinating with Process Owners of facilities to plan a regular quality audit and closure corrective actions required to eliminate the recorded nonconformities based on the internal audits and the Non Conformance Corrective and Preventative Action Report form (From No.: NEE-FRM-017).

Certificates, forms and related documents which are listed in 'Mandatory document list' (see section 17.2).shall be completed in accordance with the related process.

Where these audits indicate that tanks may be out of compliance, those tanks shall be recalled and brought into conformance.

Where repair or re-work is required, the effectiveness of the repair or re-work shall be verified by performing the appropriate tests and inspections after work is completed.

Where these audits reveal repeated non-conformance, the relevant procedures in this manual shall be reviewed and where required, training initiated to eliminate non-conformance.

The national quality systems manager shall annually review the complete process to ensure it is in conformance with this Quality Control Manual in the management review meeting. This Management Review Meetings shall include, but is not limited to:

- Results of audits
- Facility Registration documents
- Inspector/Tester/Welder (or brazer) qualifications
- Material procurement and control
- Quality Control process performance
- Identification plate stamping and tank marking
- Status of non conformities, preventive and corrective actions
- Follow-up actions from previous management review meeting
- Recommendations for improvement


17.2 References

- NEE-FRM-017 Nonconformance corrective and preventative action report

(See 21.1)

- Mandatory Document List

(See 21.1)



SECTION - 18 Registration – Facilities and Personnel

18.1 Facility Registration

Facility registration is the responsibility of the National quality system manager (NQSM).

NQSM is responsible for ensuring the certificate of registration is current and covers all functions performed at the facility with the registration number of 25-1239, located at 46A Haniak Road, Rosslyn Ontario P7K 0C8.

For the scope of the registered facility, refer to the section one (1) of this quality control manual.

18.2 Personnel Registration

It is the responsibility of the Process Owner to ensure that Design Engineer is registered with TDG list of registered authorized personnel. See the registered personnel in the end of this section. All personnel are qualified by NEEI after a proper training and get the certificate of qualification (see section 18.3) for only those functions, which they have been qualified. Employee qualification records must be retained throughout the duration of employment and for five (5) years after employment. The minimum qualification requirements of CSA B620 Clause 8 as follows:

Design Engineers

Every Design Engineer shall

(a) be an engineer and shall hold a current license by the appropriate authorities of his or her residence in Canada or the United States to practise engineering; and

(b) have at least one year of experience in the design of highway tanks in accordance with CSA B620 or 49 CFR.

National Energy Equipment Inc. may use (but are not limited to) the following firms (See the registered personnel in the end of this section) when engineering duties are required.

Tank Inspector

Tank inspector shall have

(a) the knowledge and ability to determine if a tank conforms to a particular specification; and

(b) education and experience in the construction, inspection, testing, or retesting of tanks of that specification, as follows:

(i) an engineering degree or professional engineer status in a province of Canada, and one year of experience;

(ii) a technical diploma and two years of experience;

(iii) a high-school diploma and three years of experience; or

(iv) five years of experience or more.

| NATIONAL ENERGY EQUIPMENT INC. |
|-----------------------------------|
| MANUNAL LINLING I |
| COLIIDAAENIT INIC |
| EYJUII TYLEINT INC. |

| $\mathbf{r} \leq \mathbf{E} \mathbf{Q} \mathbf{U} \mathbf{I} \mathbf{M} \mathbf{E} \mathbf{N} \mathbf{I} \mathbf{I} \mathbf{N} \mathbf{C}$ | in accordance v | with CSA B620 |
|--|--------------------------------------|-------------------------|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | Page Number: 65 of 150 | |
| Tester | | |
| Every tester shall | | |
| (a) be familiar with the specification ta | nk on which the test is performed; | |
| (b) be familiar with the test procedure a | and pass/fail criteria; | |
| (c) have at least one year of experience | performing the test; and | |
| (d) be trained and experienced in the us | se of the testing equipment. | |
| Welders/ brazers | | |
| Every welder/ brazer shall: | | |
| • Qualified by this Facility authority in | accordance with B620 | |
| Hose Testers and Inspectors | | |
| Every hose testers and inspector shall: | | |
| • Have training in product and hose saf | ety, inspection and test procedures, | and rejection criteria. |
| 18.3 References | | |
| - List of registered design engineers | | (See 21.1) |
| - List of B620 personnel and their qualify | ications | (See 21.1) |
| - Cartificate of qualification | | $(S_{22}, 21, 1)$ |

- Certificate of qualification

(See 21.1)

| I NATIONAL ENERGY | r |
|-----------------------------------|---|
| NATIONAL ENERGY EQUIPMENT INC. | |

Document Number: NEE-QCM-THB-001

Prepared by / Approved by:

Page Number: 66 of 150

Arash Navidan / Zanyar Farhadi

Revision Number: 04

Date of Issue: 2019/04/29

SECTION - 19 Mobile Units

19.1 General

The process owner shall control service vehicles and related equipment at the registered facility 25-1239, located at 46A Haniak Road, Rosslyn Ontario P7K 0C8.

One service vehicle is available for mobile service.

All records of mobile Inspections and Testing shall be maintained at the registered facility (25-1239) where the mobile equipment is located.

19.2 Mobile Equipment

The tank inspector shall gather the following required equipment and documents from the shop and transfer them to the service vehicle. He should make sure that all of the following equipment are available on the service vehicle for mobile service:

- Controlled copy of this Quality Control Manual and CSA-B620 standard currently in place,
- Laptop, used to record inspection
- Inspection check list
- Camera
- Explosion-proof Flash Light
- Hose Inspection tags
- Tanks Inspection stickers
- TANK UNDER PRESSURE Sign x 2
- Zip Ties
- Regulator
- Test fittings and Adaptors
- Air Compressor
 - o Gas Powered
 - o Electric
 - o Customer supplied
- Air Lines
- Soapy Water
- Wire Brush
- 10 Fill Betts Test Lid
- Hose Tester
 - o Aviation
 - o Gasoline/Diesel
- Calibrated Gauges



Document Number: NEE-QCM-THB-001

Revision Number: 04

Prepared by / Approved by:

Date of Issue: 2019/04/29

Arash Navidan / Zanyar Farhadi

SECTION - 20 Records Retention

20.1 General

Records referred to in this manual may be maintained and stored electronically.

The Process Owner shall review all records referred to in this manual for completeness prior to filing.

All following records shall be retained on NEEI property for a period of at least 20 years. They shall be circulated as described in the documents, where applicable.

- 1) Copy of the identification plate by the facility installing the plate
- 2) Copy of the certificate by the manufacturer, assembler or modifier
- 3) Calculations, drawings plus all superseded ones by the modifier
- 4) Inspection and test reports by the inspector or tester facility
- 5) Pressure test reports,
- 6) Hose test reports,
- 7) Calibration records,
- 8) Certificates of compliance from NEEI as well as those from other manufacturers
- 9) Repair reports

The national quality systems manager is responsible for ensuring that above mentioned records, quality control manual, certificates and other related documents required by CSA B620 and applicable codes are properly circulated and retained for the required periods.

In the event of a change in ownership, retention by the prior Owner of non-fading copies of the records shall be deemed to satisfy the requirements of the above mentioned items.

For tanks that have been manufactured, assembled, or repaired by NEEI, non-fading copies of the entire Job File, including the Certificate of Compliance, will be kept for a period of 20 years upon delivery of a manufactured or assembled tank to a tank Owner or purchaser, NEEI will issue a Certificate of Compliance for New & Assembled Tanks (Form No. NEE-FRM-004).

For tanks that have been modified by NEEI, non-fading copies of the entire Job File, including the Certificate of Compliance, will be kept for a period of 20 years. Upon delivery of a modified tank to a tank Owner or purchaser, NEEI will issue a Modification Certificate of Compliance (Form No. NEE-FRM-005).

These Certificates of Compliance shall be retained by the Owner throughout the ownership of the tank and for at least one year thereafter.

The Job File, with all contents, shall be delivered at the time of sale by the seller of a tank to the purchaser, with non-fading copies of the contents being retained by the seller.

The Owner and the motor carrier, if they are not the Owner must each retain a copy of the test and inspection reports until the next major inspection.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 68 of 150 |

On delivery of a tank, a copy of the test and inspection report (Form No.: NEE-FRM-007), Hose assembly test and inspection report (Form No.: NEE-FRM-012) shall be provided to the Owner or Owner's designate, who shall retain them throughout the ownership of the tank and for at least one year thereafter.

20.2 References

| - | NEE-FRM-004 Certificate of compliance for new & assembled tanks | (See 21.1) |
|---|---|------------|
| - | NEE-FRM-005 Modification certificate of compliance | (See 21.1) |
| - | NEE-FRM-007 Test and inspection report | (See 21.1) |
| - | NEE-FRM-012 Hose assembly test and inspection report | (See 21.1) |

| | L ENERGY NT INC. | Quality Control Manual in accordance with CSA B620 | |
|--|-------------------------------|--|--------------|
| Document Number: NEE-QCM-THB-001 | | Revision Number: 04 | |
| Prepared by / Approved by: | | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: 2019/04/29 | | Page Number: 69 of 150 | |
| SECTION - 21 Exh | <u>ibits</u> | | |
| 21.1 Reference forms a | nd documents | | Page |
| 21.1.1 NEE FRM 001 | Metal identification | plate stamping | |
| 21.1.2 NEE FRM 002 | | tamping | 71 |
| 21.1.3 NEE-FRM-003 | | nformation sheet for recertified tanks | 72 |
| 21.1.4 NEE-FRM-004 | | iance for new & assembled tanks | 73 |
| 21.1.5 NEE-FRM-005 | | cate of compliance | |
| 21.1.6 NEE FRM 006 | Repair Report | | 76 |
| 21.1.7 NEE-FRM-007 | Test and inspection | report | 77 |
| 21.1.8 NEE FRM 008 | Metal identification | plate replacement | 81 |
| 21.1.9 GMAW-AL-01 | 01 | specifications (WPS) and, cation records (PQR) and related tests | 82 |
| 21.1.10 NEE-FRM-010 | | Inspection Check List | |
| 21.1.11 NEE-FRM-011 | Test and inspection | travel sheet | 92 |
| 21.1.12 NEE-FRM-012 | Hose assembly test a | and inspection report | 93 |
| 21.1.13 NEE FRM 013 | Welding inspection | report | 94 |
| 21.1.14 NEE-FRM-014 | Gauge Calibration L | og | 95 |
| 21.1.15 NEE-FRM-015 | Equipment Calibrati | on Log | 96 |
| 21.1.16 NEE FRM 016 | Welder Continuity I | -0g | 97 |
| 21.1.17 NEE-FRM-017 | Nonconformance co | rrective and preventative action report | 98 |
| 21.1.18 Mandatory Docum | nent List | | 99 |
| 21.1.19 List of registered | design engineers | | 100 |
| 21.1.20 List of B620 perso | onnel and their qualification | ations | 101 |
| 21.1.21 Certificate of qual | lification | | 102 |
| 21.1.22 Table 7.1 of CSA | B620 Periodic insp | pection and test intervals, | 103 |
| Table 7.2 of CSA | - | periodic inspection and test intervals | |
| 21.1.23 Table 7.3 of CSA 21.1.24 Table 7.4 of CSA | | r periodic retestin107 hickness for TC and MC 306, 307, and 312 specific | ation tanks |
| | | ed with steel and steel alloys | 108 |
| 21.1.25 Table 7.5 of CSA | B620 Minimum th | tickness for TC/MC 306,307,and 312 specification ed with aluminum and aluminum alloys) | tanks 109 |
| 21.1.26 NEE-FR-L-102 | Confined space er | ntry permit | |
| 21.1.27 NEE-CSEP-MB-(| 01 Confined space en | try program | 111 |
| 21.1.28 Required informat | tion on the Identification | on Plate checklist | 118 |
| 21.1.29 NEE MPI WF 00 | 1 Magnetic Particle | Inspection Procedure | 119 |
| 21.1.30 Testing in-service | cargo tank manway co | overs procedure | 132 |

Document Number: NEE-QCM-THB-001Quality Control Manual
in accordance with CSA B620Revision Number: 04

Prepared by / Approved by: Arash Navidan / Zanyar Farhadi Date of Issue: 2019/04/29 Page Number: 70 of 150

21.1.1 NA

| and Number NET ED 1 004 | Revision: 0 | | |
|--|---------------------------------------|-----|--|
| arm Number:NEE-FR-L-001 | ACMBIOLE 0 | | |
| | | | |
| NOTE* - All characters are to be a minimum 5mm (3/ | 16") high and be stamped or embossed. | | |
| | | | |
| Fauk Manufacturer: | Date of Manufacture: | | |
| Specification TC: | MDIN: | | |
| Assembler: | Date of Assembly: | | |
| FCRN: | Serial No.: | | |
| VIN: | Certification Date: | | |
| Org. Test Date: | | | |
| Design Temp, Range; to°C | Max. Lading Density:kg/L | | |
| MAWP:kPa | Test Pressure: kPa | | |
| .ining Material: | | | |
| | | | |
| Head Material: | Weld Material: | | |
| Vlin, Shell Thickness: Top | Sides Bottom | | |
| Min. Head Thickness: Top | SidesBottont | | |
| Compartment: 1 2 | 3 4 5 | | |
| Volume Cap (L) | | | |
| Exposed Surface Area | | | |
| sq. meters) | | | |
| Vlax, Payload:kg | Max. Load Rate:L/min@ | kPa | |
| Max. Unload Rate:L/min@kPa | | | |
| AND OL HERLY | Mfd. Head Thickness: | mm | |
| Mfd. Shell Thickness: mm | | °C | |

| Z NATIONAL ENERGY EQUIPMENT INC. | | Quality Control Manual in accordance with CSA B620 | | |
|---|--|---|--|--|
| Document Number: NEE-QCM-THB-001 Prepared by / Approved by: Date of Issue: 2019/04/29 | | Revision Number: 04 | | |
| | | Arash Navidan / Zanyar Farhadi | | |
| | | Page Number: 71 of 150 | | |
| 21.1.2 | NA | | | |
| | P HATIRNAL ENERG | Modification Plate Stamping | | |
| | Form Number:NEE-FRM-002 | Revision: 1 | | |
| | Note ^s - All characters to be a minimum 5r Indicate ALL item | s modified from original Specification | | |
| | MODIFIED BY | | | |
| | EQUIDMENT INC | | | |
| | 25 Manufacturer Serial No. | | | |
| | | Re-certification Date | | |
| | Re-test Date | | | |
| | Items Modified | | | |
| | | _ Remount —Design change 🔄 | | |
| | Plate as | s per CSA B620, Clause 7.6.9 | | |

Quality Control Manual Z NATIONAL ENERGY EQUIPMENT INC.

in accordance with CSA B620

| Document Number: NEE-QCM-THB-001 Prepared by / Approved by: | | Revi | Revision Number: 04 Arash Navidan / Zanyar Farhadi | | | |
|---|---|-------------------------------|---|--|--|--|
| | | Arasl | | | | |
| Date of Issue: | : 2019/04/29 | Page | Page Number: 72 of 150 | | | |
| 21.1.3 | NA | | | | | |
| | PROUPMENT INC. | | Specification plate information sheet for recertified tanks | | | |
| | Form Number:NEE-FRM-003 | | Revision:0 | | | |
| | Owner:Unit #: | | | | | |
| | Record all required information from the Specification Plate below. If the Spec Plate is illegible, a rubbing may be made and the information may be used for the test and inspection purposes. | | | | | |
| | Required Information: | Required Information: | | | | |
| | TC Specification | | Vessel Material Spec # Shell | | | |
| l | Tank Manufacturer. | | Manufactured Shell Thickness | | | |
| | Tank Vehicle Serial Number | | Vessel Material Spec # Head | | | |
| | Tank Vehicle Assembler | | Manufactured Head Thickness | | | |
| | Completion/Manufacture Date | | Weld Material | | | |
| | Gertificate Date | | Volumetric Capacity (Litres) | | | |
| | Original Test Date | | Max Pay/Product Load (kilograms)/(lbs) | | | |
| | Tarik Test Pressure (kpa) | | Max Loading Limit/Rate (Ipm@kpa) | | | |
| | MAWP/Design Pressure | | Max Unloading Limit/Rate (Ipm@kpa) | | | |
| | Lining Material (when applicable) | | | | | |
| | Manufacturer Design ID # | | Max Lading Density | | | |
| | Tank Design Temp Range | | Min Allowable Shell Thickness | | | |
| | (degrees C) Min Allowable Head Thickness | | Exposed Surface Shell Thickness | | | |
| | Heating System Design (kpa) | | Heating System Design Temp (G) | | | |
| | TCRN/CRN Number | | Mark OT or NQT at/near ID Plate | | | |
| | Single Plate | Duplicate Plate | | | | |
| | | | | | | |
| | Technician (print): | Techniciau (print):Signature: | | | | |
| | | | | | | |
| l | | | | | | |

Image: Second system in a coord ance with CSA B620 Document Number: NEE-QCM-THB-001 Revision Number: 04 Prepared by / Approved by: Arash Navidan / Zanyar Farhadi Date of Issue: 2019/04/29 Page Number: 73 of 150 21.1.4 NA Image: Second system in the cond system in t

| form Number:NEE-FRM-0 | V4 | | Revision: 1 | | | |
|---|------------------------------|-----------------|-----------------------|-----------------------|---------------------------|-----|
| (page 1 of 2) | | | | | | |
| | | | | | | |
| Registration No 25- | | | | | | |
| Highway Tank Serial No. | | | | | | |
| VIN No. | | | | | | |
| Tank Manufacturer | | | | | | |
| Manufacturet Address | | | | | | |
| Tank Assembler | As | sembler Addre | | | | |
| We vertify that the tank, fittings work performed. | s, valves, piping and protec | tive devices et | mply with the applica | ble specifications of | CSA B620 to the extent of | the |
| Full Spee | Short Spec | TCR | N. I | MIDIN | | |
| | | | | | | |
| Date of Manufacture: Month: | Year | Ċ | ertification Date: | Month: | Veur: | |
| Original Test Date: Month: | Vear | | | | | |
| MAWP: (Pa | | | n Température Rangi | s to | degrees C | |
| Tank Material: Shell: | He | | | | | |
| Manufacturer Thickness: Shel | | | | | | |
| Minimum Thickness: Shell: | He | | | | | |
| Төр: | | Botto | | | | |
| Weld Marerial: | | | | | | |
| Heating System Pressure: | | | ing System Temperati | ire: | эc | |
| Compartment Number | ī 2 | 3 | 4 5 | 6 | Total | |
| Volumetric Cap. (Liters) | | | | | | |
| Exposed Surface | | | | | | |
| Pressure Relief Device | Sei Pressure: | Bat | ing: Scili al | | | |
| Quantity: Per compl | | | | | | |
| Max. Lading: Density | Kg/L M | ix. Payloadi | | | | |
| Max: Load Rate: | L/min at | kPa Ma | c. Unload Rate: | L/min at | kBa | |
| Lining Material. | | | | | | |
| This Certification Includes | Tank - Chassis |] | Damage Protectic | n | | |
| | Assembly | 1 | Valve Operating I | Devices | | |
| | Piping & Valves | 1 | Relief Devices | | | |
| | Bumper | 1 | | Remail. | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

| nent Number: NEE-QCM-THB-001 | Revision Number: 04 Arash Navidan / Zanyar Farhadi Page Number: 74 of 150 | | |
|---|---|--|--|
| red by / Approved by: | | | |
| f Issue: 2019/04/29 | | | |
| | | | |
| Z HATIRMAL ENERGY | Certificate of Compliance for New or Assembled Tanks | | |
| Form Number:NEE-FRM-004 | Revision: 1 | | |
| (page 2 of 2) | | | |
| This Certification Excludes: Tank - Chassis Assembly Piping & Valves Bumper | Damage Protection | | |
| Tank Tester (Print): | Signature: | | |
| Date: | | | |
| Certified By (Print): | Signature: | | |
| Date: | Signautes | | |
| | | | |

| NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 75 of 150 |

| .1.5 | |
|------|------|
| | |
| | .1.5 |

| | | | | Modification Certificate of Compliance | | | |
|--------------------------------------|--------------|-------------|-----------------------|--|------------|---------|--|
| rm Number:NEE-FRM-0 | Revision: 0 | | | | | | |
| | Address. | | | | | | |
| Modified by 1997 Facility Nu. 25- | | | | | | | |
| | | | | | in Date | | |
| slamutaonuted w | | | any Idamitatione Late | | | | |
| | | | | | - 100. NOS | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Min Thickness | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Vre Thoater al | | | | | | | |
| | | | | | | | |
| there used Capacit | | | | | | | |
| | | | | | | | |
| latings of vient. | | | | | | | |
| Max. Endrog Paylouds | | | | | | | |
| Niax Travi Rate | | | | | el france: | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| All modifications have b | aen performe | d in compli | ance wit | | ments of C | SA 8620 | |
| | | | | | | | |
| | | | | | | | |

| eent Number: NEE-QCM-THB-001 Revision Number: 04 eed by / Approved by: Arash Navidan / Zanyar Farhadi FIssue: 2019/04/29 Page Number: 76 of 150 6 NA Repair report Repair report Resistantion #: 25 Facility Address: Owner's Name: Owner's Tel. No.: Owner's Name: Serial #: Manufacture: Serial #: Date of Repair (Provide sketch if required) Description of Repair (Provide sketch if required) Weld Procedures used: Authorized Welder Name: Signature: Date: Date: Signature: Date: Comparise Signature: Sig | NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 | | | |
|---|-----------------------------------|---|--|--|--|
| I Issue: 2019/04/29 Page Number: 76 of 150 6 NA Image: Registration #: 25- Revision: 0 Facility Address: Owner's Tel. No.: Owner's Address: Owner's Tel. No.: Owner's Address: Serial #: Date of Repair: Serial #: Date of Repair: Description of Repair (Provide sketch if required) Image: Serial #: Tank Spec: Date of Repair (Provide sketch if required) Image: Serial #: Material: Tank Spec: Description of Repair (Provide sketch if required) Image: Serial #: Meld Procedures used: Signature: | nt Number: NEE-QCM-THB-001 | Revision Number: 04 | | | |
| 6 NA Perm Number:NEE-FRM-006 Registration #: 25 Facility Address: Owner's Tel. No.: Owner's Tel. No.: Owner's Address: Manufacture: Serial #: MFR Date: Date of Repair: Description of Repair (Provide sketch if required) Description of Repair (Provide sketch if required) Weld Procedures used: Authorized Wolder Name: Signature: | d by / Approved by: | Arash Navidan / Zanyar Farhadi | | | |
| Repair report Form Number:NEE-FRM-006 Revision: 0 Registration #: 25 | Issue: 2019/04/29 | Page Number: 76 of 150 | | | |
| Form Number:NEE-FRM-006 Revision: 0 Registration #: 25 | NA | | | | |
| Registration #; 25 | NATIONAL ENERGY EQUIPMENT INC. | Repair report | | | |
| Facility Address: Owner's Name: Owner's Address: Manufacture: Serial #: MFR Date: Material: Tank Spec: Date of Repair: Description of Repair (Provide sketch if required) | Form Number:NEE-FRM-006 | Revision: 0 | | | |
| Owner's Name: Owner's Tel. No.: Owner's Address: Serial #: Manufacture: Serial #: MFR Date: Material: Tank Spec: Date of Repair: Description of Repair (Provide sketch if required) Image: | Registration #: 25- | | | | |
| Owner's Address: Manufacture: MFR Date: Date of Repair: Description of Repair (Provide sketch if required) Image: Comparis and the second state | Facility Address: | | | | |
| Manufacture: | Owner's Name: | Owner's Tel. No.: | | | |
| MFR Date; | Owner's Address: | | | | |
| Date of Repair: Description of Repair (Provide sketch if required) | Manufacture: | Serial #: | | | |
| Description of Repair (Provide sketch if required) | MFR Date: Material: | Tank Spec: | | | |
| Weld Procedures used: Authorized Welder Name: | Date of Repair: | | | | |
| Authorized Welder Name:Signature: | | | | | |
| | Weld Procedures used: | | | | |
| | | | | | |
| Date: | Authorized Welder Name: | Signature: | | | |
| | | Date: | | | |
| | | | | | |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2019/04/29

Page Number: 77 of 150

| REQUIPMENT INC. | | Test any | d Inspection Report |
|---|--|----------------------------|-------------------------|
| Form Number:NEE-FRM-007 | | Revision: 4 | (Page 1of 4) |
| Facility Name: N | ational Energy Equipment Inc. | Test Date: | |
| Address | | | |
| Telephone | | Facility Registration No.: | |
| Tank Owner | | | |
| Address: | | | |
| Telephone | | Work Order Location: | |
| OWNERS UNIT No.: | | SERIAL No.: | |
| MANUFACTURER: | | MAWP: | |
| CERT. DATE: | MATERIAL: | WICE WE. | TANK SPEC: |
| For TC/MC331 & TC51 | OT | NOT | PWHT |
| Stress relievedafter repair: | Complete | Local | N/A |
| | 1 | | |
| | 2. | | |
| COMP. CAPACITY (IG/L): | 4 | | |
| | 5 | | |
| | 6 | | |
| TESTS PERFORMED | "V" | "K" | ч г , |
| | "P" | ··· In. | "UC" |
| EXTERNAL VISUAL INSPECTIO | N ** V ** | QC Man. Reference: | 12.2 |
| Data plate and other markings, present | and legible | Complies | Retest complies |
| Shell & heads corrosion, abrasion, den nuts on any flanged/blank connection, c | ts, overlay patches, leaks, loose bolts and lefect welds, etc. | Complies | Retest complies |
| Structural members, outriggers, cross r | nembers etc. | Complies | Retest complies |
| Piping and valves for leakage, damage | , corrosion | Complies | Retest complies |
| Remote closures, thermal devices | | Complies | Retest complies |
| Hoses for defects, identification and te | st dates | Complies | Retest complies |
| Tank attachments to frame or running ; can be inspected without dismantling | gear, elements of the UC assembly that | Complies | Retest complies |
| Ladders, walkways, etc. | | Complies | Retest complies |
| Fill covers, manways and closure device | res | Complies | Retest complies |
| Relief valves and vents (replace or test corrosive to relief device) | if tank in service where lading | Complies | Retest complies |
| Accident damage protection | | Complies | Retest complies |
| Engine air intake shut off device and d (Transport Canada's requirement) | ry chemical fire extinguishers | Complies | (It is not a rejection) |
| Note: Rejection Criteria for Visual I Less than minimum material thickness Any dent with a depth greater than $\frac{1}{2}^{N}$ Any dent with a depth greater than 109 | under any cut, dig or gouge where it includes a weld 6 of the length of the dent hole, or incomplete fusion of the weld leakage 8 | | |
| | B UTTONIC CON | A flor Poter | e Cimatum. |
| Inspector Name: | Signature: | Allel Keles | st Signature: |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001Revision Number: 04Prepared by / Approved by:Arash Navidan / Zanyar Farhadi

Date of Issue: 2019/04/29

Page Number: 78 of 150

| | ENERGY T INC. | Test and Inspection Report | | | |
|--|-------------------------------------|---|---|--|--|
| Form Number:NEE-FRM-007 | 5 / 7 5 / 7 S / 7 | Revision: 4 | (Page 2 of 4) | | |
| Facility Name: National End | ergy Equipment Inc. | Test Date: | | | |
| Address: | | | | | |
| Telephone | | Facility Registration No | 4 | | |
| Tank Owner | | | | | |
| Address: | | | | | |
| Telephone | | Work Order Location: | | | |
| OWNERS UNIT No.: | | SERIAL No .: | | | |
| MANUFACTURER: | | MAWP: | | | |
| CERT. DATE: | MATERIAL: | | TANK SPEC: | | |
| INTERNAL VISUAL INSPECTION "I" | | QC Man. Reference: | 12.3 | | |
| Interior surface, corrosion, distortion overlay patch | nes, cracking etc. | Complies | Retest complies | | |
| Interior welds for defects, cracking etc. | | Complies | Retest complies | | |
| Internal supports and attachments | | Complies | Retest complies | | |
| Internal valves, piping and vents for leakage, dama | ige, etc. | Complies | Retest complies | | |
| | | | | | |
| Inspector Name: | Signature: | At | fter Retest Signature: | | |
| Inspector Name: Fank Tester Name (If applicable): | | At Date: | ter Retest Signature: Date: | | |
| Fank Tester Name (If applicable): | 4 | | and the second | | |
| | | Date: | Date: | | |
| Fank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in | | Date: QC Man. Reference: | Date: 12.4 | | |
| Fank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in frum table assembly inspected in place | | Date: QC Man. Reference: Complies | Date: 12.4 Retest complies | | |
| Tank Tester Nume (If upplicable): UPPER COUPLER AREA INSPECTION *UC | | Date: QC Man. Reference: Complies Complies | Date: 12.4 Retest complies | | |
| Tank Tester Nume (If upplicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in frum table assembly inspected in place Inspected elements: | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies | Date: 12.4 Retest complies Retest complies | | |
| Tank Tester Nume (If upplicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in t'um table assembly inspected in place Inspected elements: Inspector Name: | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Al | Date: 12.4 Retest complies Retest complies fter Retest Signature: | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in Turn table assembly inspected in place Inspected elements. Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K ⁹ TEST PRESSURE (80% of MAWP MIN): | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies At Date: | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: | | |
| Fank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in furn table assembly inspected in place Inspected elements. Inspector Name: Fank Tester Name (If applicable): LEAKAGE TEST *K ⁹ TEST PRESSURE (80% of MAWP MIN): | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Af Date: QC Man. Reference: | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: | | |
| Funk Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in Furn table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: 12.5 | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in Trum table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K? TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: Passes | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: 12.5 Retest complies Retest complies Retest complies Retest complies Retest complies | | |
| Fank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in frum table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: Passes Passes Passes | Date: 12.4 Retest complies Retest complies ter Retest Signature: Date: 12.5 Retest complies Retest complies Retest complies Retest complies Retest complies Retest complies Retest complies Retest complies | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in furn table assembly inspected in place Inspected elements. Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: Passes Passes Passes Passes | Date: 12.4 Retest complies Retest complies Pate: Date: Date: 12.5 Retest complies Retest complies | | |
| Funk Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in frum table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Al Date: QC Man. Reference: TEST MEDIUM: Passes Passes Passes Passes Passes Passes Passes Passes Passes Passes | Date: 12.4 Rotest complies Retest complies Atter Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Funk Tester Name (If applicable): UPPER COUPLER AREA INSPECTION * UC Upper coupler removed from tank and inspected in frum table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 1 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Al Date: QC Man. Reference: TEST MEDIUM: Passes Passes Passes Passes Passes Passes Passes Passes Passes | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Funk Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in frum table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 2 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Al Date: QC Man. Reference: TEST MEDIUM: Passes Passes Passes Passes Passes Passes Passes Passes Passes Passes | Date: 12.4 Rotest complies Retest complies Atter Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in Turn table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 2 Piping Leakage Tested Compartment No. 3 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: Passes Passes Passes Passes Passes Passes Passes Passes Passes Passes Passes Passes Passes | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in Turn table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K? TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 7 Leakage Tested Compartment No. 7 Leakage Tested Compartment No. 8 Leakage Tested Compartment No. 9 Lipping Leakage Tested Compartment No. 9 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: Passes | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Fank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in frum table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K? TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 7 Leakage Tested Compartment No. 7 Leakage Tested Compartment No. 8 Leakage Tested Compartment No. 9 Leakage Tested Compartment No. 9 Piping Leakage Tested Compartment No. 4 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Complies A1 Date: QC Man. Reference: TEST MEDIUM: Passes | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in Turn table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 2 Piping Leakage Tested Compartment No. 3 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Al Date: QC Man. Reference: TEST MEDIUM: Passes | Date: 12.4 Retest complies Retest complies ther Retest Signature: Date: Date: 12.5 Retest complies Retest complies | | |
| Tank Tester Name (If applicable): UPPER COUPLER AREA INSPECTION *UC Upper coupler removed from tank and inspected in Turn table assembly inspected in place Inspected elements: Inspector Name: Tank Tester Name (If applicable): LEAKAGE TEST *K* TEST PRESSURE (80% of MAWP MIN): Compartment No. 1 Leakage Tested Compartment No. 2 Leakage Tested Compartment No. 3 Leakage Tested Compartment No. 4 Leakage Tested Compartment No. 5 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 6 Leakage Tested Compartment No. 7 Leakage Tested Compartment No. 8 Leakage Tested Compartment No. 9 Leakage Tested Compartment No. 9 Leakage Tested Compartment No. 9 Piping Leakage Tested Compartment No. 1 Piping Leakage Tested Compartment No. 9 Piping Leakage Tested | rel. tank areas above Signature: | Date: QC Man. Reference: Complies Complies Complies All Date: QC Man. Reference: TEST MEDIUM: Passes | Date: 12.4 Rotost complies Retest complies Pate: Date: Date: Date: Date: 12.5 Retest complies Retest complies | | |

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 79 of 150 |

| RATIONAL ENERGY EQUIPMENT INC. | | | Test and Inspection Report | | | |
|-----------------------------------|---------------------|-------------|----------------------------|-----------------|--|--|
| Form Number:NEE-FRM-00' | | | Revision: 4 | | (Page 3of 4) | |
| Facility Name: | National Energy Equ | ipment Inc. | Test Date: | | and a second | |
| Address: | | | | | | |
| Telephone | | | Facility Registration No | o.: | | |
| Tank Owner | | | | | | |
| Address: | | | | | | |
| Telephone | | | Work Order Location: | | | |
| OWNERS UNIT No.: | | | SERIAL No.: | | | |
| MANUFACTURER: | | | MAWP: | | | |
| CERT. DATE: | 0.0 | MATERIAL: | | | TANK SPEC: | |
| THICKNESS TEST "T" | | MATERIAL. | QC Man. Reference: | | 12.6 | |
| Thickness tester calibrated? | | | Qu man more anov. | | Front Head | |
| Front of the tank | 12:00 | 3:00 | 6:00 | 9:00 | \neg \land \rangle | |
| Shell's position number 1 | | | | 1.04 | | |
| Shell's position number 2 | | | | | | |
| Shell's position number 3 | | | | | | |
| Shell's position number 4 | | | | | | |
| Shell's position number 5 | | | | | Rear Head | |
| Shell's position number 6 | | | | | | |
| Shell's position number 7 | | | | | | |
| Shell's position number 8 | | | | | | |
| Shell's position number 9 | | | | | | |
| Shell's position number 10 | | | | | | |
| Shell's position number 11 | | | | | Manway | |
| shell's position number 12 | | | | | | |
| Shell's position number 13 | | | | | | |
| Shell's position number 14 | | | | | | |
| Shell's position number 15 | | | | | | |
| Shell's position number 16 | | | | | | |
| Shell's position number 17 | | | | | Sump | |
| Shell's position number 18 | | | | | | |
| Shell's position number 19 | | | | | | |
| Shell's position number 20 | | | | | | |
| Shell's position number 21 | | | | | | |
| Shell's position number 22 | | | | | | |
| Shell's position number 23 | | | | | Nozzle 1 | |
| Shell's position number 24 | | | | | \wedge | |
| Shell's position number 25 | | | | | | |
| Shell's position number 26 | | | | | | |
| Shell's position number 27 | | | | | | |
| Shell's position number 28 | | | | | | |
| Shell's position number 29 | | | | | Nozzle 2 | |
| Shell's position number 30 | | | | | \wedge / | |
| Rear of the tank | 12:00 | 3:00 | 6:00 | 9:00 | | |
| | | | | 2.36.9 | | |
| | Complies | | Redo complies | | $\langle \rangle$ | |
| Tester Name: | | Signature: | A | fter Retest Sig | mature: | |
| | | | | | | |
| | | Ľ | vate: | | Date: | |

FAILED INSPECTION Inspector Name:

Quality Control Manual in accordance with CSA B620

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 80 of 150 |

| sue: 2019/04/29 | | rage Number: 80 01 150 | | | |
|-----------------------------------|--|--------------------------------------|--|--|--|
| RATIONAL ENERGY EQUIPMENT INC. | | Test and Inspection Report | | | |
| Form Number:NEE-FRM-0 | 07 | Revision: 4 | (Page 4of 4) | | |
| Facility Name: | National Energy Equipment Inc. | Test Date: | | | |
| Address: | | | | | |
| Telephone | | Facility Registration No.: | | | |
| Tank Owner | | | | | |
| Address: | | | | | |
| Telephone | | Work Order Location: | | | |
| OWNERS UNIT NO.: | | SERIAL No.: | | | |
| MANUFACTURER: | | MAWP: | | | |
| CERT. DATE: | MATERIAL: | | TANK SPEC: | | |
| PRESSURE TEST *P" | | QC Man Reference: | 12.7 | | |
| Test Pressure (Tank) | | 7.3 of CSA B620 for appropriate test | t pressure) | | |
| TEST PRESSURE (80% of M | STATE AND A MARKED AND A STATE | TEST MEDIUM: | But and a second lat | | |
| Compartment No. 1 Leakage T | | Passes | Retest complies | | |
| Compartment No. 2 Leakage T | | Passes | Retest complies | | |
| Compartment No. 3 Leakage 1 | | Passes | Retest complies | | |
| Compartment No. 4 Leakage T | | Passes | Retest complies | | |
| Compartment No. 5 Leakage T | | Passes | Retest complies | | |
| Compartment No. 6 Leakage T | | Passes | Retest complies | | |
| Compartment No. 1 Piping Les | | Passes | Retest complies | | |
| Compartment No. 2 Piping Les | and the second | Passes | Retest complies | | |
| Compartment No. 3 Piping Les | | Passes | Retest complies | | |
| Compartment No. 4 Piping Lea | Contraction of the second s | Passes | Retest complies | | |
| Compartment No. 5 Piping Les | | Passes | Retest complies | | |
| Compartment No. 6 Piping Les | akage Tested | Passes | Retest complies | | |
| Tester Name: | Signature: | After Re | test Signature: | | |
| | | Date: | Date: | | |
| CONCLUSION | | | | | |
| Any defect or damage discover | red on tank? | Yes or No | | | |
| of any subsequent test or inspe | | | | | |
| Tank successfully retested afte | | Yes or No | Not Applicable | | |
| Written repair weld inspection | | Yes or No | Not Applicable | | |
| Expired Inspection Markings r | | Yes or No | 1. | | |
| TANK DISPOSITION | Removed from Service | | Yes or No | | |
| | Safety Mark (Specification Indication |) removed | Yes or No | | |
| | Returned to Service | | Yes or No | | |
| PWHTafter repair of a TC/MC | 2331 & TC51 | Yes or No | Not Applicable | | |
| Wet Florescent Markings appli | ied and report attached | Yes or No | Not Applicable | | |
| Inspection Markings applied | | Yes or No | | | |
| a because the strength and shirts | | Discourse Disput and and | | | |

Signature;

PASSED INSPECTION

After Retest Signature:

Date:

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2019/04/29

Page Number: 81 of 150

| RequiPMENT INC. | Metal identification plate replacement |
|---|--|
| Form Number:NEE-FRM-008 | Revision: 0 |
| | cation to which it was originally certified and is indeed the |
| tank listed in the above supporting documentation Tank Specification: | |
| | |
| <u>Notes:</u> - Replacement metal ID plate shall be permanently af | fixed to the tank or its supporting structure by brazing or |
| welding around its perimeter or by means of tamper | |
| | assembly, modify, or repair functions for the following tanks. Therefore, we cannot stamp or install a replacement metal ID |
| plate for these type of tanks. | |
| For TC331 tank specifications, the replacement of a requirements of the Manitoba pressure vessel author | |
| | asy, 331 tanks is limited to Assembly, a plate shall not be installed |
| the installation involves welding to the tank wall. Th | e replacement metal ID plate could be installed by means of |
| tamper-resistant fasteners as per page 33, item 17 of | QC manual, pertaining to TC331 tanks. |
| Original Tank Manufacturer: | Original Date of Manufacture: |
| Original Tank Vehicle Assembler: | Date of Assembly: |
| Tank Serial No.: | Vehicle Identification Number: |
| Owner's Name: | |
| Owner's address: | |
| Owner's Signature: | |
| Registered Facility Installing Replacement Plate Name; | |
| Installing Plate Facility Number: | |
| Registered Facility address: | |
| Name of Compliance Officer at Registered Facility: | |
| Signature of Compliance Officer at Registered Facility: | |
| Date of Installment of the Plate: | |
| Attach a copy of the supporting documentation (ta | ink's original or replacement Certificate of Compliance) |
| Attach a full copy of a facsimile or rubbing of the | |
| | replacement metal ID plate shall be kept by the owner or k, and a copy shall be retained for at least 1 year, thereafter. |

| ument Number: NEE-QC | M-THB-001 | Revision Number: 04 Arash Navidan / Zanyar Farhadi | | | | |
|---|---|---|--------------------------|----------------------------|---|-------|
| pared by / Approved by: | | | | | | |
| e of Issue: 2019/04/29 | | Page N | umber: 82 of 150 | | | |
| .1.9 NA | | | | | | |
| | | | | | | |
| | QW-482 suggested format (see QW-200.1, Section I | | | |) | |
| Company Name National Energy Equips | | oment Inc. | | | | |
| Welding Procedure Specification No. | | MAW-AL-01 | | Revision: | D | |
| Supporting POR No (s) | GN | MAW-AL-01 | | Issue Date, | 4-Feb+19 | |
| Welding Procese(66) | | GMAW | | WO; | W13935-D2 | |
| Type(s) | Sem | ni-Automatic | | - | | |
| JOINTS (QW-402) Refe | r-Defalls RootScreen 1 | 1/32 ln - 1/8 in | All As | Details ME VIII Div 1.8 | s B31.3 Standard | |
| | | lo Retainers | | | Design & Fillets | |
| and the second sec | no. 22 | | | | | |
| Shut et. | in award protoco | | All of the second second | Contractor Contractor | the family in a case of the second second | |
| biotomitalia. | | | | | th back gouge to sound mi de with backing. | 12:00 |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| * For welds with backing use Root S | | | | | | |
| Sketches, production drawings, weld | symbols or written description | | | | | |
| | | | | | | |
| | in of the parts to be welded. Where | | | | | |
| applicable, the root spacing and the | | | | | | |
| epplicable, the root spacing and the BASE METALS (QW-403) | n of the parts to be welded. Where details of weld groove may be strendled. | | | do. | | |
| applicable, the foot spacing and the BASE METALS (QWI-403) Theory 22 | in of the parts to be welded. Where | | P.M. | 22 | NIA. | |
| epplicable, the root spacing and the BASE METALS (QW-403) The 22 | n of the parts to be welded. Where details of weld groove may be strendled. | 10 | 2 au | 22 | ionere IIIA | |
| epplicable, the tool opacing and the BASE METALS (QW-403) The 22 | n of the parts to be welded. Where details of weld groove may be strendled. | | 2 Au | 22 | Guarde - MIA | |
| applicable, the root spacing and the BASE METALS (QW-403) The 22 | n of the parts to be welded. Where details of weld groove may be strendled. | | 2 Ar | 22 | i Staterer - AllA. | |
| epplicable, the root opacing and the BASE METALS (QW-403) The 22 | n of the parts to be welded. Where details of weld groove may be strendled. | | 2 Ar | 22 | - MiA. | |
| epplicable, the yoot opacing and the BASE METALS (QW-403) The 22 | n of the parts to be welded. Where details of weld groove may be strendled. | 0 | P an | 22 | NiA. | |
| applicable, the root spacing and the BASE METALS (QW-403) The 22 Participant of the 22 P | n of the parts to be welded. Where details of weld groove may be strendled. | | P er | 22 | I Smart IIIA. | |
| applicable, the root spacing and the BASE METALS (QW-403) Time 22 Parameters of the 22 Parame | in of the parts to be welded. Where defails of wold groove may be apenilied. | am) to 0.5 in (12. | P == 7 (mm) | 92. Tites | All Micknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) The 22 Participant of the 22 Participant of the 24 Participant of the 24 P | in of the parts to be welded. Where defails of wold groove may be apenilied. | nm) to 0.5 in (12. All | 2 == 7 mm) | | | |
| applicable, the root spacing and the BASE METALS (QW-403) The The Particular (QW-403) The Particular (QW-403) The Particular (QW-403) The Particular (QW-403) Particu | in of the parts to be welded. Where defails of wold groove may be apenilied. | | 2 == 7 mm) | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) Time 22 Second Contract Contract Second Contract Contract Contract Second Contract Contract Contract Second Contract Contract Contract Contract Second Contract Contract Contract Contract Contract Contract Second Contract Con | in of the parts to be welded. Where defails of wold groove may be apenilied. | All | 2 e- 7 mm) | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) Time 22 applicable, the root spacing and the applicable, the root space | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A | 2 == | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) Time 22 applicable, the root spacing and the applicable, the root space | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A None | 7 mm). | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) Trice 22 Parameters of the 22 Parameters of the 22 Parameters of the 22 Parameters of the 22 Parameter of th | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A None | ₽ ∞ 7 mm). | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) Time 22 applicable, the root spacing and the Date METALS (QW-403) Time 22 applicable, the root spacing and the applicable, the root space the date of the root space FILLER METALS (QW-404) | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A None N/A | P === 7 mm) | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 and and characterized of the state of | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A None N/A GMAW | 2 so 7 tmm) | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 applicable, the root spacing and the BASE METALS (QW/-403) Trice applicable, the root spacing and the applicable, the root space between the population of the space applicable, the root space applicable, the root space applicable, the root space The root space <td>in of the parts to be welded. Where defails of wold groove may be apenilied.</td> <td>All N/A None N/A GMAW F22</td> <td>₽ ∞ 7 tmm)</td> <td>Tier</td> <td>All Inicknesses</td> <td></td> | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A None N/A GMAW F22 | ₽ ∞ 7 tmm) | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice applicable, the root spacing and the BASE METALS (QW/-403) Trice applicable, the root spacing and the applicable, the root spacing and the applicable, the root space The root | in of the parts to be welded. Where defails of wold groove may be apenilied. | All N/A None N/A GMAW F22 ER5356 | P ↔ | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 applicable, the root spacing and the Base METALS (QW/-403) Trice applicable, the root spacing and the applicable, the root space applicable, the root space applicable, the root space The field space Metal Applicable & Tempare The field space Metal Applicable & Tempare The field space of the root space The root space The root space of the root space The root space | in of the parts to be welded. Where details of wold groove may be specified. | All N/A None N/A GMAW F22 ER5356 5.10 | 7 mm) | Tier | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 and an analysis and an analysis an an analysis an an analysis Trice Sum Hase Metal (Scores) The Metal (Scores) Mission (Scores) Mission (Scores) The Metal (Scores) Mission (Scores) Mission (Scores) Mission (Scores) M | in of the parts to be welded. Where details of wold groove may be specified. | All N/A None N/A GMAW F22 ER5358 5.10 ER5358 | 7 mm) | | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW-403) Trice 22 applicable, the root spacing and the BASE METALS (QW-403) Trice applicable, the root space of the space of the root space of the space of the root space of the space of the root space of the metal space of the root space of the metal space of the root space of the metal space of the root space of the space of the space of the space of the space of the space of the root space of the root space of the space of the root space of the root space of the space of the root space of the root space of the space of the root space of the root space of the root space of the space of the root space of the root space of the root space of the space of the root space of the root space of the root space of the space of the root space of the root space of the root space of the space of the root space of the root space of the root space of the space of the root space of the root space of the root space of the space of the root space of the roo | in of the parts to be welded. Where details of wold groove may be specified. Connector NDA 1/16 In (1.5 m 0.03 | All None N/A GMAW F22 ER5358 5.10 ER5358 35 In (0.5 mm) | 7 mm) | | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 Trice 22 continuencey products 22 continuence 22 continuence 22 continuence 22 continuence 22 continuence 22 Trictorise Superit 20 Hans Meter (Strowes) 21 Trictorise Superit 22 Trictorise Superit 22 Trictorise Superit 22 Trictorise Superit 22 Trictorise Converse 22 The Metal Strowes 23 Filler METALS (OW-404) 24 Weiters (Notesis) 25 Trictories Superit 25 The Metal Strowes 25 Mithall To 25 From the Metal Strowes 25 Mithal Strowes 25 | in of the parts to be welded. Where details of wold groove may be specified. Connector NDA 1/16 In (1.5 m 0.03 | All N/A None N/A GMAW F22 ER5358 5.10 ER5358 35 In (0.5 mm) None | 7 mm) | | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 Trice 22 continuences products 22 continuences 22 < | in of the parts to be welded. Where details of wold groove may be specified. Canadon NDA 1/16 In (1.5 m 0.03 4 | All N/A None N/A GMAW F22 ER5358 5.10 ER5358 35 In (0.5 mm) None | 7 mm) | | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 Trice 22 applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 applicable, the root spacing and the BASE METALS (QW/-403) applicable, the root space of the space o | in of the parts to be welded. Where details of wold groove may be specified. | All N/A None N/A GMAW F22 ER5358 5.10 ER5358 35 In (0.9 mm) None Solid wire | 7 mm) | | All Inicknesses | |
| applicable, the root spacing and the BASE METALS (QW/-403) Trice 22 Trice 22 partmanercy products 22 control defaultion of the second metal of the second | in of the parts to be welded. Where details of wold groove may be specified. | All N/A None N/A GMAW F22 ER5358 5.10 ER5358 35 In (0.9 mm) None Solid wire (12.7 mm) max: | 7 mm) | | All Inicknesses | |
| applicable, the root opacing and the BASE METALS (QW/-403) Trice 22 Trice 22 protocommony protocome 4 common opportunities a common 1 com 0 c | in of the parts to be welded. Where details of wold groove may be specified. | All N/A None N/A GMAW F22 ER5358 5.10 ER5358 35 In (0.9 mm) None Solid wire (12.7 mm) max: All sizes | 7 mm) | | All Inicknesses | |

Quality Control Manual in accordance with CSA B620

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 83 of 150 |

| | | | | WPS no. | GMA | W-AL-01 | Rev. 0 |
|--|------------------|--|---|--------------|----------------|---------|--------|
| POSITIONS (QVI-405) | | | POSTWELD HE | AT TREATMENT | CW44071 | | |
| | All | | 0.4471 | None | CARCE AREA | | |
| | Up | | Company and | N/A | | NB | Ą. |
| | All | | Therein. | NIA | | | |
| | | | GAS (QW-408) | | | | |
| e de l'erre Mai | 65°F (18°C) | | | | | | |
| | 180°F (82°C) | | GMAW | | | | |
| | As Above | | and the second | Argon | 100 | % Argon | 20-30 |
| | N/A | | a second s | None | | | |
| | | | time (c) | None | | | |
| ELECTRICAL CHARACTERISTICS | | | | | | | |
| Mort second to be | As per weldi | ng parameters | | | | | |
| | DC | | | RP (EP) | | | |
| | See below | | | See below | | | |
| | Global, Spray o | - Dulear | | | | | |
| | a short a burd a | un unseu | | | | | |
| | N/A | A T DISEU | | | | | |
| | | n u tu setu | | | | | |
| lan ann an lan ann. Tar | | n'i tuseti | | | | | |
| TECHNIQUE (OW-410) | | | MAW | | | | |
| TECHNIQUE (OW-410) | | G | MAW slight weave | | | | |
| TECHNIQUE (QW410) | | Gi Stringer/ | | | | | |
| TECHNIQUE (QW-410) | | G Stringer / 9/16 in | slight weave | | | | |
| December 200 Faile TECHNIQUE VOW-4101 TECHNIQUE VOW-4101 TECHNIQUE VOW-4101 Autor 200 Autor 20 | N/A | G Stringer / 9/16 in Brushin | slight weave n (14 mm) | ວນສູງໃດຜູ | | | |
| TECHNIQUE (QW-410) | N/A | G Stringer/ 9/16 in Brushin ing, Plasma Atc N | slight weave n (14 mm) g, grinding or Mechanical Go lone | ວນging | | | |
| Hardware per la de Norma TECHNIQUE VOW-4101 Millor Millor Millor Altan and and Millor March Norma | N/A | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip | slight weave n (14 mm) g, grinding or Mechanical Gr lone bass, as required | շսցուց | | | |
| Hardware per la de Norma TECHNIQUE VOW-4101 Millor Millor Millor Altan and and Millor March Norma | N/A | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si | slight weave n (14 mm) g, grinding or Mechanical Gr lone bass, as required ngle | ວນຊູງົກຜູ | | | |
| Trechnicoue series TECHNICUE (CIVI-4-10) | N/A | Gi Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (| slight weave n (14 mm) g, grinding or Mechanical Gr lone bass, as required ngle 18 mm - 25 mm) | ວນອູກັດສູ | | | |
| Tree-File CHNIQUE & OW-4101 TECHNIQUE & OW-4101 TRUE | N/A | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (| slight weave (14 mm) g, grinding or Mechanical G lone bass, as required ngle 18 mm - 25 mm) N/A | ວນອູງັກຜູ | | | |
| Tree-in-in- TECHNIQUE (CW-410) III - III III - III IIII - III III - IIII III - III III - III IIII - IIII IIII - IIII IIII - III IIII - IIII IIII - IIII IIIII - IIII IIIIII IIIII - IIII IIIIIIIIII | N/A | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (| slight weave n (14 mm) g, grinding or Mechanical Gr lone bass, as required ngle 18 mm - 25 mm) | วนฐาณ | | | |
| Tree-International Control of Con | N/A | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Mutlip Si 0,75 in - 1 in (Semi-/ N | slight weave n (14 mm) g, grinding or Mechanical G lone bass, as required ngle 18 mm - 25 mm) N/A Automatic lone | วนฎักษ | | | |
| Information of the Information o | N/A | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Mutlip Si 0,75 in - 1 in (Semi-/ N | slight weave n (14 mm) g, grinding or Mechanical G lone bass, as required ngle 18 mm - 25 mm) N/A Automatic | ວນອູງັກຜູ | | | |
| Andones and the COMMIQUE & COMMIQ | Grind | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (Semi-/ N N | slight weave n (14 mm) g, grinding or Mechanical G lone bass, as required ngle 18 mm - 25 mm) N/A Automatic lone | ວນອູງັກຜູ | | | |
| Trechnicous and a second secon | Grind | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (Semi-/ N N | slight weave n (14 mm) g, grinding or Mechanical G lone bass, as required ngle 18 mm - 25 mm) N/A Automatic lone | ouging | | | |
| December 2010 | Grind | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (Semi-A N N | slight weave n (14 mm) g, grinding or Mechanical Gi lone bass, as required ngle 18 mm - 25 mm) NA Automatic lone lone | | | | |
| Technicule volu-4101 Technicule volu-410 Technicule volu-410 Technicule volu-4101 Te | Grind | G Stringer / 9/16 in Brushin ing, Plasma Arc N Single / Multip Si 0.75 in - 1 in (Semi-/ N N | slight weave (14 mm) g. grinding or Mechanical Gr lone bass, as required ngle 19 mm - 25 mm) N/A Automatic lone | | 21-25 21-25 | | 10-20 |

Base metal shall be clean, dry & without water stain. Prepare weld joints by mechanical means (cutting, sawing, shearing etc), plasma arc cutting, laser cutting or water jet cutting. It is recommended to use acetone as a cleaning agent prior to welding (before removal of the oxide layer) and between passes. Immediately prior to welding remove oxide using either a stalnless steel brush or a non-resin bonded grinding disk (resin bonded disks may be used for post weld operations only). Remove smut between passes with a stainless steel wire brush. Ideally aluminum welding operations will be kept separate from welding on other materials. Do not use equipment for the welding of Aluminum that has been previously used for the welding or cleaning of other materials.

| anyar Farhadi, National Quality Systems Ma | | Mathew Smith, P. Eng. |
|--|------------|---|
| 2019-02-13 | 2018-02-06 | |
| | | anyar Farhadi. National Quality Systems Manager 2019-02-13 |

| Z NATIONAL ENERGY EQUIPMENT INC. | | | Quality Control Manual in accordance with CSA B620 | | | |
|--|---|--|---|---|--|---|
| ument Number: NEE | -QCM-THB-001 | | Revision Number: 04 Arash Navidan / Zanyar Farhadi | | | |
| oared by / Approved I | by: | | | | | |
| e of Issue: 2019/04/29 | | | Page Number: | 84 of 150 | | |
| | | | | | | |
| | (see QW-200.2, | Section IX, ASM | ocedure qualifica E Boiler and Pres s Used to Weld Te | sure Vessel Coo | | |
| Company Name Nationa | al Energy Equipme | nt Inc. | B | | | |
| Procedure Qualification Record (Pr Walding Procedure Specification (V Walding Process(es) Type(\$) (Manual, Automatic, Semi JOINTS (QVV-402) | WPS) No.: | GMAW-AL- GMAW-AL- GMAW Semi-autom | 01 is W | avision: sue Date: D | 0 4-Feb-20 W13939-I | |
| G = 1/64 m (0,4mm) Rf = 3/32 in (2,4mm) | T = 0.25 in (6 4mm | n' | | | cal for T = 0,25 in yers, 2 Passes | |
| | | | | | | |
| DAGE METALO (DIA 400) | Fundantingeson qualificatio | (e, the deposited ward metal | Incorrect shall no recorded to a | | | |
| BASE METALS (QW-403) | | POST WELD HEAT TREATMENT (QW-407) | | | | |
| (1) | ASTIN DOOD | ACTU DOGO | Carlos et | 1 | | |
| Mitting oper Transfer Comm | ASTM B209 | ASTM B209 5052 | EW) II | 1 | None | NUA |
| Transform | 5052 | 5052 | Ewit (f Templerature | N/A | | N/A |
| | | | - | 1 | None | N/A |
| Prove of Carene and Carenge and | 5052 P22 | 5052 P22 N/A | Templerature | N/A | None | |
| Prove of Carene and Carene (| 5052 P22 N/A | 5052 P22 N/A 4 mm) | Templerature | 1 | None | N/A Tim Hats (cimi) |
| Provide Concept 1955 Constraints Presidents of face obtaining Columnian | 5052 P22 N/A 0.25 in (6 | 5052 P22 N/A 4 mm) | Templerature | N/A | None Firm | |
| Front on Careline Comparison Transformers of face concerns I Calentinos | 5052 P22 N/A 0.25 in (8 N/A | 5052 P22 N/A 4 mm) | Tampenilue GAS (QVI-408) | NJA | None Films Face a Cohoosilant (0730 eq) | Concentration (Figure 1 |
| Trans of Grand Final Transmission of feat coupling Transmission I Clubbled To (millimmission (Maggi – Lights) (firmmi To Jumbal (Grans See.) | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A N/A | 5052 P22 N/A 4 mm) A 6 | Tampenylue GAS (QVV-408) Statistics Gar (ST/W) Lecting Sat Trailing Gas | N/A Argon N/A N/A | None Time Ferom Cotrosoften (076 m) 100% Ar N/A N/A | Conversion Financia |
| Trans of Grand Final Transmission of feat coupling Transmission I Clubbled To (millimmission (Maggi – Lights) (firmmi To Jumbal (Grans See.) | 5052 P22 N/A 0.25 in (8 N/A N/A N/A | 5052 P22 N/A 4 mm) A a a | Tampenylue GAS (QVV-408) Statistics Gar (ST/W) Lecting Sat Trailing Gas | N/A Serve Argon N/A | None Time Ferrers Consociant (0720 m) 100% Ar N/A N/A 409) | 1 m Hats (elen) 25 N/A N/A |
| Trease Care First Designed Trease and feat order 1 Carefuel Concern T Carefuel Common T Carefuel Common T Carefuel Common FILLER METALS (COW-404) | 5052 P22 N/A 0.25 in (8 N/A N/A Non N/A | 5052 P22 N/A 4 mm) A a a a a a | Cass (QW-408) | N/A Argon N/A N/A | None Firm Firm Consociant Orano 100% Ar N/A N/A N/A 409) All Passes | 1 m Hats (elen) 25 N/A N/A |
| Type of Carelle First Compiles Type and feat occasion 1 Carelle and feat occasion 1 Carelle and feat occasion The Carelle and the Carelle FILLER METALS (COW-404) BE* Corealization | 5052 P22 N/A 0.25 in (8 N/A N/A N/A Non N/A All Paa 5.1 | 5052 P22 N/A 4 mm) A A A Sees D | CAS (QVI-408) CAS (QVI-408) Cashing Gan (GT/W) Cashing Gan (GT/W) Cashing Gan Trailing Gan ELECTRICAL GAR/ Company (Cate), Max | N/A Argon N/A N/A | None Firm Percen Consoction (0)32(6) 100% Ar N/A N/A 409) All Passes 21.8 | 1 m Hats (elen) 25 N/A N/A |
| Tenkin-Carelle Fino- Geographic Trachae Juni for constant I Carelland Tel millionmad I Mass LCMI (Crimmy T. Landor Guar Sam) FILLER METALS (CIW-404) SE ¹ Corealization Filter (Meal Cleanification | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pae 5.11 ER53 | 5052 P22 N/A 4 mm) A A A Sees D 56 | Temperature GAS (QVV-408) Straining Gan (GD/W) Electing Gan Training Gan ELECTRICAL GAR/ Houlingul (Lake) - Mex Current | N/A Argon N/A N/A | None Fire Percen Consoction (0)32(6) 100% Ar N/A N/A 409) All Passes 21.8 DC | 1 m Hats (elen) 25 N/A N/A |
| Type - Care First Comprise Trackae and fact organis 1 Calefinat Fill Calefinat 1 Calefinat The Calefination FILLER METALS (COW-404) SE ¹ Consultation Filler Metal Clean Anator Filler Metal Clean Anator Filler Metal Clean Anator Filler Metal Clean Anator Filler Metal Clean Anator | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pae 5.11 ER53 F22 | 5052 P22 N/A 4 mm) A A A A A A A A A A A A A A A A A A | Temperature GAS (QVV-408) Straining Aim (STAW) Backing Kan Traing Gas Traing Gas ELECTRICAL CAR Healingul (Faim) - Max Current Current Current | N/A Argon N/A N/A | None Dive Permit Concordiant (0)32(m) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) | 1 m Hats (elen) 25 N/A N/A |
| Press - Cores Press Graphino Trespectual feetorecom 1 Calabian 1 Calabian 1 Calabian 1 Calabian 1 Calabian 1 Calabian Press | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 | 5052 P22 N/A 4 mm) A 6 6 5 6 5 6 2 5 8 | Temperature GAS (QVV-408) Straining Gan (STAW) Backing Gas Training Gan (STAW) Backing Gas Training Gas ELECTRICAL GAR/ Chroniti Cutroniti Cutroniti Cutronity Amparenti | N/A Argon N/A N/A | None Dive Permi Concordium (0)32(m) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 | 1 m Hats (elen) 25 N/A N/A |
| Press - Cores Press Graphino Trespectual for constant 1 Calabian 1 Calabian 1 Calabian 1 Calabian 1 Calabian 1 Calabian Press | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pae 5.11 ER53 F22 | 5052 P22 N/A 4 mm) 4 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 | Temperature GAS (QVV-408) Straining Aim (STAW) Backing Kan Traing Gas Traing Gas ELECTRICAL CAR Healingul (Faim) - Max Current Current Current | N/A Argon N/A N/A | None Dive Permit Concordiant (0)32(m) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) | 1 m Hats (elen) 25 N/A N/A |
| Type in Carelle Final Comprise Final Analysis on Comprise Final Analysis Final Comprise Final Comprise | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 0.035 in (0 | 5052 P22 N/A 4 mm) 4 56 56 2 56 2 56 2 56 2 56 2 56 2 56 2 | Temperature GAS (QVV-408) GAS (QVV-408) Straining Gan (GTAW) Backing Gas Training Gan (GTAW) Backing Gas Training Gas ELECTRICAL GAR/ Houlingul (Fuller) - Mac Current Current Current Current Current Voltz | N/A Argon N/A N/A | None Dive Percent Concoction (000000) 100% Ar N/A N/A All Passes 21.8 DC RP (EP) 210 23 | 1 m Hats (elen) 25 N/A N/A |
| Type x - Carelle Fino. Comprise Traches and feet oncession 1. Calabilities 1. Calabilities 1. Calabilities 1. Calabilities Filler (Second Calabilities) Filler (Second Calabilities) F | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pas 5.10 ER53 F22 ER53 0.035 in (0 Solid V | 5052 P22 N/A 4 mm) 4 seas 5 5 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 5 5 6 2 2 5 6 2 2 5 6 2 2 5 7 2 2 8 7 2 2 8 7 2 7 8 7 7 8 7 7 7 7 7 | Temperature GAS (QVV-408) Straining Gan (STAW) Backing Gas Training Gan (STAW) Backing Gas Training Gas ELECTRICAL GAR Christingul (Tutho), Max Christin Christingul (Tutho), Max Gareati Christingul (Tutho), Max Kote of Training | N/A Argon N/A N/A | None Dive Percent Concordium (000000) 100% Ar N/A N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray | 1 m Hats (elen) 25 N/A N/A |
| Tipes of Carelle Final Comprise The Area and Tex socialism 1 Calabilities 1 Calabilities | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non | 5052 P22 N/A 4 mm) 4 56 56 56 2 56 56 2 56 56 2 56 2 56 2 | Temperature GAS (QVI-408) GAS (QVI-408) Straining Gan (STAW) Backing Gas Traing Gas Traing Gas ELECTRICAL GAR/ Heal input (Luke) , Max Current | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None Dive Persin Concordium (0)32(0) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A | 1 m Hats (elen) 25 N/A N/A |
| Tipe x - Carelle Fino. Comprise Tredoness, of feet occasion 1. Calabilities 1. Calabilities 1. Calabilities 1. Calabilities 1. Calabilities Filler (Second Calabilities) FILLER METALS (COVE-404) EFT Covershiftson Filler (Metal Calabilities) Filler (Metal Calabilities) Filler (Metal Calabilities) Filler (Metal Calabilities) Score of Filler Metal (Metal Metal Calabilities) (Metal Metal Metal Calabilities) (Metal Metal Metal Metal) (Metal Metal Metal) (Metal Metal Metal Metal) (Metal Metal Metal Metal Metal) (Metal Metal Metal Metal Metal Metal) (Metal Metal M | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non | 5052 P22 N/A 4 mm) 4 56 56 56 2 56 56 2 56 58 0.9 mm) Nire te 4 mm) 16 | Temperature GAS (QVI-408) Straining Gan (STAW) Backing Gas Toolary Gan (STAW) Backing Gas Toolary Gas Toolary Gas Current Cu | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None Dive Percent Concoction (07000) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 | 1 m Hats (elen) 25 N/A N/A |
| Inclusion Commission Inclusion (Secondarian Clustification (Secondarian Clustification) Inclusion Inclusion (Secondarian Inclusion (Secondarian FILLER METALS (COVE-404) Inclusion (Secondarian FILLER METALS (COVE-404) Inclusion (Secondarian FILLER METALS (COVE-404) Inclusion (Secondarian Inclusion (Second | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non | 5052 P22 N/A 4 mm) 4 56 56 56 56 56 56 56 56 58 N.9 mm) Nire te 4 mm) 16 6 | Tempergiue GAS (QVI-408) GAS (QVI-408) Gas Smalling Gas Traing Gas Traing Gas ELECTRICAL GAR/ Heal Input (Later), Max Gurenti Calment Cal | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None Dive Percent Consoction (0)32(e) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 | 1 m Hats (elen) 25 N/A N/A |
| Pener - Commission Procession of loss occurs Procession of loss occurs Procession of loss occurs Procession of loss occurs Procession of loss of loss of loss Procession occurs Procession occurs Procession occurs Procession occurs Procession occurs Procession of loss Procession occurs Procession occurs | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non | 5052 P22 N/A 4 mm) 4 56 56 56 56 56 56 56 56 58 N.9 mm) Nire te 4 mm) 16 6 | Temperature GAS (QVI-403) Strating Gas ELECTRICAL GAR/ Gurenti Cumpt) Amprovi Voliz Kote of Carnetor Voliz Note of Carnetor Ungstar electrose Nite Frice Operat (pm) Uter, At3 (pm) Technique (CVV-410 Electricule (CVV-4 | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None Dive Percent Consoction (0)12000 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer | 1 m Hais - comy 25 N/A N/A |
| Press - Comme From Comme From Comme From Comment Count of feet occurs From Comment Count of feet occurs Fritzen (Count occurs Fritzen (Count occurs Fritzen (Count occurs Fritzen (Count occurs Fritzen (Count occurs Fritzen (Count occurs Count occurs Count occurs Count occurs Fritzen (Count occurs Count occurs Fritzen (Count o | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pae 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non Non | 5052 P22 N/A 4 mm) 4 56 56 56 56 56 58 0,9 mm) Nire te 4 mm) 16 te | Temperature GAS (QVI-408) Strateging Gas Trateging Gas Trateging Gas Trateging Gas ELECTRICAL GAR/ Gurenti Coursett Co | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None None Percent Consoction (0)32(e) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer \$/16 in (14 m) | Un Hais (dan) 25 N/A N/A |
| Tipes - Carelle Fino. Gragmino Thebresia of feet occursion 1. Calablado 1. Calablado 1. Calablado 1. Calablado 1. Calablado Filler (Secolaristica) FILLER METALS (QVV-404) SET Greenhiston Filler (Secolaristica) Filler (Secolaristica) | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pac 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non Non Linde El | 5052 P22 N/A 4 mm) 4 56 56 56 56 56 58 0.9 mm) Wire te 4 mm) 16 te | Temperature GAS (QVV-408) Strateging Gas Trateging Gas Trateging Gas ELECTRICAL GARV Useding Gas ELECTRICAL GARV Useding Gas Current Curre | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None Time Percent Consoction (0132m) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust | Un Hais (dan) 25 N/A N/A |
| Type of Careford Pints Group mo The break of feet occasion 1 Cuelling 1 C | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pac 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non N/A Linde El GMA | 5052 P22 N/A 4 mm) A A B B A B B B B B B B B B B B B B B | Tempergiue GAS (QVI-408) GAS (QVI-408) GAS (QVI-408) Gas Stealang Gas Tralag Gas Tralag Gas ELECTRICAL CAR/ Heal input (Lake) , Max Gurenti Carenti | N/A Siend Argen N/A N/A ACTERISTICS (QW- | None Time Percent Consoction (013200) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust Grinding | Un Hais (dan) 25 N/A N/A |
| Type of Careford Pints Group mo The breach of fore occasion 1 Challed A Confirmmed 1 Challed A Confirmmed 1 Desc Lidver, Primory FILLER METALS (COV-404) SPT Covering to an one Filter Medal (Careford) SPT Covering to an one Spring Metal (Careford) Spring Metal (Careford) Spring Metal (Careford) Weith Metal (Careford) Spring Metal (Careford) Weith Metal (Careford) Spring Metal (Careford) Metal Metal (Careford) Metal Metal (Careford) Weith Metal (Careford) Metal Metal (Careford) Metal Metal (Careford) Metal Metal (Careford) Metal Metal (Careford) Metal Metal (Careford) Metal (Careford) Me | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pac 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non Non Linde El | 5052 P22 N/A 4 mm) A A B B A B B B B B B B B B B B B B B | Tempergiue GAS (QVI-408) GAS (QVI-408) GAS (QVI-408) Gas Stellong Gas Trailing Gas Trailing Gas ELECTRICAL GAR/ Heal Input (Lake), Max Gurenti Carenti Carent | | None Time Percent Consoction (013200) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust Grinding None | Un Hais (dan) 25 N/A N/A |
| Type of Careford Pints Group mo The break of feet occasion 1 Cuelling 1 C | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pac 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non N/A Linde El GMA | 5052 P22 N/A 4 mm) A A B B A B B B B B B B B B B B B B B | Tempergium GAS (QVV-408) GAS (QVV-408) GAS (QVV-408) Gas (GTAW) Lecting Gas Trailing Gas Trailing Gas Commit Trailing Gas ELECTRICAL CAR) Houl Input (Luke) , Max Gament Commit Commi | | None Time Percent Consoction (013200) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust Grinding | Un Hais (dan) 25 N/A N/A |
| Types of Career Proc. Group into Trackine Lio Floe coccession 1 Classification 1 Classification 1 Classification 1 Construction 1 Cons | 5052 P22 N/A 0.25 in (8 N/A N/A N/A N/A All Pac 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non Non N/A Linde El GMA | 5052 P22 N/A 4 mm) 4 4 56 55 55 2 55 2 55 2 55 2 55 2 55 2 | Tempergiue GAS (QVI-408) GAS (QVI-408) GAS (QVI-408) Gas Stellong Gas Trailing Gas Trailing Gas ELECTRICAL GAR/ Heal Input (Lake), Max Gurenti Carenti Carent | | None Time Percent Consoction (01200) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust Grinding Nons Single | 1 MAA ohay 25 N/A N/A |
| Type v= Carelle Pino. Groupmo The location for sociality 1 Cualification 1 Cualification 1 Cualification 1 Cualification Filler (Social Prime) FILLER METALS (QVV-404) SP* Covering to the movies of the social s | 5052 P22 N/A 0.25 in (8 N/A N/A N/A All Pac 5.10 ER53 F22 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non N/A Linde El GMA 1G (F | 5052 P22 N/A 4 mm) 4 4 mm) 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 | Temperature GAS (QVI-408) GAS (QVI-408) GAS (QVI-408) Gas (GTAW) Lecting Gas Trailing Gas Trailing Gas Trailing Gas Commit Trailing Gas Gument Commit Co | | None None Diversion N/A N/A N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust Grinding None Single Single | 1 MAA ohay 25 N/A N/A |
| Type of Careford Proc. Groupmo The base of top occasion 1 Cualification Fill Cualification Cualification Fill Cualification Cualification Fill Cualification Fill Cualification | 5052 P22 N/A 0.25 in (8 N/A 0.25 in (8 N/A N/A All Pas 5.10 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non 0.25 in (8 Non Non N/A Linde El GMA 1G (F | 5052 P22 N/A 4 mm) 4 4 mm) 4 4 56 55 55 55 55 55 55 55 55 55 55 55 55 | Temperature GAS (QVI-408) GAS (QVI-408) GAS (QVI-408) Gas (GTAW) Bedding Gas Trailing Gas Trailing Gas Trailing Gas Current Curre | | None None Time Percent Concordint (Internet) 100% Ar N/A N/A 409) All Passes 21.8 DC RP (EP) 210 23 Spray N/A 525 13.3-17.1 Stringer 9/16 in (14 m Grinding, brust Grinding None Single Single 1 in (25 mm | 1 m Hate (shary) 25 N/A N/A m/A m) ming |
| Type of Careller Proc. Group mo The breach of fore occasion 1 Challer 1 | 5052 P22 N/A 0.25 in (8 N/A 0.25 in (8 N/A N/A All Pas 5.10 ER53 0.035 in (0 Solid V Non 0.25 in (8 Non 0.25 in (8 Non Non 0.25 in (8 Non Non 0.25 in (8 Non Non 0.25 in (8 Non Non 0.25 in (8 Non Non N/A | 5052 P22 N/A 4 mm) 4 4 mm) 4 4 56 55 55 55 55 55 55 55 55 55 55 55 55 | Temperature GAS (QVI-408) GAS (QVI-408) GAS (QVI-408) Gas (GTAW) Beding Gas Trailing Gas Trailing Gas Trailing Gas Trailing Gas Gurent Council (Call CAR) Gurent Gastation Gurent Council (Call CAR) Gurent Gastation Gastation Gastation Council (Call CAR) Gurent Council (Call CAR) Gurent Gastation Gurent Gastation | | None None Dive None None None None None None None None None None None Single Si | 1 m Hate (shary) 25 N/A N/A m/A m) ming |

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 85 of 150 |

| | | | | -483 (BACK) | | GMAL | V-AL-01 |
|-----------------------|--------------------------------------|---------------|------------------|-----------------------|------------------------|--|-------------------|
| | | | TENSIL | E TEST (QW-150) | | Sector 1 | |
| | No. | - o llo | | (mails (move | Ontereste | | d faither |
| | | | | | Mile- | | |
| 5T1 | 6.15 | 18.9 | 116 | 22.5 | 194 | Base Me | tal - Ductile |
| 5T2 | 6.15 | 18.9 | 116 | 22.8 | 195 | 1 | tal - Ductile |
| 1. | Specified UTS | : 170 Mpa m | | | 01125T, dated 29/01 | /2019 | |
| 100000 | Turner | | GUIDE BE | END TEST (QVV-160 | 2) | 1 | |
| 5F1 | Transverse, Face Transverse, Face | | | | | | les within limit |
| 5F2 | | | QW-462.3(a) | 180° | Acceptable | | ies within limit |
| 5R1 | Transverse, | | QW-462.3(a) | 180° | Acceptable | and the second sec | les within limit |
| 5R2 | Transverse, | | QW-462.3(3) | 180° | Acceptable | | les within limit |
| | | | 21901301156B, da | | I Mecabiable | 1 wiscontinuu | iss worder output |
| | elle usball h | al traduction | | ESIS TEST (QW-170 | 1) | | |
| | | | | | | Transfer and | Law Brown |
| and the first | | | | | | | 4 |
| N/A | | | | | | | |
| | | | | | | | |
| | | | Ha | | | | |
| | | - | - 1 a 10 10 | | | | |
| | | | | 1 | | | |
| N/A | | | | | | | |
| | | | | | | | |
| | GMAW | V.V | ELLING EGUIPME | ENT AND SETTING | EDETAILS | | |
| | CV | | | | | | |
| | N/A | | | | | | |
| | N/A | | | | | | |
| | N/A | | | | | | |
| and the second second | | Michae | Critchlow | Venee | | BCSA Reg. | #384846 |
| | | | IC 13939 | 6 | | 18-Jan- | |
| | | | ineering Ltd. | | | (Compared of the second | |
| | | | | Address Tault | | W13939-P190 | |
| | C | rristopher F | toss, Applus RTD | | | W13939-P190 | 1301156B |
| tes | | | | | | | |
| | | | | | | | |
| | we certify | | | | tal the test welds wer | e prepared, | |
| | | welded an | | ance with the require | | | |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 86 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 87 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 88 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 89 of 150 |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2019/04/29

Page Number: 90 of 150

| 21 | .1 | .1 | 0 | |
|----|----|----|---|--|
| | | | | |

| | TC 331 (| tank 1-year inspection checklist | | | |
|---|--|---|--|--|--|
| Form Number:NEE-FR-L-010 | Revision: 0 | | | | |
| Date: Tank Owner: Address: | Phone #: Unit #: | : Page 1 of 2 | | | |
| Serial #: Tank Spec: Shell Material: Comp. Sizes: Original Test Date: M.A.W.P.: Tests Performed: K Hose Test **Tank and attachments must be clean prior to inspect | MFG Date: Test Pressur Next 5-year i | | | | |
| **Working from Heights policies are in effect** | | | | | |
| External Visual "V" | | | | | |
| -Inspect data plate [12.2] (legible, permanently affixed, | has all information | required in 12.2) PassFailN/A | | | |
| -Inspect tank inspection decals [12.2] (verify what tests | are required, 1 yea | r or 5 year) PassFailN/A | | | |
| -Inspect tank bulk heads and shell [12,2] (Check for indicating weakness in the tank that could render it unsafe show no signs of leakage.) | | | | | |
| -Inspect fenders and attachments [12.2] (Ladder/drop I mounting) | iose compartments | latch, cracks, damage to fenders or PassFail N/A | | | |
| -Inspect bumper / rear end protection [12.2] (Securely between widest part of rear of vehicle and outward edge of bumper and ground is less than 30" when empty.) | | exceed 18" distance between bottom of | | | |
| -Inspect rear tank sills/frame [12.2] (damage, welds) | | PassFailN/A | | | |
| -Inspect placards (correct product, legible, all 4 present) | | PassFailN/A | | | |
| -Inspect tank mounts [12.2] (unable to loosen with wren [wood/rubber etc.]) | ich, welds on brack | ets, condition of sill fil material PassFailN/A | | | |
| -Inspect underslung boxes [12.2] (hydraulic leaks, fittin valves/air switches work correctly, grasshopper springs) -Inspect slam latches/door safety latches [12.2] (all late -Inspect cabinet doors (damage, seal properly when clos -Inspect all air switches (make sure all switches work) -Inspect emergency switches (verify operation of all) -Inspect underneath tank [12.2] (denis, corrosion, leaks voids are not capped, pipes for dents/rubbing, hydraulics, Outlet valve) | ch correctly) sed) 1,ISC vics, cracks of | Pass Fail N/A Pass Fail N/A Pass Fail N/A Pass Fail N/A Pass Fail N/A Pass Fail N/A n outriggers/cross members, make sure | | | |
| -Inspect on top of tank [12,2] (dents, corrosion, fall prot wearing tank, obvious signs of leakage, | tection functions (if | equipped), anti-slip grating insecure or Pass Fail N/A | | | |
| Leakage Test "K" | | Test Pressure | | | |
| Dedicated service, the fest pressure shall be the maximum | normal operating | pressure of the tank, | | | |
| MC 330, MC 331 or TC 331 in LPG or NH3 service shal | l be tested at no les | s than 60 PST | | | |
| - Pressure test compartment and all associated, | | | | | |
| -Spray with soapy water all welds pipe connections, met | er and pump equipr | nent for signs and observe for signs of leaks. | | | |
| TANK [12.5] Pass Fail N/A PII | PING [12.5] | Pass Fail N/A | | | |
| | 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 | | | | |

ZEQUIPMENT INC.

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2019/04/29

Page Number: 91 of 150

| | TC 331 tank 1-year inspection checklist |
|---|---|
| Form Number:NEE-FR-L-010 | Revision: 0 |
| Emergency Discharge Control [12.2] | Pass Fail N/A Page 2 of 2 |
| -TC 331 tanks that transport liquefied compressed gas (LPG) designed to transport Class 2.2, non-flammable and non-toxi | |
| -Tanks that are 13,250L or less, equipped for metered Servic | e, need an off-truck emergency shutdown system. |
| -Tanks that are 13,250L or more, equipped for metered servi- emergency shutdown system in addition to an off-truck emer | |
| -The system will be tested at the time of inspection. | |
| -With product running at normal flow rate throughout the me system (normally this would be a BASE Engineering produc the product flow. The meter should stop the flow and close the | t) Observe the meter to determine how long it takes to stop |
| seconds or sooner. No meter creep after 5 seconds. | |
| -The same process for testing the Emergency Discharge Con | trols shall be used on both ON and OFF truck applications. |
| -The emergency shut down system shall function reliably at : | a distance of 46 m (150ft) and |
| -When the Emergency shutdown has been activated, the ISC | can't be reactivated remotely. |
| -Indicate results on Test and Inspection Report (Form No- N | EE-FR-L-007). |
| closed, all of the inaterial in the downstream piping shall be of temperature and pressure. The outlet shall then be monitored leakage. Hose Test [12.2 & 12.9] | |
| -Perform visual inspection of all hoses (look for kinks, exp | osed re-enforcement, damaged ends, gaskets) |
| -Pressure test all hoses (hold pressure for 5 minutes) Hose I.D. : Test Press. : (Test/MAWP) Test Medium : | PassFailN/A PassFailN/A |
| | |
| Fail Items | Failure Corrected Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N Y N |
| ONLY AFTER SUCCUSSFEUL TEST WILL I Has inspection sticker been applied to tank? (Sticker must be affixed Driver-side front of the barrel and el Has B620 test and inspection report been filled out? ** Take picture of Data Plate and attach | YN learly visible) YN |

Quality Control Manual Z NATIONAL ENERGY EQUIPMENT INC. in accordance with CSA B620 **Document Number:** NEE-QCM-THB-001 **Revision Number:** 04 Prepared by / Approved by: Arash Navidan / Zanyar Farhadi

| Date of Issue: | 2010/04/20 |
|----------------|------------|
| Date of issue. | 2012/04/22 |

NA

Page Number: 92 of 150

| COM | IPANY: | | | |
|----------|---|------------|--------------|--------------|
| ADD | RESS: | | | |
| | | | | |
| DATE | | | UNIT No.: | |
| TCS | PEC: DESIGN PI | RESSURE: | MANUFACTU | IRER: |
| VEAD | R OF MANUFACTURE: | TANK SERI | N No- | |
| | ACITY BY COMPARTMENT: | IABINOLINI | AL NO. | |
| | 2 3 | 4 | 5 | 6 |
| | I SERVICE ON | 1.00 | 1.2 | |
| | | | Certified by | |
| Inspe | ection Conducted by: | | | |
| BI-T | INODECTION ACTIVITY | 001/01/150 | Debalo | LUGI D DOUIT |
| No. 1 | INSPECTION ACTIVITY | COMPLIES | REPAIR | HOLD POINT |
| 2 | Drawings Materials | | | |
| 3 | Welding | | | |
| 4 | External Visual Inspection | | | |
| 5 | Internal Visual Inspection | | | |
| 6 | Rollover Protection | | | |
| 7 | Emergency Flow Control & Piping | | | |
| 8 | Safety Relief Valves | | | |
| 9 | Vapour Tightness Test | | | |
| 10 | Lining Inspection | | | |
| 14 | Leakage Test | | | |
| 12 | Ultrasonic Thickness Test | - | | |
| 13 | Wet Fluorescent Test | | | |
| 14 | Hose Assembly | | | |
| 15 | Hydrostatic Retest | | | |
| 16 | Cold Vacuum Retention Test Helium Detection Test | | | |
| 1.1 | Manhole Covers | | | |
| 1.0. | Manufacture / Repair / Recertification | | | |
| 18 19 | Plate | | | |
| 18 19 | | | | |
| | Other (detail) | | 1 | |
| 19 | Other (detail) | | | |
| 19 | Other (detail) | | | |
| 19 20 | Other (detail) | | Date | |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B6 | | |
|---|---|--|--|
| | Revision Number: 04 | | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | | |
| Date of Issue: 2019/04/29 | Page Number: 93 of 150 | | |
| 21.1.12 | | | |
| RATIONAL ENERGY EQUIPMENT INC. | Hose assembly test and inspection report | | |
| Form Number:NEE-FR-L-012 | Revision: 0 | | |
| FACILITY NAME: ADDRESS: | TEST DATE: | | |
| HOSE OWNER: | | | |
| UNIT # | | | |
| | | | |
| HOSE SERIAL # | OMPLIES COMPLIES COMPLIES | | |
| | | | |
| KINKED, FLATTENED OR PERMANENTLY DEFORMED | | | |
| SOFT SPOTS WHEN NOT UNDER PRESSURE, BULGING UNDER PRESSURE OR LOOSE OUTER COVERING | | | |
| COUPLINGS | | | |
| COUPLING ASSEMBLIES | | | |
| DETERIORATED LEGIBILITY OR ABSENCE OF SERIAL OR ID NUMBER OR HAWP | | | |
| HOSE SERIAL # HAWP (PSI) | TEST PRESSURE (PSI) TEST MEDIUM PASS FAIL | | |

| | | | Quality Control Manual in accordance with CSA B620 | | | |
|----------|--|---------------------------|---|--|--|--|
| ment N | umber: NEE-QCM-THB-001 | Revision Number: (| Revision Number: 04 | | | |
| red by | / Approved by: | Arash Navidan / Zan | Arash Navidan / Zanyar Farhadi | | | |
| of Issue | e: 2019/04/29 | Page Number: 94 o | Page Number: 94 of 150 | | | |
| 1.13 | NA | | | | | |
| | | RGY | | | | |
| | I - EQUITMENT INC | Weld | ing inspection report | | | |
| | Form Number:NEE-FR-L-013 | Revision: 0 | | | | |
| | Facility Address: | | | | | |
| | Registration #: | | | | | |
| | Owner's Serial #: | | | | | |
| | Manufacture: | | | | | |
| | MFR Date: Mat | | | | | |
| | Location of welds to be inspecte | | | | | |
| | | | | | | |
| | Welding Process(es): | | | | | |
| | Welding Process(es): Welder Qualification Verified YI | ES NO | | | | |
| | Welder Qualification Verified YI | ES NO | | | | |
| | Welder Qualification Verified YI | ES NO | | | | |
| | Welder Qualification Verified YI | ES NO | | | | |
| | Welder Qualification Verified YI ITEM ITEM Porosity and/or Inclusions Inclusions Complete Fusion Inclusions Start and End Complete Inclusions | ES NO | | | | |
| | Welder Qualification Verified YI ITEM I Porosity and/or Inclusions I Complete Fusion I Start and End Complete I Full Penetration I | ES NO | | | | |
| | Welder Qualification Verified YI ITEM ITEM Porosity and/or Inclusions Inclusions Complete Fusion Inclusions Start and End Complete Inclusions | ES NO | | | | |
| | Welder Qualification Verified YI ITEM I Porosity and/or Inclusions I Complete Fusion I Start and End Complete I Full Penetration I | ESNO | REJECT | | | |

| NATIONAL ENERGY | |
|-----------------|--|
| EQUIPMENT INC. | |

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 95 of 150 |

| n Number:NEE-FR-L-014 | | | Revisi | on: U | | |
|------------------------|------|--------|--------|-------|------------------|-----|
| Mobile gauges for B620 | | | | | | |
| Gauge # | Date | Method | Pass | Fail | Next Due Date | Job |
| | | | - | - | | |
| | | | | | | |
| | - | - | | - | | |
| | | | | 1 | | |
| | | | 2 | | | |
| | - | | | + | - | |
| | | | | | | |
| | | | | | | |
| | - | _ | | - | - | |
| | | | | | | |
| - | | | 1 | | | |
| | | | | | 1 | |
| | | - | - | | - | |
| | | | | | | |
| - | | | | | | |
| - | | - | - | | | |
| 2 | | | | | | |
| | | | 1 | | | |
| | | - | - | | - | |
| | | | | | 1 | |
| | | | 11 | 12.2 | | |
| | | | | | | |

| NATIONAL ENERGY |
|-----------------|
| EQUIPMENT INC. |

Document Number: NEE-QCM-THB-001Revision Number: 04Prepared by / Approved by:Arash Navidan / Zanyar FarhadiDate of Issue: 2019/04/29Page Number: 96 of 150

| | | | Revision: 0 | | | |
|----------------|-------------|---------------------|-------------|---------------|--------|--|
| I.D. Number | Description | Calibration Date | Due Date | Calibrated By | Result | |
| | | | | | | |
| | | | | | | |
| | | | i III | | | |
| | | | | - | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| - | | | | | | |
| | | | | | 1 | |
| | | - | | | - | |
| | | | | | - | |
| | | | | | - | |
| | | | | | - | |
| | | | ÷ | | - | |
| | | | | | _ | |
| | | | | | | |
| | | - | | | | |
| | | | | | | |

| Document Number: NEE-QCM-THB-001 | | | | in accordance with CSA B620 Revision Number: 04 | | | | |
|---|---------------|-------------|------------|--|--------------------|--|--|--|
| | | WI-1ПD-001 | | | - Fack a di | | | |
| Prepared by / Approved by: Date of Issue: 2019/04/29 | | | | Arash Navidan / Zanyar Page Number: 97 of 15 | | | | |
| 21.1.16 NA | | | | age Number. 97 01 1. | 50 | | | |
| 21.1.10 | | URMEN FN | ERGY VC | Weld | er Continuity Log | | | |
| | Form Number:N | EE-FR-L-016 | | Revision:0 | | | | |
| | Welder: | tion #: | | | | | | |
| | Date | Customer | Proces | s Date Qualified | Repair description | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| Z NATIONAL ENERGY EQUIPMENT INC. | | ïY | Quality Control Manual in accordance with CSA B620 | | | | |
|-------------------------------------|---|-----------------------|--|--|--|--|--|
| ocument Number: NEE-QCM-THB-001 | | | evision Number: 04 | | | | |
| repared by / | Approved by: | Aı | ash Navidan / Zanyar Farhadi | | | | |
| Date of Issue: | 2019/04/29 | Pa | ge Number: 98 of 150 | | | | |
| 21.1.17 | | | | | | | |
| | | | | | | | |
| | Z NATIONAL EN EQUIPMENT I | IERGY NC. | Nonconformance corrective and preventative action report form | | | | |
| | Form Number:NEE-FR-L-017 | | Revision: 0 | | | | |
| | | | | | | | |
| | | Type ol | action/Status | | | | |
| | Corrective Action | | Preventive Action | | | | |
| | Job # | | | | | | |
| | Issued To | | | | | | |
| | Reference Highway Tank/ Portable Tank | | - 1 | | | | |
| | Reference Area/Process | | | | | | |
| | Documents | - | | | | | |
| | Name of Initiator: | Signature: | ture: Date: | | | | |
| Name of Initiator: Signat | | | | | | | |
| | | | | | | | |
| | | Noi | nconformity | | | | |
| | Description of Nonconformity: | Noi | nconformity | | | | |
| | Description of Nonconformity: | Nor | nconformity | | | | |
| | Description of Nonconformity: | | oot Cause | | | | |
| | Corrective Action | | | | | | |
| | | | oot Cause | | | | |
| | Corrective Action | R | oot Cause | | | | |
| | Corrective Action Determination of Root Cause: | on: | oot Cause Preventive Action | | | | |
| | Corrective Action Determination of Root Cause: | R | oot Cause Preventive Action | | | | |
| | Corrective Action Determination of Root Cause: | on: Position/Title | oot Cause Preventive Action | | | | |
| | Corrective Action Determination of Root Cause: Description of Implemented Acti Signature: | on: Position/Title | Date: | | | | |
| | Corrective Action Determination of Root Cause: Description of Implemented Acti Signature: | on: Position/Title | oot Cause Preventive Action Date: | | | | |
| | Corrective Action Determination of Root Cause: Description of Implemented Acti Signature: | on: Position/Title | oot Cause Preventive Action Date: | | | | |



| | T = EQUIPMENT INC. | | in accordance with CSA B620 | | | |
|--------|-----------------------|--|---|--|--|--|
| Docur | nent Number: NEE-QCM | -THB-001 | Revision Number: 04 | | | |
| Prepa | red by / Approved by: | | Arash Navidan / Zanyar Farhadi | | | |
| Date o | f Issue: 2019/04/29 | | Page Number: 99 of 150 | | | |
| 21.1 | .18 Mandatory | y Document List | | | | |
| - | NEE-FRM-001 | Metal identification Related Sections: 7 N | plate stamping Manufacture, 8 Assembly | | | |
| - | NEE-FRM-002 | Modification plate st Related Section: 9 M | 1 0 | | | |
| - | NEE-FRM-003 | 1 1 | nformation sheet for recertified tanks Manufacture, 8 Assembly, 9 Modification | | | |
| - | NEE-FRM-004 | 1 | ance for new & assembled tanks Manufacture, 8 Assembly | | | |
| - | NEE-FRM-005 | Modification certific Related Section: 9 M | - | | | |
| - | NEE-FRM-006 | Repair report Related Section: 10 I | Repairs | | | |
| - | NEE-FRM-007 | Test and Inspection I Related Section:12 In | Report inspection and testing – examination | | | |
| - | NEE-FRM-008 | Metal identification Related Section:12 In | plate replacement nspection and testing – examination | | | |
| - | NEE-FRM-010 | | Inspection Check List nspection and testing - examination | | | |
| - | NEE-FRM-011 | Test and inspection t Related Sections: 7 M | ravel sheet Manufacture, 8 Assembly, 9 Modification | | | |
| - | NEE-FRM-012 | • | and Inspection Report nspection and testing - examination | | | |
| - | NEE-FRM-013 | Welding inspection r Related Sections:10 | eport Repairs, 15 Welding / brazing control | | | |
| - | NEE-FRM-014 | Gauge Calibration L Related Section:16 C | | | | |
| - | NEE-FRM-015 | Equipment Calibration Related Section:16 C | | | | |
| - | NEE-FRM-016 | Welder Continuity L Related Section: 15 V | | | | |
| - | NEE-FRM-017 | | rrective and preventative action report Nonconformities-Corrective action, 17 Quality audits | | | |



Document Number: NEE-QCM-THB-001

Revision Number: 04

Prepared by / Approved by:

Date of Issue: 2019/04/29

Arash Navidan / Zanyar Farhadi

Page Number: 100 of 150

21.1.19 List of registered design engineers

| Name: | <u>Ahmad Moaaz</u> |
|--------------------------|---|
| Address: | 1004 600 Setter St Winnipeg MB R2Y 2H7 |
| Registration No.: | 35-0188 |
| Date of Expiry: | 01-February-2021 |
| Telephone: | 204-698-0657 |

Transport Canada

rt Transports Canada

Certificate of Registration

This is to certify that

Ahmad Moaaz

residing at:

1004 600 Setter St Winnipeg, MB R2Y 2H7

is registered as a

Design Engineer

pursuant to the requirements of Clause 8.1.5 of CSA Standard B620-09.

EXPIRY DATE OF THIS REGISTRATION:

Unless otherwise notified this registration is valid until the date of expiry indicated below. A new application must be submitted where there is any substantive change in the information given on the application form filed with Transport Canada. Application for renewal must be made by email at least three months before expiry.

DATE OF ISSUE: 08-January-2016 DATE OF EXPIRY: 01-February-2021

REGISTRATION #: 35-0188

| NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 Revision Number: 04 | | | |
|---|--|--|--|--|
| Document Number: NEE-QCM-THB-001 | | | | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | | | |
| Date of Issue: 2019/04/29 | Page Number: 101 of 150 | | | |
| 21.1.20 List of B620 personnel and their qu | ualifications | | | |
| Name: Position: Qualification Date: Qualification Process: Name: Position: Qualification Date: Qualification Process: Name: Position: Qualification Process: Name: Qualification Process: Qualification Qualification | | | | |
| Process: Name: Position: Qualification Date: Qualification Process: | | | | |
| Name: Position: Qualification Date: Qualification Process: | | | | |
| Name: Position: Qualification Date: Qualification Process: | | | | |



Document Number: NEE-QCM-THB-001 Quality Control Manual in accordance with CSA B620

 Prepared by / Approved by:
 Arash Navidan / Zanyar Farhadi

 Date of Issue: 2019/04/29
 Page Number: 103 of 150

21.1.22 Table 7.1 of CSA B620

20 Periodic inspection and test intervals

| (See Clauses 7.1.1, C.1, C.2, and C.6) | of CSA-B620.) |
|--|---------------|
|--|---------------|

| Description of tank | Clause 7.2.1 External inspection | Internal inspection ⁽¹⁾ | Clause 7.2.3 Lining inspection | Clause 7.2.5 Leakage test | - | Clause 7.2.11 Structural inspection |
|--|--|---|---|------------------------------|---|--|
| TC 306 or TC 406 tanks | l year | 5 years ⁽²⁾ | — | l year | 5 years ⁽³⁾ | _ |
| TC 306 Crude or TC 406 Crude tanks | 2.5 years | 5 years | | 2.5 years | 5 years ⁽³⁾ | |
| TC 307 or TC 407 tanks | l year | 5 years | _ | l year | 5 years | _ |
| TC 312 or TC 412 tanks | l year | 5 years | _ | l year | 5 years ⁽³⁾ | _ |
| TC 423 tanks | l year | l year | _ | l year | 5 years | 5 years |
| TC 350 tanks | 6 months | l year | _ | l year | 2 years | _ |
| TC 350 Crude tanks | l year | l year | — | l year | 2 years | _ |
| TC 331 tanks | l year | 5 years | — | l year ⁽⁴⁾ | 5 years ⁽⁴⁾ | _ |
| TC 338 tanks | l year | — | — | — | 5 years | _ |
| TC 341 tanks ⁽⁵⁾ | l year | 10 years | — | — | 10 years | _ |
| TC II portable tanks | l year | 10 years ⁽⁶⁾ | _ | l year | 5 years | _ |
| TC 44 portable tanks | l year | 5 years | _ | l year | 5 years | _ |
| TC 51 portable tanks ⁽⁹⁾ | 2.5 years ⁽⁷⁾ | 5 years | 5 years | _ | 5 years | _ |
| TC 56 and 57 portable tanks ⁽⁸⁾ | 2.5 years | _ | _ | _ | 2.5 years | _ |
| TC 60 portable tanks | 2 years | Initial: 4 years Next 8 years: every 2 years After 12 years: annually | Initial: 4 years Next 8 years: every 2 years After 12 years: annually | | Initial: 4 years Next 8 years: every 2 years After 12 years: annually | - |

Notes:

- (1)Where a tank, other than a TC 341 tank, is not equipped with a manhole or inspection ports, a hydrostatic or pneumatic pressure test shall be performed at the interval for internal inspections. See also Note 5.
- (2)Highway tanks used only to refuel aircraft and that operate only on airport property shall be exempt from internal inspection, provided that they are clearly marked "Restricted to Use on Airport Property" in letters not less than 25 mm (1 in) high in a contrasting colour on each side of the tank where they will be clearly visible from the ground.
- (3)For TC 306, TC 406, TC 306 Crude, TC 406 Crude, TC 312, or TC 412 tanks, the pressure tests specified in Clause 7.2.7 shall not be required for uninsulated lined tank trucks and trailers with a design pressure or MAWP of *103 kPa* (15 psi) or less, if an external inspection and a lining inspection have been performed annually.

| NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 104 of 150 |

- (4)TC 331 tanks in chlorine service shall be leak tested as specified in Clause 7.2.5 and pressure tested as specified in Clause 7.2.7 every two years. Pressure tests shall not be required on TC 331 tanks when in sodium metal service.
- (5)As an alternative to the inspection and test requirements of this Table for TC 341 tanks, owners may perform the tests and inspections described in Annex C.
- (6)The internal inspections specified in Clause 7.2.2 do not apply to TC 11 tanks that are less than 2350 L (620 US gal) and that do not have inspection openings.
- (7)The external inspection period may be extended to 3 years following a pressure test for tanks described in CSA B622, Clause 6.3, Specific Requirement 55.
- (8)TC 56 and TC 57 tanks shall be inspected and retested in accordance with Section 7 of CAN/CGSB-43.146.
- (9)A TC 51 portable tank that is loaded and off-loaded without being removed from the vehicle shall be inspected and tested according to the requirements for TC 331 tanks specified in this Table.
- (10) The pressure test period for tanks described in CSA B622, Clause 6.3, Specific Requirement 54 and Specific Requirement 55, is three years
- (11) TC 331 and TC 51 tanks shall be subjected to an internal inspection by the wet fluorescent magnetic particle method in accordance with Clause 7.2.8 when the conditions of Clause 7.2.8(a) are met.

| ent Number: NEE-QCM-THB-001 | | | | in accordance with CSA B620 | | | | |
|---|--|---|----------------------------|-----------------------------|--------------------------------|---|--|--|
| | | | | Revisi | ion Number: 04 | 4 | | |
| d by / Approve | d by: | | | Arash | Navidan / Zany | var Farhadi | | |
| [ssue: 2019/04/2 | 29 | | | Page 1 | Number: 105 o | f 150 | | |
| 7.2 of CSA 1 | <u>B620 A</u> | dditional per | | | tion and test 7.1.1 and C.6 | | | |
| Description of tank | Clause 7.2.1 External inspection | Clause 7.2.2 Internal inspection ⁽¹⁾ | Clause Lining inspec | g | Clause 7.2.5 Leakage test | Clause 7.2.7 Pressure test, hydrostatic or pneumatic | Clause 7.2.6 Thickness test ⁽⁶⁾ | Clause 7.2 Upper coupler inspection |
| All tanks designed to be loaded by vacuum, with full opening rear heads | 6 months ⁽⁵⁾ | - | | | - | 2 years | | - |
| All lined tank trucks and tank trailers in corrosive service | - | 1 year | 1 year | | - | - | - | - |
| All lined tank trucks and tank trailers not in corrosive service ⁽⁷⁾ | - | | 5 year: | 5 | - | - | - | - |
| All unlined tank trucks and tank trailers in corrosive service ⁽²⁾ | - | 1 year | | | | | 2 years ⁽⁴⁾ | ÷ |
| All insulated tank trucks and tank trailers ⁽³⁾ | ÷ | 1 year | ÷ | | - | - | - | - |
| All insulated highway and portable tanks, lined or without manholes ⁽²⁾ | - | - | - | | _ | 1 year | - | Ŧ |

| Document Number: NEE-QCM-THB-001 | | | | Quality Control Manual in accordance with CSA B620 | | | | |
|--|--|---|----------------------------|---|------------------------------|---|--|--|
| | | | | Revis | ion Number: 04 | 4 | | |
| Prepared by / Appro | Prepared by / Approved by: | | | | Navidan / Zany | var Farhadi | | |
| Date of Issue: 2019/0 | 4/29 | | | Page | Number: 106 o | f 150 | | |
| | | Т | able | 7.2 (| Conclude | d) | | |
| Description of tank | Clause 7.2.1 External inspection | Clause 7.2.2 Internal inspection ⁽¹⁾ | Clause Lining inspec | | Clause 7.2.5 Leakage test | Clause 7.2.7 Pressure test, hydrostatic or pneumatic | Clause 7.2.6 Thickness test ⁽⁶⁾ | Clause 7.2.4 Upper coupler inspection |
| All tank trailers Not in corrosive service equipped with an upper coupler | | - | | | | | - | 5 years |
| trailers in corrosive service equipped with an upper coupler | | | | | | | | |
| Notes: (1) Where to at the in (2) Except 7 (3) Except 7 (4) If the the annuall (5) Except 7 (6) The thic (7) Lined to | nterval for interr TC 338 and 341 TC 331, 338, an ickness is such t y. TC 350 crude tau ckness test does | al inspections. tanks. d 341 tanks. hat less than 20 nks. not apply to FRP sive service shall | % of the tanks. | corrosi | ion allowance re | ydrostatic or pnet emains, a thickne cted but the mark | rss test shall be j | performed |

| 7 | NATIONAL ENERGY EQUIPMENT INC. | - |
|---|-----------------------------------|---|
| | EQUIPMENT INC. | |

| Document Number: NEE-QCM-' | ГНВ-001 | Revision Number: 04 | | | |
|-----------------------------------|---|---|--|--|--|
| Prepared by / Approved by: | | Arash Navidan / Zanyar Farhadi | | | |
| Date of Issue: 2019/04/29 | | Page Number: 107 of 150 | | | |
| 21.1.23 Table 7.3 of CSA B620 | Test pressures (See Clauses 5.2.5, 5.5.2.4 | 4, 7.2.7.7, and 7.2.7.8.) | | | |
| Tank specification | <u>Pressure, kPa (psi)</u> | | | | |
| TC 306 or MC | 21 kPa (3 psi) or design | n pressure, whichever is greater | | | |
| TC 307 or MC 307 | 275 kPa (40 psi) or 1.5 | × design pressure, whichever is greater | | | |
| TC 312 or MC 312 | 21 kPa (3 psi) or 1.5 × d | design pressure, whichever is greater | | | |
| TC 331, MC 330, or MC 331 | $1.5 \times \text{design pressure}$ | | | | |
| TC 406 | 34.5 kPa (5 psi) or $1.5 \times$ MAWP, whichever is greater | | | | |
| TC 407 | 275.8 kPa (40 psi) or 1. | $5 \times MAWP$, whichever is greater | | | |
| TC 412 | $1.5 \times MAWP$ | | | | |
| TC 423 | $1.5 \times MAWP$ | | | | |
| TC 338 | According to calculation | n in Clause 5.2.5 | | | |
| TC 341 | According to calculation | n in Clause 5.5.2.4 | | | |
| TC 350 | 155 kPa (22.5 psi) or 1. | $5 \times MAWP$, whichever is greater | | | |
| TC 11 | According to calculation | n in Clause 6.4.11(c) | | | |
| TC 44 | 27 kPa (4 psi) or 1.5 × 1 | MAWP, whichever is greater | | | |
| TC 51 or DOT 51 | $1.5 \times design pressure$ | | | | |
| TC 60 or DOT 60 | 415 kPa (60 psi) | | | | |
| TC Type 1, 2, and 3 | $1.5 \times MAWP$ | | | | |
| | | | | | |
| | | | | | |

| Document Number: NEE-QCM-THB-001 | | Quality Control Manual in accordance with CSA B620 | | |
|--|---|---|--|------------------|
| | | Revision Number: 04 | | |
| repared by / Approved by: | | Arash Navidan / Zanyar Farhadi | | |
| ate of Issue: 2019/04/29 | | Page Number: 108 of 150 | | |
| | Minimum thickness manufactured with s (See Clause 7.2.6.2.) | | nd MC 306, 307, and 312 spe steel alloys. | cification tanks |
| Minimum nominal thickness required in Tables 5.2 or 5.3, 5.4 or 5.5, and 5.6 or 5.7, as applicable, for the specification, US gauge or mm (in) | Nominal decimal equivalent for refe mm (in) | rence, | In-service minimum thickness, mm (in) | |
| 19 | 1.06 (0.0418) | | 0.97 (0.038) | |
| 18 | 1.21 (0.0478) | | 1.09 (0.043) | |
| 17 | 1.37 (0.0538) | | 1.22 (0.048) | |
| 16 | 1.52 (0.0598) | | 1.37 (0.054) | |
| 15 | 1.71 (0.0673) | | 1.55 (0.061) | |
| 14 | 1.90 (0.0747) | | 1.70 (0.067) | |
| 13 | 2.28 (0.0897) | | 2.06 (0.081) | |
| 12 | 2.66 (0.1046) | | 2.39 (0.094) | |
| 11 | 3.04 (0.1196) | | 2.74 (0.108) | |
| 10 | 3.42 (0.1345) | | 3.07 (0.121) | |
| 9 | 3.80 (0.1495) | | 3.43 (0.135) | |
| 8 | 4.18 (0.1644) | | 3.76 (0.148) | |
| 7 | 4.55 (0.1793) | | 4.09 (0.161) | |
| 4.76 (3/16) | 4.76 (0.1875) | | 4.29 (0.169) | |
| 6.35 (1/4) | 6.35 (0.2500) | | 5.72 (0.225) | |
| 7.94 (5/16) | 7.94 (0.3125) | | 7.14 (0.281) | |
| 9.53 (3/8) | 9.53 (0.3750) | | 8.59 (0.338) | |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|---|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 109 of 150 |
| | s for TC and MC 306, 307, and 312 specification tanks |
| (See Clause 7.2.6.2.) | aluminum and aluminum alloys. |
| Minimum nominal thickness required in Tables 5.2 or 5.3, 5.4 or 5.5, and 5.6 or 5.7, as applicable, for the specification, US gauge or mm (in) | In-service minimum thickness, mm (in) |
| 1.98 (0.078) | 1.78 (0.070) |
| 2.21 (0.087) | 1.98 (0.078) |
| 2.44 (0.096) | 2.18 (0.086) |
| 2.77 (0.109) | 2.49 (0.098) |
| 3.30 (0.130) | 2.97 (0.117) |
| 3.58 (0.141) | 3.23 (0.127) |
| 3.84 (0.151) | 3.54 (0.136) |
| 4.37 (0.172) | 3.94 (0.155) |
| 4.39 (0.173) | 3.96 (0.156) |
| 4.93 (0.194) | 4.45 (0.175) |
| 5.49 (0.216) | 4.93 (0.194) |
| 6.02 (0.237) | 5.41 (0.213) |
| 6.86 (0.270) | 6.17 (0.243) |
| 9.14 (0.360) | 8.23 (0.324) |
|).14 (0.300) | 0.25 (0.521) |
| 11.43 (0.450) | 10.29 (0.405) |

Document Number: NEE-QCM-THB-001Revision Number: 04Prepared by / Approved by:Arash Navidan / Zanyar FarhadiDate of Issue: 2019/04/29Page Number: 110 of 15021.1.26NA

| orm Number:NE | E-FR-L-102-(RE | EV3) Page | e1of1 | Revision: 3 | | | |
|--|--|--|--|--|--|--|------------|
| | | | | | | | |
| Date of Issue: Time Of Entry: | | | | Of Issue: pated Time Out | | | |
| Entrant. | | | | et Last Containe | | | |
| Standby Person. | | | Entry | Supervisor: | | | 1 |
| Type of Work Type of Work N | Hot Work | Cold Work | Wel | ding 🗌 Repa | irs 🗍 Inspec | ntion/Cleaning | |
| Lock Lock C.S. C.S. | | 'ollowed S/SDS Reviewed MSDS/SDS Sheets ned Space ards locked on Required or to Entry | | Safety Hamo Fire Fighting Liquid Press Electrical To GFI & Seale Hearing Pro Face Shield | ools Grounded od Extension Co tection Require Glasses Requir tion Required R clothing | i Hand Type ords đ ed | |
| 02% 20.9% | ilation Required | During Entry TS OF ATMOSF Acceptable Atmo 0% CO < 5 | ospheric/ 5 ppm | Workers Aw /EXPLOSIM Explosimeter F | Extraction Kit vare of Condition ETER TEST Readings Oppm TV | ons ING 70C 0 ppm or | background |
| O2% 20.9% Instrument # | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSF Acceptable Atmo 0% CO < 5 n Date: Dail | ospheric/ 5 ppm y Bump 7 | Workers Aw /EXPLOSIMI Explosimeter R H ₂ S (Test Completed) | Extraction Kit vare of Conditio ETER TEST Readings Oppm TV By | ons ING 7OC 0 ppm or similar to | background |
| 02% 20.9% | ilation Required RESUL LEL | During Entry TS OF ATMOSF Acceptable Atmo 0% CO < 5 n Date: Dail | ospheric/ 5 ppm | Workers Aw /EXPLOSIM Explosimeter R Fl2S (| Extraction Kit vare of Condition ETER TEST Readings Oppm TV | ons ING 70C 0 ppm or | background |
| □ □ □ Vent O2% 20.9% Instrument #: | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSF Acceptable Atmo 0% CO < 5 n Date: Dail | ospheric/ 5 ppm y Bump 7 | Workers Aw /EXPLOSIMI Explosimeter R H ₂ S (Test Completed) | Extraction Kit vare of Conditio ETER TEST Readings Oppm TV By | ons ING 7OC 0 ppm or similar to | background |
| □ □ □ Vent O2% 20.9% Instrument #: | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSF Acceptable Atmo 0% CO < 5 n Date: Dail | ospheric/ 5 ppm y Bump 7 | Workers Aw /EXPLOSIMI Explosimeter R H ₂ S (Test Completed) | Extraction Kit vare of Conditio ETER TEST Readings Oppm TV By | ons ING 7OC 0 ppm or similar to | background |
| O2% 20.9% Instrument # | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSF Acceptable Atmo 0% CO < 5 n Date: Dail | ospheric/ 5 ppm y Bump 7 | Workers Aw /EXPLOSIMI Explosimeter R H ₂ S (Test Completed) | Extraction Kit vare of Conditio ETER TEST Readings Oppm TV By | ons ING 7OC 0 ppm or similar to | background |
| O2% 20.9% Instrument # | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSE Acceptable Atm 0% CO < 5 n Date: Dail CO | ospheric/ 5 ppm y Bump 7 H ₂ S | Workers Aw /EXPLOSIME Explosimeter R H2S (Test Completed) | Extraction Kit vare of Condition ETER TEST Readings D ppm TV By Date/Time | ons ING 7OC 0 ppm or similar to | background |
| O2% 20.9% Instrument # Oxygen % | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSE Acceptable Atm 0% CO < 5 n Date: Dail CO | ospheric/ 5 ppm y Bump 7 H ₂ S SAFETY | Workers Aw | Extraction Kit vare of Condition ETER TEST Readings D ppm TV By Date/Time | ons ING 7OC 0 ppm or similar to | background |
| O2% 20.9% Instrument # Oxygen % | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSE Acceptable Atm 0% CO < 5 n Date: Dail CO | ospheric/ 5 ppm y Bump 7 H ₂ S SAFETY | Workers Aw | Extraction Kit vare of Condition ETER TEST Readings D ppm TV By Date/Time | ons ING 7OC 0 ppm or similar to | background |
| O2% 20.9% Instrument # Oxygen % | ilation Required RESUL LEL Calibratio | During Entry TS OF ATMOSE Acceptable Atm 0% CO < 5 n Date: Dail CO | ospheric/ 5 ppm y Bump 7 H ₂ S SAFETY | Workers Aw | Extraction Kit vare of Condition ETER TEST Readings D ppm TV By Date/Time | ons ING 7OC 0 ppm or similar to | background |

| | ATIONAL ENERGY DUIPMENT INC. | Quality Control M in accordance with C | |
|----------------|---------------------------------|--|---------------|
| Document Nu | mber: NEE-QCM-THB-001 | Revision Number: 04 | |
| Prepared by / | Approved by: | Arash Navidan / Zanyar Farhadi | |
| Date of Issue: | 2019/04/29 | Page Number: 111 of 150 | |
| 21.1.27 | NA | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | Confined S | pace Entry Program | |
| | | s/ 8 | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | n | |
| | MER MATECHIAL CHIE | Decument Number: NEE-CSEP-MB-001 | |
| | REQUIPMENT IN | Prepared by: Arush Na Approved by: Zanyar I | |
| | | Date of Issue; 2017/06/20 Rev. No.: 3 | Sheet: 1 of 7 |
| | 1 | | |

Z EQUIPMENT INC.

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Prepared by / Approved by:

Date of Issue: 2019/04/29

Arash Navidan / Zanyar Farhadi Page Number: 112 of 150

| Hem No. | Sul | bject | | Page No |
|---------|--|--------------------------------------|--------------------------|---------|
| 1 | Scope | | | 3 |
| 2 | Definitions and Glossary of Abbreviations | | 3 | |
| 3 | Résponsi bili ti es | | | 4. |
| 4 | Procedures | | | 972 |
| 4+1 | Confined Space Entry Program | | | i. |
| 4-2 | Confined Space Entry, Rescue and Ventil | ation Procedure | | ġ. |
| 4-3 | Confined Space Hazard Assessment | | | 5 |
| | Records | | | 6 |
| 5 | Training Requirements | | | 6 |
| | Appendices | | | |
| А | Confined Space Entry and Rescue Procee highway tanks | lure for the inspect | ion of propane delivery | - |
| В | Confined Space Entry and Rescue Proceed highway tanks | ure for the inspectio | m of petroleum delivery | - |
| С | Confined Space Entry and Rescue Proc petroleum delivery highway tanks | edure for repairs | including hot work of | - |
| D | Confined Space Entry and Rescue Procee highway tanks | lure for the inspecti | on of chemical delivery | |
| E | Confined Space Hazard assessment for tanks | he inspection of pro | opane delivery highway | ~ |
| F | Confined Space Hazard assessment for th tanks | e inspection of petr | oleum delivery highway | - |
| G | Confined Space Hazard assessment for delivery highway tanks | repairs including 1 | not work of petroleum | - |
| Н | Confined Space Hazard assessment for th tanks | ue inspection of che | mical delivery highway | - |
| | | Dummer March | MR-001 | |
| | | Dumment Number: CSEP Prepared by: | -MB-001 Arash Bavidan | |
| | | Approved by: | Zanyar Farhaili | |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2019/04/29

Page Number: 113 of 150

| | Confined Space Entry Program |
|--|--|
| Document Number: NEE-CSEP-MB-001 | Date of Issue: 2017/06/30 |
| Prepared by: Arash Navidan | Revision Number: 3 |
| Approved by: Zanyar Farhadi | Sheet Number: 3 of 7 |
| SECTION - 1 Scope | |
| This program governs the entry into Confined Space facilities. It shall be followed by all NEEI employee mentioned NEEI property. | |
| This program is meant to satisfy the requirements o Regulation (OHSR), and all provincial legislation re | f the Work Safe BC, Occupational Health & Safety elated to Confined Space Entry. |
| SECTION - 2 Definitions and Glos | sarv of Abbreviations |
| | ine, duct or conduit which is connected to a confined from within the device to enter the confined space; |
| <i>"blank"</i> means a solid plate installed through the connection; | ross-section of a pipe, usually at a flanged |
| "blanking or blinding" means the absolute closure solid plate or cap that completely covers the b maximum pressure of the adjacent piping; | |
| "blind" means a solid plate installed at the end of a disconnected from a piping system; | pipe which has at that point been physically |
| "clean respirable air" when used to describe the at atmosphere which is equivalent to clean, outdo | |
| (a) about 20.9% oxygen by volume, | |
| (b) no measurable flammable gas or vapour as dete instrument, and | ermined using a combustible gas nieasuring |
| (c) no air contaminant in concentrations exceeding section 4.6, or an acceptable ambient air qualit jurisdiction over environmental air standards, | ty standard established by an authority having |
| "confined space" means an area, other than an und | erground working, that |
| (a) is enclosed or partially enclosed, | |
| (b) is not designed or intended for continuous hum | an occupancy, |
| (c) has limited or restricted means for entry or exit evacuation, rescue or other emergency respons | |
| | |

Z EQUIPMENT INC.

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2019/04/29

Page Number: 114 of 150

| Document Number; NEE-CSEP-MB-001 | Date of Issue; 2017/06/30 |
|---|---|
| Prepared by: Arash Navidan | Revision Number; 3 |
| Approved by: Zanyar Earhadi | Sheet Number: 4 of 7 |
| "disconnecting" means physically disconnecting ac contents from entering the space in the event o | |
| <i>"double block and bleed"</i> means the closure of adja open position in the line between 2 locked out | |
| <i>"harmful substance"</i> means a WHMIS hazardous p a substance which may have a harmful effect o | roduct, a substance referred to under section 4.6, or on a worker in a confined space. |
| <i>"high hazard atmosphere"</i> means an atmosphere th incapacitation, injury, acute illness or otherwis from a confined space, in the event of a failure | e impair the ability of the worker to escape unaided |
| | here inside a confined space with an inert gas such of flammable vapours inside the confined space but re; |
| known to contain clean respirable air immedia not likely to change during the work activity, a consideration of the design, construction and u performed, and all engineering controls require | ce which is shown by pre-entry testing or otherwise tely prior to entry to a confined space and which is as determined by a qualified person after use of the confined space, the work activities to be ed. For example, all brand new B620 tanks and |
| water tanks. | |
| "moderate hazard confined space" means a confine | ed space that is not clean respirable air but is not ape unaided from a confined space, in the event of a |
| <i>"moderate hazard confined space"</i> means a confine likely to impair the ability of the worker to esc | |
| "moderate hazard confined space" means a confine likely to impair the ability of the worker to esc failure of the ventilation system or respirator. | ape unaided from a confined space, in the event of a |
| "moderate hazard confined space" means a confine likely to impair the ability of the worker to esc failure of the ventilation system or respirator. SECTION - 3 Responsibilities | ape unaided from a confined space, in the event of a |
| "moderate hazard confined space" means a confine likely to impair the ability of the worker to esc failure of the ventilation system or respirator. SECTION - 3 Responsibilities The people who are involved in the process of confi | ape unaided from a confined space, in the event of a |
| "moderate hazard confined space" means a confine likely to impair the ability of the worker to esc failure of the ventilation system or respirator. SECTION - 3 Responsibilities The people who are involved in the process of confi - Entry Supervisor | ape unaided from a confined space, in the event of a |

Quality Control Manual in accordance with CSA B620

| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
|----------------------------|--------------------------------|
| Date of Issue: 2019/04/29 | Page Number: 115 of 150 |

Revision Number: 04

Document Number: NEE-CSEP-MB-001 Date of Issue; 2017/06/30

Prepared by: Arash Navidan Revision
Approved by: Zanyar Farhadi Sheet Nu

SECTION-4 Procedures

4.1 Confined Space Entry Program

This program provides:

- A method for identifying each confined space at NEEI projects and facilities.
- A review of every confined space to determine the Hazard ratings of each related confined space.
- A method for identifying and evaluating the hazards to which workers may be exposed in confined spaces before allowing entry.
- The development of confined space entry procedures.
- · General and plan-specific training of workers.
- The duties of the various workplace parties in the confined space program.
- A hazards assessment that sets out measures, procedures and practices to be followed for safe entry operations when work is to be performed in a confined space.
- Monitoring to test the confined space atmosphere for hazards, such as Oxygen. Combustible gases/vapours, Toxic gases/vapours, total volatile organic compounds (TVOC).
- · The means for ensuring unprotected workers are not exposed to hazardous atmospheres.
- · A rescue plan and rescue procedures in place before entry into a Confined Space occurs.
- · An accountability system, such as a log of authorized entrants into a Confined Space.

4.2 Confined Space Entry, Rescue and Ventilation Procedure

A confined space entry permit must be completed prior to entry. A confined space warning sign must be posted at the entrance to the space. Entry, Rescue and Ventilation procedures of the delivery highway tanks are conducted by the mentioned persons in the section 3 of this document for the following purposes:

- Confined Space Procedure- Propane tanks inspection and grinding only. (NEE-CSP-NA-001)
- Confined Space Procedure Petroleum tanks inspection only. (NEE-CSP-NA-002)
- Confined Space Procedure Petroleum tanks repairs including hot work. (NEE-CSP-NA-003)
- Confined Space Procedure Chemical tanks inspection only. (NEE-CSP-NA-004)

4.3 Confined Space Hazard Assessment

The confined space hazards assessments for the aforementioned confined space entry and rescue procedures are prepared and reported as following Confined space hazard assessment (CSHA) locuments:

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
|----------------------------|--------------------------------|
| | |

Date of Issue: 2019/04/29

Page Number: 116 of 150

Revision Number: 04

| | Confined Space Entry Program |
|----------------------------------|------------------------------|
| Document Number; NEE-CSEP-MB-001 | Date of Issue; 2017/06/30 |
| Prepared by: Arash Navidan | Revision Number; 3 |
| Approved by: Zanyar Farhadi | Sheet Number: 6 of 7 |

- Confined Space Hazards Assessment Propane tanks inspection and grinding only (NEE-CSHA-NA-001)
- Confined Space Hazards Assessment Petroleum tanks inspection only (NEE- CSHA- NA-002)
- Confined Space Hazards Assessment Petroleum tanks repairs including hot work (NEE-CSHA-NA-003)
- Confined Space Hazards Assessment Chemical tanks inspection only (NEE- CSHA- NA-004)

4.4 Records

A copy of the signed confined space entry permits, and any other related information will be kept on file at the NEEI facility for a period of no less than three years after completion of the project if no incident or unplanned event occurred during the entry. For any instance where an incident or unplanned event occurred during entry, a record of the permit, test results, and any related information will be kept on file and available for inspection for a period of no less than five years after completion of the project.

SECTION-5 Training Requirements

Prior to permitting workers to work in or around confined spaces, the employer shall ensure that workers are trained in the requirements outlined within in this program.

Training shall be given by a qualified individual or agency.

When there is reason to believe that any worker who has been previously trained does not have the understanding or skill required by this procedure, the employer shall consider re-training.

Every contractor or 3rd party worker having the potential to work in confined spaces shall be made aware of the requirements of the program through initial orientation training and periodic reviews during weekly safety meetings, through the use of bulletins and other communication strategies, etc.

Training certificates will be kept and updated as required.

List of trainings are as follows:

- Safety trainings including:
 - WHMIS 2015 or the most current version.
 - o Confined Spaces,
 - e LOTO,
 - Transport of Dangerous Goods,
 - o FALL ARREST,

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Prepared by / Approved by:

Date of Issue: 2019/04/29

Page Number: 117 of 150

Arash Navidan / Zanyar Farhadi

| ZEQUIPMENT INC | Confined Space Entry Program |
|----------------------------------|------------------------------|
| Document Number: NEE-CSEP-MB-001 | Date of Issue: 2017/06/30 |
| Prepared by: Arash Navidan | Revision Number: 3 |
| Approved by: Zanyar Farhadi | Sheet Number: 7 of 7 |

- o POST Certified,
- o First Aid.
- Confined space entry program (this document) training.
- Gas monitor instructions
- B620 Quality manual training.
- Respiratory protection training.
- Respirator fit testing.
- Equipment manufacturing training



Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Prepared by / Approved by:

Date of Issue: 2019/04/29

Page Number: 118 of 150

Arash Navidan / Zanyar Farhadi

Revision Number: 04

21.1.28

Required information on the Identification Plate checklist

The following information shall appear on the plate(s) (parenthetical abbreviations are authorized):

Note: *This information may be provided and marked in accordance with the ASME* Code.

(a) tank manufacturer (Tank mfr.);

(b) date of tank manufacture — month and year (Date of mfr.);

(c) assembler;

(d) completion and certification date — month and year (Cert. date);

(e) original test date — month and year (Orig. Test Date);

(f) TC Specification (TC Spec.);

(g) Transport Canada Registration Number (TCRN);(1)

(h) Manufacturer's Design Identification Number (MDIN);(2)

(i) tank serial number (Ser. No. or S/N);

(j) vehicle identification number (VIN);

(k) tank maximum allowable working pressure in kPa (MAWP);

(l) tank test pressure in kPa (Test P);

(m) tank design temperature range — ___oC to ___oC (Design temp. range);

(n) maximum design density of lading — in kilograms per litre (Max. lading density);

(o) vessel material specification number(3) — all numbers to be marked where the material for the shell is

different from the material for the heads (Shell & Head Matl. yyy zzz or Shell Matl. yyy zzz and Head Matl. yyy zzz, where "yyy" is replaced by the alloy designation and "zzz" by the alloy type);

(p) weld material (Weld Matl.);(3)

(q) minimum allowable thickness of shell — in millimetres (Min. shell thick.). When minimum shell

thicknesses are not the same for different areas, mark variances (Top Side...... Bottom......);

(r) minimum allowable thickness of heads — in millimetres (Min. head thick.);

(s) manufactured thickness of shell — in millimetres (Mfd. shell thick.);(4)

(t) manufactured thickness of heads — in millimetres (Mfd. head thick.);(4)

(u) exposed surface area — in square metres;

(v) volumetric capacity — in litres (Cap. Litres);

(w) maximum product load — in kilograms (Max. payload);

(x) maximum loading rate — in litres per minute and optionally in US gallons per minute [Max load. rate, L/min (US GPM) at maximum loading pressure XX kPa (psi)];(5)

(y) maximum unloading rate — in litres per minute and optionally in US gallons per minute [Max. unload. rate, L/min (US GPM) at maximum unloading pressure XX kPa (psi)];(5)

Annotations:

(1)Required for all tanks including: (a) TC 331; (b) TC 407 with a MAWP greater than 240 kPa (35 psi) or designed to be loaded by vacuum,

(2)Required for all tanks other than those outlined in above.

(3)For FRP tanks, "NA" shall be marked.

(4)Required when additional material is provided for corrosion allowance

(5)Does not apply to TC 331 highway tanks.

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 119 of 150 |
| | |

21.1.29 NA

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 120 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 121 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 122 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 123 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 124 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 125 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 126 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 127 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 128 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 129 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 130 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 131 of 150 |



Quality Control Manual in accordance with CSA B620

| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
|----------------------------------|--------------------------------|
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 132 of 150 |

21.1.30 Testing in-service cargo tank manway covers procedure

21.1.30.1 Purpose

The purpose of this test procedure is to qualify, by means of a pressure test, the structural integrity of in-service manways and fill openings.

21.1.30.2 Qualifying Test

- In-service manways and/or fill opening covers not marked as certified by the manufacturer shall be tested using the equipment described in 21.1.30.3 and the procedure described in 21.1.30.4.
- Manway and/or fill opening covers successfully meeting this test per 21.1.30.5 and prior to reinstallation on the cargo tank may be permanently marked by stamping or other means. The name of the tester and date of the test should be recorded and retained.
- Any device, such as a pressure relief valve, which becomes a part of the manway cover assembly, shall be evaluated separately for compliance.

21.1.30.3 Test Equipment (See Figure 1)

- The test fixture for the test consists of 16" diameter, 20" diameter, or 12"x 16" elliptical collars with a suitable material welded to the bottom. The test fixture collar shall be the same size, thickness, and material as that collar on the tank to which the manway cover assembly is to be installed.
- Gauges:

One (1) applicable pressure gauge, which should be more than the required tank's test pressure regarding table 7.3 of CSA B620 (see section 21.1.23) for leakage test of other tanks.

- Pipe fittings:

One (1) ¹/₂" NPT globe valve

One (1) ¹/₂" ball valve

One (1) ¹/₂" cross

Five (5) ¹/₂" pipe nipples

- Rubber membranes of 1/8" thickness to fit outside diameter of manway collar.
- Steel plate with guides to block fill opening only if fill opening cover acts as a pressure relief valve. Please note that some old manway covers have fill covers that do not provide pressure relief and those fill covers should not be blocked closed.
- Vent plugs, flanges, or other devices to block holes in manway cover.

| NATIONAL ENERGY |
|-----------------|
| EQUIPMENT INC. |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Prepared by / Approved by:

Date of Issue: 2019/04/29


Page Number: 133 of 150

- Manway gaskets One (1) for each size manway assembly to be tested.
- Gasket for the 10-inch diameter pressure relief valves.
- 21.1.30.4 Manway Cover Test Procedures
 - 21.1.30.4.1 Remove manhole cover assembly and clamping ring assembly to be tested from the cargo tank.

Revision Number: 04

Arash Navidan / Zanyar Farhadi

- 21.1.30.4.2 Remove any normal pressure/Vacuum vents, sensors, high capacity vents or any other appurtenance that protrudes below the manhole cover.
- 21.1.30.4.3 Block the openings in the manhole cover with the devices listed in 21.1.30.3.
- 21.1.30.4.4 Fill test fixture base with air or water.
- 21.1.30.4.5 Lay rubber membrane on test base.
- 21.1.30.4.6 Open 10" diameter pressure relief valve. Install steel plate with guides to underside of 10" diameter opening. Use vice grips to hold this plate in position while placing manhole cover assembly on rubber membrane.
- 21.1.30.4.7 Install 1 0-30 psig gauge in test base.
- 21.1.30.4.8 Attach manhole cover assembly with its clamping ring assembly to the test fixture. While tightening clamping ring bolt, tap the ring at various points to ensure equal clamping.
- 21.1.30.4.9 Slowly increase pressure in tank to the proper test pressure for that tank type, indicated in the Table 7.3 of CSA B620 (see section 21.1.23) for a period of at least 5 minutes: CAUTION: WATCH PRESSURE. DO NOT OVER-PRESSURIZE.
- 21.1.30.5 Inspection
- 21.1.30.5.1 Any leakage will be considered a failure of this cover and others of its type and condition.
- 21.1.30.5.2 If the cover does not pass this test in its original condition, but the manhole cover assembly manufacturer has components available that will enable the cover to pass the test, covers using such components are considered satisfactory.
- 21.1.30.5.3 Before reinstalling the manhole cover to the cargo tank, the collar and gasket shall be inspected. If damage, distortion, corroded areas or other conditions exist that could impair its product retention capability, the collar and/or gasket shall be replaced.



| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 135 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 136 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 137 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 138 of 150 |

NATIONAL ENERGY

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Prepared by / Approved by:

Arash Navidan / Zanyar Farhadi

Page Number: 139 of 150

Date of Issue: 2019/04/29

21.2 Equipment, signs and decals

Equipment:

Test Gauge Calibration Devices:

- 15# Gauge
- 300# Gauge -
- Air Pressure Regulator
- Hose Testing Test Tee







10" Fill Test Fixture


16" and 20" Manway Bench Test Fixture

12"x16" Elliptical Manhole Bench Test Adapter r

Hydrostatic Test Pump

0-5 PSI Manometer



















| NATIONAL ENERGY |
|-----------------------------------|
| NATIONAL ENERGY EQUIPMENT INC. |

Quality Control Manual in accordance with CSA B620

| / | |
|----------------------------------|--------------------------------|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 140 of 150 |

Air Compressor



Multigas Detector



Tank Under Pressure Signs



Test and Inspection Decals



Calibration Decal

| CALIBRATION | |
|-------------|--|
| Date: | |
| Technician: | |
| Due: | |

| Z EQUIPMENT INC. | in accordance with CSA B620 | | | |
|---|--------------------------------|--|--|--|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 | | | |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi | | | |
| Date of Issue: 2019/04/29 | Page Number: 141 of 150 | | | |

2

21.3 Samples of actual completed documents

The following documents are SAMPLES only. Latest quality control manual must be followed to complete the forms. Please refer to facilities' completed records for more samples.

| | nal Energy Ec | quipment In | IC | | TEST | DAT | E: 1 XX | XXXXX, | |
|--|--|--|---|-------------|---|-------------|---------------|--|--------------------|
| ΛΛΛΛΛ | XX, | | | | | | - | | vvv |
| Telephone XXXX | | | | | Facility | y Re | gistration No | o, : XX-2 | |
| Tank Ow Address: John Doe XXXXXXX | XXX, XXXX | | | _ | Owner | rs Sig | gnature | | |
| Telephon 111111 | | | | | Date: | _ | | | |
| OWNERS UNIT N : X MANUFACTUREI XX | | - | SERIA | . No | : XX | | XX-XXX | 5 | |
| MFG DATE: 11/89 | | MATERIAL | .: 5454 | _ | | TAI | NK SPEC: | TC 306 | |
| MC/TC331 & TC51 | QT 🗆 | | NQT [|] | | PV | ИНТ 🔲 | | |
| COMP. CAPACITY 1 4 | 2000 L 4500 L | IG/L 2 IG/L 5 | 3600 L 2400 L | IG IG | /L 3 | 5500 | L IG/ | | |
| TESTS PERFORMED | "V" | × "!" | ⊠ "K" | \boxtimes | "P" | \boxtimes | "Т" | "U/C" | |
| EXTERNAL VISUAL IN | SPECTION ' | | | | QC Ma Ref. | | Complies | Reject | Retest Complie |
| Data plate, present and le Shell & Heads, corrosion Structural members, outri- Piping and valves for leak Remote closures, thermal Hoses for defects, identifi- Tank attachments to fram Ladders, walkways etc Fill covers, manways and Relief valves and vents (r ading corrosive to relief d Accident damage protecti Inspector- Tom T | abrasion dents ggers, crossme age, damage, devices cation and test e or running ge closure device eplace or test i levice) | embers etc corrosion dates ear | vice where | c 2 | 8.1.3 8.1.4 8.1.5 8.1.7 8.1.7 8.1.8 8.1.9 8.1.10 8.1.11 8.1.12 8.1.13 | | | □ □ □ □ □ □ □ □ □ □ □ □ □ □ | |
| INTERNAL VISUAL IN | | | | | 00.00- | | O a man lla a | Delest | Detect |
| Interior surface, corrosion Interior welds for defects, Internal supports and atta Internal valves, piping and | cracking etc chments | rlay patches | | ° 9 | QC Ma Ref. 8.2.2 8.2.3 8.2.4 8.2.4 | | Complies | Reject | Retest Complies |
| Inspector- Tom T | | Signa | ture | - | ~ | - | Date- | Nov 30 20 | 15 |
| Note: Rejection Criteria | for Visual Ins | pections | - | | | | | | |
| Any of the follow | ving conditions | shall cause | the tank to b | e reje | cted | | | | |
| Less than minin Any dent with a Any dent with a Any weld defect Any structural d Any repairs mad | depth greater f depth greater f including a cra efect or any so de using overla | than ½" whe than 10% of ack, pinhole, urce of leaka | re it includes the length of or incomple age | a well | d ent | weld | | | |

| | TIONA JIPME | | ERGY IC. | - | • | | Manual CSA B62 |
|--|--------------------------------------|---|---|--|------------------|-------------|-------------------|
| ocument Numbe | er: NEE-QCM | A-THB-001 | | Revision Number: 0 | 4 | | |
| repared by / App | proved by: | | | Arash Navidan / Zany | yar Farhad | li | |
| ate of Issue: 2019 | 9/04/29 | | | Page Number: 142 c | of 150 | | |
| Te | st and Insp | ection Rep | oort in Accorda | nce with CSA B620 | | Pag | ge 2 of 3 |
| UP | PER COUPLE | R INSPECTI | ON "U/C" (QC Man | ual Reference 8.1.5 and 8. | 1.6) Complies | Reject | Retest |
| ı | Jpper coupler re | emoved from ta | ank and inspected (inc | cluding tank areas above) | | | Complies |
| ı | Jpper coupler in | spected in pla | се | | | | |
| Inst | pector- | | Signature | | Date- | | - |
| | AKAGE TEST | "K" (QC M | Manual Reference 8 | .3) | | | |
| TE | ST PRESSUR | E _ 2.4 PSI | (80% of M/ | AWP MIN) TEST MEDIUM | AIR | | |
| | Item Tester | d Pass | Fail Retest | Item Tested | Pass | Fail | Retest |
| (| Compartment N | 0.1 🛛 | Complies | Compartment No. 1 piping | | | Complies |
| (| Compartment N | o. 2 🗌 | | Compartment No. 2 piping | | | |
| | Compartment No Compartment No | the second se | | Compartment No. 3 piping Compartment No. 4 piping | | | |
| | Compartment No | | | Compartment No. 5 piping | | H | |
| (| Compartment N | | | Compartment No. 6 piping | | | |
| | | | | () () | • | | |
| Tar | nk Tester- Tom | Т | Signature | | | Nov 30 20 | 15 |
| | | | Signature Nanual Reference 8 | shal | | Nov 30 20 | 15 |
| THI Thi | ICKNESS TES ckness Tester | ST "T" (QC N | Anual Reference 8 accordance with in | .5) structions provided by the | _ Date- | | |
| тн | ICKNESS TES ckness Tester | ST "T" (QC N | ا accordance with in م | .5) | _ Date- | | esting |
| THI Thi | ICKNESS TES ckness Tester | ST "T" (QC M Calibrated in | ا accordance with in م | .5) Instructions provided by the VES D NC | _ Date- | er of the t | esting |
| THI Thi dev | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | 5) Istructions provided by the VES D NC | _ Date- | er of the t | esting |
| THI Thi dev | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | 5) Istructions provided by the VES I NC 00 HEAD 1 | _ Date- | er of the t | esting |
| THI Thi dev | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | 5) Istructions provided by the VES D NC | _ Date- | er of the t | esting |
| THI Thi dev | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | .5) Istructions provided by the VES NC | _ Date- | er of the t | esting |
| THI Thi dev 1 2 3 4 5 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | .5) Instructions provided by the VES NC NC NC NC NC | _ Date- | er of the t | esting |
| THI Thi dev 1 2 3 4 5 6 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | .5) Instructions provided by the VES NC NC NC NC NC NC NC NC NC NC | _ Date- | er of the t | esting |
| THI Thi dev 1 2 3 4 5 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | .5) Instructions provided by the VES NC NC NC NC NC | _ Date- | er of the t | esting |
| THI Thi dev 1 2 3 4 5 6 7 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | .5) Instructions provided by the VES D NC HEAD 1 2 3 4 5 6 7 | _ Date- | er of the t | esting |
| THI Thi dev 1 2 3 4 5 6 7 8 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | .5) Istructions provided by the VES NC NC 00 HEAD 1 2 3 4 5 6 7 8 | _ Date- | er of the t | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT | Anual Reference 8 a accordance with in ץ | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 | Manual Reference 8 accordance with in f 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester /ice | ST "T" (QC M Calibrated in FRONT 3:00 3:00 | Anual Reference 8 accordance with in f 6:00 9: 6:00 6:00 9: 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 | Anual Reference 8 accordance with in f 6:00 9: 6:00 6:00 9: 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 3:00 | Anual Reference 8 accordance with in f 6:00 9: 6:00 6:00 9: 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 3:00 | Anual Reference 8 accordance with in f 6:00 9: 6:00 6:00 9: 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 3:00 | Anual Reference 8 accordance with in f 6:00 9: 6:00 6:00 9: 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 3:00 | Anual Reference 8 accordance with in f 6:00 9: 6:00 6:00 9: 6:00 9: | 5) istructions provided by the VES NC 00 HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD | _ Date- | FRONT | esting HEAD |
| THI Thi dev 1 2 3 4 5 6 7 8 9 10 11 | ICKNESS TES ckness Tester rice | ST "T" (QC M Calibrated in FRONT 3:00 3:00 | Anual Reference 8 accordance with in | 5) structions provided by the VES NO NO NO NO NO NO NO NO NO NO | _ Date- | REAR H | esting HEAD |

| cument Number: NEE-QCM-THB-001 Revision Number: 04 epared by / Approved by: Arash Navidan / Zanyar Farhadi te of Issue: 2019/04/29 Page Number: 143 of 150 Test and Inspection Report in Accordance with CSA B620 Page 3 of 3 PRESSURE TEST "P" (QC Manual Reference 8.4) Test Pressure (Tank) 3 PSI (Refer to Table 7.3 of CSA B620-2003 for appropriate test pressure) Test Medium AIR Item Tested Pass Fail Retest Compartment No. 1 Compartment No. 2 Description Compartment No. 3 piping Description Description of defects found and methods used to repair Hose out of date, retested good Replace lids for out of spec Weld cracks on left reaf rame over rear ends Description of spec |
|---|
| te of Issue: 2019/04/29 Page Number: 143 of 150 Test and Inspection Report in Accordance with CSA B620 Page 3 of 3 PRESSURE TEST "P" (QC Manual Reference 8.4) Test Pressure (Tank) 3 PSI (Refer to Table 7.3 of CSA B620-2003 for appropriate test pressure) Test Pressure (Piping) 2.4 PSI (80% Tank Test) Test Medium AIR Item Tested Pass Fail Retest Item Tested Pass Fail Retest Complies Compartment No. 1 Compartment No. 2 piping Compartment No. 3 Compartment No. 3 piping Compartment No. 3 Description of defects found and methods used to repair Tank Tester- Tom T Signature Date- Nov 30 2015 Description of defects found and methods used to repair Hose out of date, retested good Replace Vents in all lids Replace lids for out of spec |
| Test and Inspection Report in Accordance with CSA B620 Page 3 of 3 PRESSURE TEST "P" (QC Manual Reference 8.4) Test Pressure (Tank) 3 PSI (Refer to Table 7.3 of CSA B620-2003 for appropriate test pressure) Test Pressure (Piping) 2.4 PSI (80% Tank Test) Test Medium AIR Item Tested Pass Fail Retest Item Tested Pass Fail Retest Compartment No. 1 Compartment No. 1 piping Compartment No. 2 piping Image 1 Image 2 Compartment No. 2 Compartment No. 3 piping Image 2 Image 2 Image 2 Tank Tester- Tom T Signature Date- Nov 30 2015 Image 2 Description of defects found and methods used to repair Image 2 Image 2 Image 2 Hose out of date, retested good Replace vents in all lids Replace lids for out of spec Image 2 Image 2 |
| PRESSURE TEST "P" (QC Manual Reference 8.4) Test Pressure (Tank) 3 PSI (Refer to Table 7.3 of CSA B620-2003 for appropriate test pressure) Test Pressure (Piping) 2.4 PSI (80% Tank Test) Test Medium AIR Item Tested Pass Fail Retest Complies Compartment No. 1 Compartment No. 1 piping Compartment No. 2 Compartment No. 2 piping Compartment No. 3 Compartment No. 3 piping Compartment No. 4 Compartment No. 5 piping Tank Tester- Tom T Signature Description of defects found and methods used to repair Hose out of date, retested good Replace Vents in all lids Replace lids for out of spec |
| Weld cracks on left rear frame over rear ends |

| NATIONAL ENERGY |
|-------------------------------------|
| I NATIONAL ENERGY EQUIPMENT INC. |

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001 **Revision Number:** 04 Prepared by / Approved by: Arash Navidan / Zanyar Farhadi Date of Issue: 2019/04/29 Page Number: 144 of 150 WELD INSPECTION REPORT **Facility Address** XXXXXXXXXXXX Registration Num XX-XXX 600 100 TIOU XXX OWNERS SERIA John Doe 1.1 XXX0XXX1XXX TANK SPEC: 400 MANUFAC MFG DATI XXX uvanee Ling)7 MATERIAL: 3434 H-32 Location of welds to be inspected (Provide sketch if required) Weld cracks on both frame rails at front slide mounts All positions John Doe XXX Welding Process(es): GMAW WPS: NEEP 22-01 Accept Reject Welder Qualification Verified \boxtimes Porosity and/or inclusions \boxtimes X **Complete Fusion** Start and End Complete \boxtimes **Full Penetration** \boxtimes 12 Welder Identi XXX X Welder Name: XXX XXX Inspector Name: Tom T Signature: Date: Nov 18 2015

This Report must be attached to the Test and Inspection Report for this unit

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 145 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 146 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 147 of 150 |

| Z NATIONAL ENERGY EQUIPMENT INC. | Quality Control Manual in accordance with CSA B620 |
|--|---|
| Document Number: NEE-QCM-THB-001 | Revision Number: 04 |
| Prepared by / Approved by: | Arash Navidan / Zanyar Farhadi |
| Date of Issue: 2019/04/29 | Page Number: 148 of 150 |

Z EQUIPMENT INC.

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Page Number: 149 of 150

Prepared by / Approved by:

Arash Navidan / Zanyar Farhadi

Date of Issue: 2019/04/29

SECTION - 22 Revision Control Sheet

| D | | | | on Numb st Issue I | | | | D - | | | | on Numb est Issue l | | | | |
|-----------|-------------|-------------|-------------|-----------------------|---------------|---|---|------------|--|-------------|-------------|------------------------|---------------|--|---|--|
| Page ↓ | 0 | 1 | 2 | 3 | 4 | 5 | 6 | Page ↓ | $\begin{array}{c c c c c c c c c c c c c c c c c c c $ | | | | | | | |
| * | Jan 2018 | Feb 2018 | May 2018 | May 2018 | April 2019 | | | * | Jan 2018 | Feb 2018 | May 2018 | May 2018 | April 2019 | | | |
| 1 | X | X | X | X | Х | | | 51 | Х | X | X | | X | | | |
| 2 | Х | Х | Х | Х | Х | | | 52 | Х | X | X | | Х | | | |
| 3 | Х | Х | Х | Х | X | | | 53 | Х | Х | X | | Х | | | |
| 4 | Х | Х | Х | Х | Х | | | 54 | Х | Х | Х | | Х | | | |
| 5 | Х | Х | Х | Х | Х | | | 55 | Х | Х | X | | Х | | | |
| 6 | Х | X | X | X | X | | | 56 | Х | X | X | | Х | | | |
| 7 | X | X | X | Х | X | | | 57 | Х | X | X | | Х | | | |
| 8 | X | X | X | X | X | | | 58 | X | X | X | | X | | | |
| 9 | X | X | X | X | X | | | 59 | X | <u>X</u> | X | | X | | | |
| 10 | X | X | X | X | X | | | 60 | X | X | X | | X | | | |
| 11 | X | X | X | X | X | | | 61 | X | X | X | | X | | | |
| 12 13 | X | X X | X X | X X | X X | | | 62 | X X | X X | X X | | X | | | |
| 13 | X X | X X | X X | X X | X X | | | 63 64 | X | A | Α | | X X | | | |
| 14 | | X | X | X | X X | | | | X | | | | | | | |
| 15 | X X | X X | X X | X X | X X | | | 65 66 | Λ | | | | X X | | [| |
| 10 | X | X | X | X | X | | | 67 | | | | | Х | | [| |
| 18 | X | X | X | X | X | | | 68 | | | | | X | | | |
| 19 | X | X | X | X | X | | | 69 | | | | | X | | | |
| 20 | X | X | X | X | X | | | 70 | | | | | X | | | |
| 21 | X | X | X | X | X | | | 71 | | | | | X | | | |
| 22 | X | X | X | X | X | | | 72 | | | | | X | | | |
| 23 | Х | X | X | X | Х | | | 73 | | | | | Х | | | |
| 24 | Х | X | X | X | X | | | 74 | | | | | Х | | | |
| 25 | Х | X | Х | X | Х | | | 75 | | | | | Х | | | |
| 26 | Х | Х | Х | Х | Х | | | 76 | | | | | Х | | | |
| 27 | Х | Х | Х | Х | Х | | | 77 | | | | | Х | | | |
| 28 | Х | Х | Х | Х | Х | | | 78 | | | | | Х | | | |
| 29 | Х | Х | Х | Х | Х | | | 79 | | | | | Х | | | |
| 30 | Х | X | Х | Х | Х | | | 80 | | | | | Х | | | |
| 31 | X | X | Х | Х | X | | | 81 | | | | | Х | | | |
| 32 | Х | X | Х | Х | X | | | 82 | | | | | Х | | | |
| 33 | X | X | X | X | X | | | 83 | | | | | Х | | ļ | |
| 34 | X | X | X | X | X | | | 84 | | | | | Х | | | |
| 35 | X | X | X | X | X | | | 85 | | | | | X | | | |
| 36 | X X | X X | X X | X X | X X | | | 86 | | | | | X X | | | |
| 37 38 | X X | X X | X X | X X | X X | | | 87 88 | | | | | X X | | | |
| | | <u>+</u> | + | + | ++ | | | | | | | | | | [| |
| 39 | X | X | X | X | X | | | 89 | | | | | X | | | |
| 40 | X | X | X | X | X | | | 90 | | | | | X | | | |
| 41 | X | X | X | X | X | | | 91 | | | | | Х | | | |
| 42 | X | Х | Х | Х | X | | | 92 | | | | | Х | | | |
| 43 | Х | X | Х | Х | X | | | 93 | | | | | Х | | | |
| 44 | Х | Х | Х | Х | Х | | | 94 | | | | | Х | | | |
| 45 | Х | Х | Х | Х | Х | | | 95 | | | | | Х | | | |
| 46 | Х | X | X | X | X | | | 96 | | | • | | Х | | | |
| 47 | X | X | X | X | X | | | 97 | | | • | | X | | | |
| 48 | X | X | X | X | X | | | 98 | | | | | X | | | |
| 49 | X | X | + | ~ | X | | | 99 99 | | | | | Х | | [| |
| | | | X | | ······ | | | | | | | | | | | |
| 50 | Х | Х | Х | | X | | | 100 | | | | | Х | | L | |

ZEQUIPMENT INC.

Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-THB-001

Revision Number: 04

Prepared by / Approved by:

Date of Issue: 2019/04/29

Arash Navidan / Zanyar Farhadi Page Number: 150 of 150

| n | Revision Number and Latest Issue Date | | | | | | | | Revision Number and Latest Issue Date | | | | | | | |
|------------|--|------------------|------------------|------------------|----------------------------|---|----------|-----------------|--|------------------|------------------|------------------|--------------------|----------|---|--|
| Page ↓ | 0 Jan 2018 | 1 Feb 2018 | 2 May 2018 | 3 May 2018 | 4 April 2019 | 5 | 6 | ·· Page ·· ↓ | 0 Jan 2018 | 1 Feb 2018 | 2 May 2018 | 3 May 2018 | 4 April 2019 | 5 | 6 | |
| 101 | 2010 | 2010 | 2010 | 2010 | X | | | 151 | 2010 | 2010 | 2010 | 2010 | 2019 | | | |
| 102 | | | | | X | | | 152 | | | | | | | | |
| 103 | | | | | X | | | 153 | | | | | | | | |
| 104 | | | | | X | | | 154 | | | | | | | | |
| 105 | | | | | X | | | 155 | | | | | | | | |
| 106 | | | | | X | | | 156 | | | | | | | | |
| 107 | | | | | X | | | 157 | | | | | | | | |
| 108 | | | | | X | | | 158 | | | | | | | | |
| 109 | | | | | X | | | 159 | | | | | | | | |
| 110 | | | | | Х | | 1 | 160 | | | | | | | | |
| 111 | | | | | Х | | | 161 | | | | | | | | |
| 112 | | | | | Х | | | 162 | | | | | | | | |
| 113 | | | | | X | | | 163 | | | | | | | | |
| 114 | | | | | Х | | | 164 | | | | | | | | |
| 115 | | | | | Х | | | 165 | | | | | | | | |
| 116 | | | | | X | | | 166 | | | | | | | | |
| 117 | | | | | X | | | 167 | | | | | | | | |
| 118 | | | | | X | | | 168 | | | | | | | | |
| 119 | | | | | Х | | | 169 | | | | | | | | |
| 120 | | | | | X | | | 170 | | | | | | | | |
| 121 | | | | | X | | | 171 | | | | | | | | |
| 122 123 | | | | | X X | | | 172 173 | | | | | | | | |
| 125 | | | | | X X | | | 173 | | | | | | | | |
| 125 | | | | | X | | | 175 | | | | | | | | |
| 126 | | | | | X | | | 176 | | | | | | | | |
| 127 | | | | | Х | | | 177 | | | | | | | | |
| 128 | | | | | X | | | 178 | | | | | | | | |
| 129 | | | | | X | | | 179 | | | | | | | | |
| 130 | | | | | X | | | 180 | | | | | | | | |
| 131 132 | | | | | X X | | | | | | | | | | | |
| 132 | | | | | X X | | | | | | | | | | | |
| 133 | | | | | X | | | | | | | | | | | |
| 135 | | | | | + | | <u>+</u> | 1 | | | | | | İ | | |
| 136 | | | | | X | | | 1 | | | | | | | | |
| 137 | | | | | X X X X X X | | | I | | | | | | | | |
| 138 | | | | | X | | | | | | | | | | | |
| 139 | | | | | X | | | | | | | | | | | |
| 140 | | | | | X | | | | | | | | | | | |
| 141 142 | | | | | X V | | | | | | | | | | | |
| 142 | | | | | X X X X | | | | | | | | | | | |
| 144 | | | | | X | | | - | | | | | | | | |
| 145 | 1 | | | | X | | | 1 | | | | | | <u> </u> | İ | |
| 146 | | | | | Х | | | - Signatu | re. | • | | | | | | |
| 147 | | | | - | X | | | | <u></u> | | | | | | | |
| 148 | | | | | Х | | | | | | | | | | | |
| 149 | | | | | Х | | | Date: | | | | | | | | |
| 150 | | | | | X | | | 1 | | | | | | | | |