# **Quality Control Manual**

for

	Manufacture,	[ <b>M</b> ]
	Modification,	[Mod]
	Repair,	[ <b>R</b> ]
	Assembly,	[A]
$\checkmark$	Inspection, Test, and	Retest [IT]

of

#### **Highway Tanks and Portable Tanks**

for the

#### **Transportation of Dangerous Goods by Road**

in accordance with CSA B620-14 or the most current version (based on Transport Canada TDG regulations)

Facility Address: 8909 Henri-Bourassa Blvd Est., Anjou, PQ, H1E 1P4



This manual is electronically controlled, if for any reason hard copies are produced they are: "NOT CONTROLLED IF PRINTED"

This manual must not be reproduced, distributed, amended or loaned, in whole or in part, without prior written consent of the National Quality Systems Manager or the Quality Assurance Specialist

This manual is in accordance with CSA B620-14 or the most current version (based on Transport Canada TDG regulations) and is for the following facility of National Energy Equipment Inc..

Facility Address	Registration No.	Activities:
8909 Henri-Bourassa Blvd Est., Anjou, PQ, H1E 1P4	25-xxxx	Inspection, Test, & Retest

National Energy Equipment Inc.'s National Quality Systems Manager ensures the quality system meets the requirements of the CSA B620-14 or the most current version.

In this manual anywhere mentioned CSA B620, it means CSA B620-14 or the most current version - (based on Transport Canada TDG regulations)

	National Energy Equipment Inc. Authorization						
Approved by:							
Name:	Zanyar Farhadi						
Title:	National Quality Systems	National Quality Systems Manager					
Phone:	(778) 588 7739						
Email address:	zfarhadi@nee.ca						
Signature:							
Date:	Date:						
		Quality Control Ma	anual in accordanc	e with CSA B620			
<b>NATIONAL ENERGY</b>		Prepared by / Approved by: Arash Navidan / Zanyar Farhadi					
<b>T</b> < EQUIP/	MENT INC.	Control Number: NEE-Q	QCM-QC-001				
		Date of Issue: 2018/02/25	Rev. No.: 01	Page: 2 of 63			

	TABLE OF CONTENT				
Item No.	Subject		Page No.		
1	Scope		6		
2	Definitions and glossary of abbreviations		7		
3	Statement of authority		8		
3-1	Responsibilities		8		
3-2	Codes and Standards		8		
3-3	Signature		8		
4	Organization chart		9		
5	Manual control		9		
6	Drawing and design control				
7	Manufacture				
8	Assembly				
9	Modification				
10	Repairs				
11	Material Control N/A				
12	Inspection and testing - examination		11		
12-1	Inspection program		12		
12-2	External visual inspection (V)		13		
12-3	Internal visual inspection(I)		N/A		
12-4	Upper Coupler area inspection(UC)		N/A		
12-5	Leakage inspection (K)				
12-6	Thickness test (T)				
12-7	Pressure tests (P)		N/A		
		Quality Control Manual in accordance with	h CSA B620		
Z	NATIONAL ENERGY QUIPMENT INC.	Prepared by / Approved by: Arash Navidan / Za Control Number: NEE-QCM-QC-001	anyar Farhadi		

Date of Issue: 2018/02/25

Rev. No.: 01

Page: 3 of 63

	TABLE OF C	CONTENT		
Item No.	Subject		Page No.	
12-8	Testing in-service, unmarked or uncertified ca	rgo tank manway covers	23	
12-9	Product hose testing procedure		26	
12-10	References		27	
13	Test and inspection marking		28	
14	Nonconformities – corrective action		29	
14-1	Identification of non-conformities		29	
14-2	Examples of tank non-conformities		29	
14-3	Retest		29	
14-4	Calibrated equipment		29	
14-5	References			
15	Welding/ brazing control			
16	Calibration			
16-1	General			
16-2	References			
17	Quality audits			
17-1	General			
17-2	Reference		32	
18	Registration – facilities and personnel		33	
18-1	Facility registration		33	
18-2	Personnel registration		33	
18-3	Reference		34	
19	Mobile units		35	
Z	NATIONAL ENERGY	Quality Control Manual in accordance wi         Prepared by / Approved by:       Arash Navidan /         Control Number: NEE-QCM-QC-001	th CSA B620 Zanyar Farhadi	
		Date of Issue: 2018/02/25 Rev. No.: 01	Page: 4 of 63	

	TABLE OF CONTENT						
Item No.	Subject						
19-1	General						
19-2	Mobile Equipment			35			
20	Records retention			36			
20-1	General			36			
20-2	References			36			
21	Exhibits			37			
21-1	Reference forms and documents			37			
21-2	Equipment, signs and decals			47			
21-3	Samples of actual completed documents			49			
22	Revision control sheet						
		anual in accord	lance with CSA				
2	NATIONAL ENERGY	Prepared by / Approved	by: Arash Navio	lan / Zanyar Farhadi			
		Control Number: NEE-Q	QCM-QC-001				
		Date of Issue: 2018/02/25	Rev. No.: 01	Page: 5 of 63			

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 6 of 63

#### SECTION - 1 Scope

This manual applies to the National Energy Equipment Inc. (NEEI) facility with the registration number of of **25-xxxx**, located at **8909 Henri-Bourassa Blvd Est., Anjou, PQ, H1E 1P4**, only to those Highway Transport tanks manufactured in accordance with the specifications contained in the CSA B620.

Work is including all or some of the followings: inspection, test and retest of highway tanks.

	Tank Specification	Inspection - External	Inspection - Internal	Inspection - Lining	Inspection - Upper coupler	Test/Retest - Hydrostatic	Test/Retest - Pneumatic	Test/Retest - Leak Test	Test/Retest - Fluorescent Test	Test/Retest - Thickness Test	Tanks - Repair	Tanks - Manufacture	Tanks - Assembly	Tanks - Modification	Piping - Repair	Piping - Manufacture	Piping - Modification
	TC 406	М						М									
	TC 407	М						М									
	TC 306	М						М									
	TC 307	М						М									
	TC 331	М						М									
6																	
Tanks																	
way <sup>-</sup>																	
High																	

ZEQ	TIONAL ENERGY UIPMENT INC.	Quality Control Manual in accordance with CSA B620			
Document Numb	er: NEE-QCM-QC-001	Revision Number: 01			
Prepared by / Ap	oproved by:	Arash Navidan / Zanyar Farhadi			
Date of Issue: 20	18/02/25	Page Number: 7 of 63			
<u>SECTION - 2</u>	2 Definitions and Glossary of	Abbreviations			
ASME	American Society of Mechanical En codes)	gineers (generally refers to boiler and pressure vessel			
AWS	American Welding Society				
CODE	The code or specification that the tar	nk is built to (eg. MC 306, TC 406)			
CSA	Canadian Standards Association				
CSA B620	The Canadian Standard that includes requirements (Revision 14 or most c	s highway tank specifications and inspection and testing urrent version)			
DOT	United States Department of Transportation				
HAWP	HAWP Hose assembly working pressure (the anticipated working pressure of the hose assembly, whic does not exceed the maximum working pressure of the hose assembly's lowest-rated component.)				
Hot work	any work involving welding, cutting	, grinding, drilling, or exposure to open flame.			
ISC	Internal Self Closing (valve)				
"К"	The cargo tank marking that indicate	es a LEAK test			
MAWP	The maximum allowable working pr	ressure of a cargo tank as indicated on the data plate			
MDIN	Manufactures Design Identification	Number			
MC	Motor Carrier as used in code design	nations (eg. MC 306)			
NEEI	National Energy Equipment Inc.				
PSI	Pounds per square inch				
SRV	Safety Relief Valve				
TC	Transport Canada				
TDG	Transportation of dangerous goods				
TCRN	Transport Canada Registration Num	ber			
"V"	The cargo tank marking that indicate	es an EXTERNAL visual inspection			

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 8 of 63

#### **Statement of Authority** <u>SECTION - 3</u>

This manual outlines the requirements for the activities, as detailed in Section 1. In addition, this program addresses the National Quality Systems Manager's responsibility, which details the support of the management of National Energy Equipment Inc. (NEEI), for administrating the quality control program and the various related standards to be used for the activities.

#### **3-1 Responsibilities:**

All involved personnel are totally committed to meeting the requirements of CSA B620, NEEI policies, and the quality control system outlined in this manual.

The National Quality Systems Manager (NQSM) is responsible for the preparation, revision, approval and issuance of the quality control manual. The NQSM and Quality Assurance Specialist (QAS) are responsible for the administration and implementation of the quality control program in the shops. Each NEEI branch's Process Owner, shall help them in accordance with the quality control program. The NQSM has the responsibility and authority to control production, and the organizational freedom to:

- Identify quality control problems;
- Initiate action, which results in solutions to those problems;
- Verify implementation of solutions to those problems; and
- Control further processing, delivery or unsatisfactory condition until proper disposition has been made.

Process Owners will be responsible for their assigned activities. They may delegate the performance of their assigned duties to qualified individuals but they shall retain the responsibility for those assigned activities.

In the event of a disagreement between the responsible person and the Process Owner, the problem shall be brought to the NQSM for resolution. Any resolution shall not negate the requirements of CSA B620, or this Manual.

#### 3-2 Codes and standards

The latest edition of codes and standards of Canadian Standards Association (CSA) which are specified in Transportation of Dangerous Goods of Transport Canada shall be applied for B620 program. Any other standards which are mentioned in Transport Canada website, also shall be used.

#### **3-3 Signature**

Signed: \_\_\_\_\_ Title: \_\_\_\_\_

Date:



#### SECTION- 5 Manual Control

This Manual and its revisions shall be prepared, issued, maintained, and approved by the National Quality Systems Manager. The approval and acceptance of the National Quality Systems Manager are shown on each page of the manual.

This Manual shall be reviewed at least once a year at the management review meeting to ensure all procedures are current and in conformance with CSA B620 or most current version and be revised at that time if required.

If revisions are required to this Manual they shall be implemented at the date the changes in regulation take effect. The only controlled copy of the latest revision of Manual is placed in the NEEI's intranet.

Revision shall be described in the revision control sheet (section22) and noted on the Table of Contents and each page of the Quality Control Manual.

The National Quality Systems Manager shall issue, distribute and maintain copies of this Quality Control Manual and its revisions. The same person is responsible for removal of superseded versions from circulation.

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620			
Document Number: NEE-QCM-QC-001	Revision Number: 01			
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi			
Date of Issue: 2018/02/25	Page Number: 10 of 63			
SECTION- 6 Drawing and design control	<u>l</u> N/A			
<u>SECTION- 7 Manufacture</u>	N/A			
SECTION- 8 Assembly	N/A			
SECTION- 9 Modification	N/A			
<u>SECTION- 10 Repairs</u>	N/A			
SECTION - 11 Material Control	N/A			

I NATIONAL ENERGY
EQUIPMENT INC.

Prepared by / Approved by:

Date of Issue: 2018/02/25

Page Number: 11 of 63

Arash Navidan / Zanyar Farhadi

Revision Number: 01

#### SECTION - 12 Inspection and testing – Examination

For each tank design, all drawings, design calculations, and specifications shall be in accordance with CSA B620, and selected by B621 or B622 Standards (the most current version),

As applicable, the NEEI plans and carries out production and service provisions under controlled conditions. Controlled conditions include:

1) the availability of information that describes the characteristics of the product,

2) the availability of work instructions, as necessary,

3) the use of suitable equipment,

4) the availability and use of monitoring and measuring devices,

5) the implementation of monitoring and measurement activities, and

6) the implementation of product release, delivery and post-delivery activities.

The Inspector shall have free access to such parts which shall include, but not be limited to the following:

a) Location where inspection and testing takes place

b) Quality Control Manual

The Process Owner shall be responsible for:

1) Ensuring that all required examinations and inspections are performed in compliance with the current edition of CSA B620 and TDG regulations and shall ensure that these examinations and inspections are done in accordance with approved procedures,

2) Collecting all related documentation such as design changes, calculations, specifications, repairs, examination and test reports, travel sheets into the Job File for each Highway Tank being recertified,

3) Maintaining the Job File (by job number and/or serial number).

4) Maintenance of reports and other related documents to be kept in the Job File and final copies issued to tank owner.

For all tanks that are to be inspected or tested, the inspector or tester shall ensure that all precautions are taken to ensure that there is no hazard to personnel performing the inspection and test.

<b>NATIONAL ENERGY</b> EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 12 of 63

#### 12.1 Inspection Program

Periodic inspection and test intervals shall be held based on the mentioned table 7.1 of CSA B620. (Section 21.1)

If more than one test or inspection interval is prescribed for a given tank in a particular service, then the shortest interval shall apply. The due dates for the first periodic retest and inspection are measured from the original test and inspection date marked on the tank, or if no test date is marked, the certification date.

The inspection reports shall be documented on the Test and Inspection Report (Form No. NEE-FRM-007).

#### 12.1.1 Periodic and obligatory inspection and testing.

Periodic inspection and test intervals are based on Table 7.1 of CSA620. (Section 21.1)

If more than one test or inspection interval is prescribed for a given tank in a particular service, then the shortest interval shall apply. The due dates for the first periodic retest and inspection are measured from the original test and inspection date marked on the tank, or if no test date is marked, the certification date.

In addition to the periodic retesting or inspection requirements, pneumatic retesting and inspection shall be required prior to further use if:

1) The tank shows evidence of bad dents, corroded or abraded areas, leakage, or any other condition that might render the tank unsafe for transportation service;

2) The tank has been involved in an accident in which it may have been dented, torn, or otherwise damaged so as to affect its lading retention capability; or

3) The tank has not been used for transporting dangerous goods for 1 year or more,

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 13 of 63

#### **12.2 External Visual Inspection (V)**

Typical interval is every year (annually)

12.2.1 Highway tanks for the transportation of dangerous goods other than liquefied compressed gases TC406(306), TC407(307)

## TC406, Older version:TC306



Highway tank for flammable liquids and low hazard chemicals (e.g. gasoline, diesel);

Steel or aluminum shell or reinforced plastic;

MAWP between 18 and 28 kPa (2.65 and 4 psi);

If transporting crude, MAWP between 18 and 100 kPa (2.65 and 14.7 psi);

1) Inspect all tank markings for legibility. Markings must not be faded, defaced or torn.

2) Inspect to ensure that all information on the tank data plate are concise and legible. If data plate or on the tank is illegible or information is incomplete, note on the Inspection Report and reject tank. For complete list of the required information, refer to 'Required information on the Identification Plate checklist'.

3) Inspect to ensure each manhole cover is permanently marked with

- a. the manufacturer's name;
- b. the test pressure XXX kPa (psi); and
- c. a statement certifying that the manhole cover meets the testing requirements of
- i. clause 5.6.6 of CSA B620; or
- ii. §178.345-5 of 49 CFR

4) Inspect entire exterior surface area including heads for signs of corrosion, abrasion, gouges, dents or repairs made using overlay patches. Inspect surfaces of all welds for signs of defects or cracks visually by checking with hand and using flashlight if needed, especially in areas around tank nozzles.

5) The corroded or abraded areas of the tank wall shall be thickness tested by a facility registered with Transport Canada, in accordance with clause 7.2.6 of CSA B620 (Thickness test).

6) Ensure manhole tightening devices are operative, and the covers are leak-tight, with no signs of product stains.

7) Ensuring proper functioning of all valves, vents, and emergency devices, including pressure relief valves, self-closing stop-valves, excess-flow valves, and remote closure devices, and connections are properly identified (emergency closure, liquid and vapour, etc.) ensuring that they are free of corrosion, distortion, or any other damage that would prevent their normal operation.

<b>NATIONAL ENERGY</b> EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 14 of 63

8) Either replace or test the pressure relief valves (**PRV**) to ensure that they open at the required set-todischarge pressure for the tank's MAWP, and re-seat them to a leak-tight condition at not less than 90% of that pressure, or to the re-seat pressure prescribed for the tank specification.

9) Ensuring that all bolts or nuts on any flanged connection or blank flange are in place and properly tightened by checking with a proper wrench.

10) Ensuring that all major appurtenances, piping, attachments, connecting structures, and those elements of the upper coupler assembly (if applicable) that can be inspected without dismantling the assembly are not damaged or corroded so as to affect safe operation of the vehicle.

11) Ensure that hose assemblies mounted on or accompanying the tank do not display any defects, have legible markings, and where required, have been pressure tested and tagged indicating that they were pressure tested.

12) Ensure any void drains are unplugged and inspect for signs of product residue or leakage.

13) Ensure that all bolts used to secure tank to the frame are present. Use a proper wrench to confirm bolts are tight.

14) Rollover protection facilities are properly installed on the tank. The welding of any appurtenance to the shell or head must be made by attachment of a mounting pad.

15) Bumpers of the cargo tank is properly installed to the specified dimensions, and it will successfully absorb the impact of the vehicle with rated payload. The clearance between the effective bottom of the bumpers or devices and the ground is less than 76cm (30in) when the vehicle is empty;

16) Inspect to ensure that all hose assemblies mounted on or accompanying the tank do not display any defects and have legible markings.

17) The original plate shall not be removed in any condition.

18) Ensure that the tank is equipped with one or more dry chemical fire extinguishers accessible from the ground, with a combined total effective rating of not less than 40BC. Each of them shall be recharged immediately after each use.

19) Ensure that the tank is equipped with an automatic engine air intake shut off device that prevent engine runaway in case of exposure to flammable vapours. The device shall activate automatically if engine runaway is detected and remain activated until manually reset.

20) In addition to the rejection criteria (as stated in Clause 7.2.1.8 of CSA B620), reject the tanks when the following defects are found during an external inspection:

- Any dent with a depth of more than 12.7 mm (0.5 in) where it includes a weld;
- Any dent with a depth of greater than 10% of the length of the dent,
- Any weld defect, including a crack, pinhole, or incomplete fusion of the weld;
- Any structural defect; and

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi

Date of Issue: 2018/02/25

- Any source of leakage, or
- Repairs made to liquid-retaining components using overlay patches.
- When any noted CSA B620 design requirements are not met such as impact protection or rear bumper restrictions, etc.

Page Number: 15 of 63

21) Ensure all outlets, valves, closures, piping, or any devices that if damaged in an accident could result in a loss of lading, are protected by accident damage protection.

#### TC407, Older version:TC307



Highway tank for toxic, corrosive and flammable liquids; Circular cross-section; Steel, aluminum or reinforced plastic; MAWP of at least 172 kPa (25 psi); Over 235 kPa (35 psi) or vacuum loaded, must be ASME; May be vacuum loaded if external design pressure is at least 103 kPa (15 psi) and internal design pressure is at least 173 kPa (25 psi);

- 1) Inspect all tank markings for legibility. Must not be faded, defaced or torn.
- 2) Inspect to ensure that all information on the tank data plate are concise and legible. If data plate or on the tank is illegible or information is incomplete, note on the Inspection Report and reject tank. For complete list of the required information, refer to 'Required information on the Identification Plate checklist'.
- 3) Inspect to ensure each manhole cover is permanently marked with
  - a. the manufacturer's name;
  - b. the test pressure XXX kPa (psi); and
  - c. a statement certifying that the manhole cover meets the testing requirements of
    - i. clause 5.6.6 of CSA B620; or
    - ii. §178.345-5 of 49 CFR
- 4) On non-insulated tanks, inspect entire exterior surface area including heads for signs of corrosion, abrasion, gouges, dents or repairs made using overlay patches. Inspect surfaces of all welds for signs of defects or cracks visually by checking with hand and using flashlight if needed, especially in areas around tank nozzles.

NATIONAL ENERGY
EQUIPMENT INC.

Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 16 of 63

- 5) On insulated tanks note all signs of exterior damage and signs of leakage and check for loose or damaged jacketing material. Any leakage from drain of void space indicates leak in tank wall therefore tank shall be rejected.
- 6) The corroded or abraded areas of the tank wall shall be thickness tested by a facility registered with Transport Canada, in accordance with clause 7.2.6 of CSA B620 (Thickness test).
- 7) Ensure manhole tightening devices are operative, and the covers are leak-tight, with no signs of product stains.
- 8) Ensuring proper functioning of all valves, vents, and emergency devices, including pressure relief valves (PRV), self-closing stop-valves, excess-flow valves, and remote closure devices, and connections are properly identified (emergency closure, liquid and vapour, etc.) ensuring that they are free of corrosion, distortion, or any other damage that would prevent their normal operation.
- 9) Either replace or test the pressure relief valves to ensure that they open at the required set-to-discharge pressure for the tank's MAWP, and re-seat them to a leak-tight condition at not less than 90% of that pressure, or to the re-seat pressure prescribed for the tank specification.
- 10) Ensuring that all bolts or nuts on any flanged connection or blank flange are in place and properly tightened by checking with a proper wrench.
- 11) Ensuring that all major appurtenances, piping, attachments, connecting structures, and those elements of the upper coupler assembly (if applicable) that can be inspected without dismantling the assembly are not damaged or corroded so as to affect safe operation of the vehicle.
- 12) Ensure that hose assemblies mounted on or accompanying the tank do not display any defects, have legible markings, and where required, have been pressure tested and tagged indicating that they were pressure tested.
- 13) Ensure any void drains are unplugged and inspect for signs of product residue or leakage.
- 14) Ensure that all bolts used to secure tank to the frame are present. Use a proper wrench to confirm bolts are tight.
- 15) Rollover protection facilities are properly installed on the tank. The welding of any appurtenance to the shell or head must be made by attachment of a mounting pad.
- 16) Bumpers of the cargo tank is properly installed to the specified dimensions, and it will successfully absorb the impact of the vehicle with rated payload. The clearance between the effective bottom of the bumpers or devices and the ground is less than 76cm (30in) when the vehicle is empty;
- 17) Inspect to ensure that all hose assemblies mounted on or accompanying the tank do not display any defects and have legible markings.
- 18) The original plate shall not be removed in any condition.

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 17 of 63
19) Ensure that the tank is equipped with one or ground, with a combined total effective ratin immediately after each use.	more dry chemical fire extinguishers accessible from the g of not less than 40BC. Each of them shall be recharged
20) Ensure that the tank is equipped with an autorunaway in case of exposure to flammable varunaway is detected and remain activated un	omatic engine air intake shut off device that prevent engine apours. The device shall activate automatically if engine til manually reset.
21) In addition to the rejection criteria (as stated following defects are found during an extern	in Clause 7.2.1.8 of CSA B620), reject the tanks when the al inspection:
- Any dent with a depth of more than 12.7	mm (0.5 in) where it includes a weld;
- Any dent with a depth of greater than 10%	6 of the length of the dent,
- Any weld defect, including a crack, pinho	le, or incomplete fusion of the weld;
- Any structural defect; and	
- Any source of leakage, or	
- Repairs made to liquid-retaining compone	ents using overlay patches.
- When any noted CSA B620 design requir restrictions, etc.	rements are not met such as impact protection or rear bumper
22) Visually inspect the gaskets on any full open cuts, cracks, or splits that are likely to cause found	ing rear head tanks for cuts, cracks, or splits, and replaced if leakage, or are a depth of 12.7 mm (0.5 in) or more, are
Tound.	

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
<b>Document Number: NEE-QCM-QC-001</b>	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 18 of 63

**12.2.2** Highway tanks for the transportation of liquefied compressed gases and refrigerated liquefied gases TC331

#### TC331



Highway tank for liquefied compressed gases (e.g. LPG, NH3); Steel or aluminum; Design pressure shall be at least 690 kPa (100 psi) and not more than 3450 kPa (500 psi);

- 1) Inspect all tank markings for legibility. Must not be faded, defaced or torn.
- 2) Inspect to ensure that all information on the tank data plate are concise and legible. If data plate or on the tank is illegible or information is incomplete, note on the Inspection Report and reject tank. For complete list of the required information, refer to 'Required information on the Identification Plate checklist'.
- 3) Inspect entire exterior surface area including heads for signs of corrosion, abrasion, gouges, dents or repairs made using overlay patches. Inspect surfaces of all welds for signs of defects or cracks visually by checking with hand and using flashlight if needed, especially in areas around tank nozzles.
- 4) The corroded or abraded areas of the tank wall shall be thickness tested by a facility registered with Transport Canada, in accordance with clause 7.2.6 of CSA B620 (Thickness test).
- 5) Ensure manhole tightening devices are operative, and the covers are leak-tight, with no signs of product stains.
- 6) Ensuring proper functioning of all valves, vents, and emergency devices, including pressure relief valves (PRV), self-closing stop-valves, excess-flow valves, and remote closure devices, and connections are properly identified (emergency closure, liquid and vapour, etc.) ensuring that they are free of corrosion, distortion, or any other damage that would prevent their normal operation.
- 7) Either replace or test the pressure relief valves to ensure that they open at the required set-to-discharge pressure for the tank's MAWP, and re-seat them to a leak-tight condition at not less than 90% of that pressure, or to the re-seat pressure prescribed for the tank specification.
- 8) Ensuring that all bolts or nuts on any flanged connection or blank flange are in place and properly tightened by checking with a proper wrench.
- 9) Ensuring that all major appurtenances, piping, attachments, connecting structures, and those elements of the upper coupler assembly (if applicable) that can be inspected without dismantling the assembly are not damaged or corroded so as to affect safe operation of the vehicle.

NATIONAL ENERGY	-
EQUIPMENT INC.	

<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 19 of 63

10) Ensure that hose assemblies mounted on or accompanying the tank do not display any defects, have legible markings, and where required, have been pressure tested and tagged indicating that they were pressure tested.

- 11) Ensure any void drains are unplugged and inspect for signs of product residue or leakage.
- 12) Ensure that all bolts used to secure tank to the frame are present. Use a proper wrench to confirm bolts are tight.
- 13) Rollover protection facilities are properly installed on the tank. The welding of any appurtenance to the shell or head must be made by attachment of a mounting pad.
- 14) Bumpers of the cargo tank is properly installed to the specified dimensions, and it will successfully absorb the impact of the vehicle with rated payload. The clearance between the effective bottom of the bumpers or devices and the ground is less than 76cm (30in) when the vehicle is empty;
- 15) Inspect to ensure that all hose assemblies mounted on or accompanying the tank do not display any defects and have legible markings.
- 16) The original plate shall not be removed in any condition.
- 17) Ensure that the tank is equipped with one or more dry chemical fire extinguishers accessible from the ground, with a combined total effective rating of not less than 40BC. Each of them shall be recharged immediately after each use.
- 18) Ensure that the tank is equipped with an automatic engine air intake shut off device that prevent engine runaway in case of exposure to flammable vapours. The device shall activate automatically if engine runaway is detected and remain activated until manually reset.
- 19) In addition to the rejection criteria (as stated in Clause 7.2.1.8 of CSA B620), reject the tanks when the following defects are found during an external inspection:
  - Any dent with a depth of more than 12.7 mm (0.5 in) where it includes a weld;
  - Any dent with a depth of greater than 10% of the length of the dent,
  - Any weld defect, including a crack, pinhole, or incomplete fusion of the weld;
  - Any structural defect; and
  - Any source of leakage, or
  - Repairs made to liquid-retaining components using overlay patches.
  - When any noted CSA B620 design requirements are not met such as impact protection or rear bumper restrictions, etc.
- 20) Ensure all outlets, valves, closures, piping, or any devices that if damaged in an accident could result in a loss of lading, are protected by accident damage protection.
- 21) Off-truck emergency shutdown systems, shall be tested as per form number NEE-FRM-010 Inspection Check List for TC-331 mentioned in Section 21.1
- 22) Control will be tested at the time of inspection as follows:

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
<b>Date of Issue:</b> 2018/02/25	Page Number: 20 of 63

- TC 331 tanks that transport liquefied compressed gas (LPG) are required to have Emergency discharge controls, except designed to transport Class 2.2, non-flammable and non-toxic gases.
- Tanks that are 13,250L or less, equipped for metered Service, need an off-truck emergency shutdown system.
- Tanks that are 13,250L or more, equipped for metered service, will need either a monitoring feature or a passive emergency shutdown system in addition to an off-truck emergency shut down system.
- With product running at normal flow rate throughout the metering system, activate the off-truck Emergency shutdown system (normally this would be a BASE Engineering product). Observe the meter to determine how long it takes to stop the product flow. The meter should stop the flow and close the ISC within 30 seconds or sooner. No meter creep after 5 seconds.
- The same process for testing the Emergency Discharge Controls shall be used on both ON and OFF truck applications.
- The emergency shut down system shall function reliably at a distance of 46 m (150ft)
- When the Emergency shutdown has been activated, the ISC can't be reactivated remotely.
- Indicate results on Test and Inspection Report (Form No. NEE-FRM-007).
- For non-metered tanks, all ISC valves shall be open. Each emergency discharge control remote actuator (on-truck and off-truck) shall be operated to ensure each ISC valve indicator has moved to the closed position. Once all ISC valves are closed, all of the material in the downstream piping shall be evacuated, and the piping shall be returned to atmospheric temperature and pressure. The outlet shall then be monitored for 30 seconds to ensure that there is no detectable leakage.
- 23) Piping or hose used for loading/unloading liquefied gas shall be provided with a manual bleed valve or other means of relieving pressure before the hose is disconnected.

#### **12.3** Internal Visual Inspection (I)

**12.4** Upper Coupler Inspection (UC)

NA

NA

<b>NATIONAL ENERGY</b> EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 21 of 63

#### 12.5 Leakage Test (K) - Typical interval is every year (annually)

The tank shall successfully pass an External Visual Inspection prior to performing this test and if this test is being conducted at the frequency a pressure re-test is due, the pressure re-test shall be conducted first.

All product piping valves and accessories shall be in place with the exception of any normal breathing vents (vents set to release at less than test pressure), which shall be rendered inoperative.

Test pressure shall be not less than 80% of the tank design test pressure or MAWP, whichever is less, and marked on the certification plate, except if a tank with a MAWP of 690 kPa (100 psig) or more is used in dedicated service or services, the test pressure shall be the maximum normal operating pressure of the tank.

1) Put in place a Pressure Safety Relief valve and set at MAWP.

2) Test each valve and closure in sequence, with the tank laden under normal operating conditions

3) Close internal valve and open manifold valve (if equipped) and all other valves in discharge line, including external valve.

4) Ensure any adjacent compartments and void spaces are empty and open to atmosphere i.e. double walled tanks.

5) Fill compartment with enough test medium to cover the valve sump and fill the piping. Close all remaining openings.

- One of the following shall be used as the test medium:
  - (i) the normal lading of the tank;
  - (ii) a less hazardous lading of equal or less viscosity;
  - (iii) water;
  - (iv) inert gas;
  - (v) air.

Note: When using air as a test medium, the tester should be aware of the need for proper purging and ensure that there is no possibility of creating a mixture of product and air within the explosive limits of the product.

6) Pressurize the tank to the correct pressure with regulated air. Once the test pressure is reached, shut off the supply. The test pressure must be maintained for at least 5 minutes with no loss. If a tank is in dedicated service and over 100 psi the normally lading of the product will be used at the maximum of the normal operating pressure. MC 331 or TC 331 in LPG or NH3 service shall be tested at no less than 60 PSI.

7) With tank under pressure, check all weld seams with soap and water mix. Check for signs of any leakage. Inspect gaskets at internal valves and manhole covers, and venting devices.

8) Close first valve or closure in discharge system and open internal valve, leaving all other valves in discharge line open including external valve. Adjust pressure to the correct pressure for the tank being tested and shut off the supply. The piping and the first valve in discharge system will now be pressurized in addition to the tank shell; test pressure must hold for 5 minutes with a 0 psig drop.

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 22 of 63

9) Repeat the above procedure (8) for each valve and closure in discharge line, until all valves and closures have been tested. If piping includes pumps and meters these should be tested at the tank leak test pressure in sequence with the immediate downstream valve or closure closed and all upstream valves and closures open. Carefully inspect all joints in pumps and meter for signs of leakage. If piping system includes hose reel, unreel the hose to its full length and carefully inspect hose connections for leakage.

10) Relieve pressure in tank and ensure normal breathing vent is returned to operative status.

11) Indicate all defects found and methods used to repair on the Test and Inspection Report (Form No.: NEE-FRM-007) in accordance with clause 7.3 of CSA B620.

12) All leaks must be repaired and retested prior to marking tank.

13) During the test, precautions shall be taken to prevent overpressurization of the tank.

#### **12.6** Thickness Test (T) (Only at periodic inspections)

#### **12.7 Pressure Tests (P)**

NA

NA



**Document Number:** NEE-QCM-QC-001

**Prepared by / Approved by:** 

Date of Issue: 2018/02/25

Page Number: 23 of 63

**Revision Number: 01** 

Arash Navidan / Zanyar Farhadi

#### 12.8 Testing in-service, unmarked or uncertified cargo tank manway covers

#### 12.8.1 Purpose

The purpose of this test procedure is to qualify, by means of a pressure test, the structural integrity of in-service manways and fill openings.

#### 12.8.2 Qualifying Test

- In-service manways and/or fill opening covers not marked as certified by the manufacturer shall be tested using the equipment described in 12.8.3 and the procedure described in 12.8.4.
- Manway and/or fill opening covers successfully meeting this test per 5.0 and prior to reinstallation on the cargo tank may be permanently marked by stamping or other means. The name of the tester and date of the test should be recorded and retained.
- Any device, such as a pressure relief valve, which becomes a part of the manway cover assembly, shall be evaluated separately for compliance.

12.8.3 Test Equipment (See Figure 1)

- The test fixture for the 15-psig test consists of 16" diameter, 20" diameter, or 12"x 16" elliptical collars with a suitable material welded to the bottom. The test fixture collar shall be the same size, thickness, and material as that collar on the tank to which the manway cover assembly is to be installed if it complies with CSA B620 requirements.
- Gauges: One (1) 0-30 psig for leakage test.
- Pipe fittings:

One (1) <sup>1</sup>/<sub>2</sub>" NPT globe valve One (1) <sup>1</sup>/<sub>2</sub>" ball valve One (1) <sup>1</sup>/<sub>2</sub>" cross Five (5) <sup>1</sup>/<sub>2</sub>" pipe nipples

- Rubber membranes of 1/8" thickness to fit outside diameter of manway collar.
- Steel plate with guides to block fill opening only if fill opening cover acts as a pressure relief valve. Please note that some old manway covers have fill covers that do not provide pressure relief and those fill covers should not be blocked closed.
- Vent plugs, flanges, or other devices to block holes in manway cover.
- Manway gaskets One (1) for each size manway assembly to be tested.
- Gasket for the 10-inch diameter pressure relief valves.

12.8.4 Manway Cover Test Procedures

12.8.4.1 Remove manhole cover assembly and clamping ring assembly to be tested from the cargo tank.

NATIONAL ENERGY
EQUIPMENT INC.

Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 24 of 63

- 12.8.4.2 Remove any normal pressure/Vacuum vents, sensors, high capacity vents or any other appurtenance that protrudes below the manhole cover.
- 12.8.4.3 Block the openings in the manhole cover by a proper device.
- 12.8.4.4 Fill test fixture base with water to top of collar.
- 12.8.4.5 Lay rubber membrane on test base.
- 12.8.4.6 Open 10" diameter pressure relief valve. Install steel plate with guides to underside of 10" diameter opening. Use vice grips to hold this plate in position while placing manhole cover assembly on rubber membrane.
- 12.8.4.7 Install 10-30 psig gauge in test base.
- 12.8.4.8 Attach manhole cover assembly with its clamping ring assembly to the test fixture. While tightening clamping ring bolt, tap the ring at various points to ensure equal clamping.
- 12.8.4.9 Slowly pressurize test fixture to 15 psig for a period of at least 5 minutes.CAUTION: WATCH PRESSURE. DO NOT OVER-PRESSURIZE.Most water systems provide a pressure over 50 psig.
- 12.8.5 Inspection
  - 12.8.5.1 Any leakage will be considered a failure of this cover and others of its type and condition.
  - 12.8.5.2 If the cover does not pass this test in its original condition, but the manhole cover assembly manufacturer has components available that will enable the cover to pass the test, covers using such components are considered satisfactory.
  - 12.8.5.3 Before reinstalling the manhole cover to the cargo tank, the collar and gasket shall be inspected. If damage, distortion, corroded areas or other conditions exist that could impair its product retention capability, the collar and/or gasket shall be replaced.



	NATIONAL ENERGY
19	EQUIPMENT INC.

Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 26 of 63

#### 12.9 Product hose testing procedure

12.9.1 Scope This procedure covers hose testing requirements in accordance to B620, Clause 7.2.10, and applies to product delivery and vapour return hose assemblies that are temporarily connected between the tank or any tank-mounted accessory and the point of supply or receipt during loading or off-loading, but do not apply to hose assemblies that are part of the piping system.

Hoses may be tested annually on or off the vehicle.

Hoses may be tested by other qualified hose testing organizations.

- 12.9.2 Frequency All hoses shall be tested once per year
- 12.9.3 Safety Hose testing shall be performed in a manner that ensures all safety provisions including but not limited to any required 'personal protective equipment' (PPE), safety system and barricades /cones to protect personnel during testing in the event of a hose failure. Some safety provisions are as follows:
  - (i) Ensure that all hose fittings are securely fastened
  - (ii) If during the test a severe leak or hose rupture occurred, stop the test
  - (iii) The hose should be inspected by walking down the hose (away from the pump towards the nozzle)

(iv) Stay in a safe distance away from the hose while it is under test pressure and never straddle the hose or move the hose once it is under test pressure.

(v) Prevent over-pressurizing the hose during the hose testing.

# 12.9.4 Training All employees involved in hose testing shall be trained in testing procedures and rejection criteria. Records of training shall be kept in the related employment files.

# 12.9.5 Procedure (a) A hose assembly having any damage identified in Clause 7.2.10.4 of CSA B620 shall be taken out of service and not be pressure tested until repaired.

- (b) The test pressure shall be
  - (i) for CSA-certified hose assemblies, not less than 2400 kPa (350 psi);
  - (ii) for gravity off-load hose assemblies (drop hoses), not less than 69 kPa (10 psi);
  - (iii) for vapour recovery hose assemblies on TC 406 tanks and the equivalent and substitute tanks identified in CSA B621, not less than 69 kPa (10 psi);
  - (iv) for all other hose assemblies, the greater of 120% of the marked HAWP of the hose assembly and 518 kPa (75 psi).
- (c) The following shall not be used to pressurize the hose assembly:
  - (i) compressed gas;
  - (ii) compressed air;
  - (iii) flammable liquid; or
  - (iv) corrosive liquid.
  - Note: Water is the recommended test fluid.
- (d) The requirements of Item (c) shall not apply to

(i) hose assemblies used to handle aircraft fuel;

(ii) CSA-certified hose assemblies; or

<b>Z</b> NATIONAL ENE EQUIPMENT IN	RGY C.	Quality Control Manua in accordance with CSA B	l 620
Document Number: NEE-QCM-QC-001		Revision Number: 01	
Prepared by / Approved by:		Arash Navidan / Zanyar Farhadi	
Date of Issue: 2018/02/25		Page Number: 27 of 63	
(iii) hose asse and docum B51" or "A	mblies used in ented as confo SME B31.3" b	refrigerated liquefied gas service that are prming to CSA B51 or ASME B31.3 and r by the hose assembly manufacturer.	manufactured narked "CSA
(e) Provisions sha	ll be made to p	protect personnel during testing should failure	e occur.
(f) To pass the pr distortion, or le	essure test, the eaks for at least	e hose assembly shall hold the pressure wit t 5 min when isolated from the pressure supp	hout bulging, bly.
12.9.6 Hose Markings Upon successful completion of the Hose Inspection and Testing hose assemblies shall be either tagged with a metal tag or stamped on the coupling, in such a way not to affect the integrity of the hose, with letters/numbers of not less that 5mm high, with the month and year of the test. The HAWP for a hose assembly that is not already marked may be determined by referring to documentation provided by the hose and coupling manufacturer or supplier or by inspecting the hose and couplings for markings applied during manufacturing that indicate the maximum working pressure for the component. A HAWP shall be marked on a hose that is successfully tested. Hose assemblies for which ratings cannot be determined shall not be marked. If not already marked on the hose assembly, markings shall also be applied to indicate the serial number or identification number of the hose assembly.			
12.9.7 Test Report A test report shall be completed indicating name of the facility conducting the test, the hose assembly serial or identification number, the HAWP, the date and nature of inspection or test. The report shall be maintained for a minimum of 2 years. These records may be maintained electronically.			
12.10 References			
NEE-FRM-007-406 Test an	d Inspection R	eport for TC406/TC(MC)306 tanks	(See 21.1)
NEE-FRM-007-407 Test an	d Inspection R	eport for TC407/TC(MC)307 tanks	(See 21.1)
NEE-FRM-007-331 Test an	d Inspection R	eport for TC(MC)331 tanks	(See 21.1)
NEE-FRM-012 Hose Assembly Te		and Inspection Report	(See 21.1)
Table 7.1 of CSA B620Periodic inspection		nd test intervals	(See 21.1)
Table 7.3 of CSA B620Pressures for periodic		retesting	(See 21.1)
Required information on the Identification Plate checklist (See 21.1)			(See 21.1)

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620	
Document Number: NEE-QCM-QC-001	Revision Number: 01	
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi	
Date of Issue: 2018/02/25	Page Number: 28 of 63	

#### SECTION-13 Test and inspection marking

Upon successful completion of a test or registered activities in compliance with CSA B620, the tank inspector shall mark the tank in accordance with this section.

The markings shall be a minimum of 32mm high and clearly contrast with the background and shall be located on the tank front head or jacketing or above the identification plate, or anywhere on the front head where it is clearly visible from the ground. The markings shall be printed on durable labels and affixed to tanks firmly.

The markings shall consist of:

- The month and year of the inspection or test
- The letter indicating the type of inspection or test performed (in accordance with Clause 7.4 of CSA B620)
- The last four digits of the Facility Registration Number, as shown on the TC Certificate of Registration for the facility

The letters indicating the types of test of inspection shall be as follows:

"V" - External Visual Inspection

"K" - Leakage Test

Typical Marking: 02/18 VK xxxx

where: 02/18 indicates Inspection and Test performed February 2018; VK indicates External Visual and Leakage Tests were successfully completed; xxxx indicates the last digits of the Transport Canada Facility Registration number

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 29 of 63

#### SECTION- 14 Nonconformities – Corrective action

A non-conformity is any condition in process, equipment, material, fabrication or attachment that does not meet all the requirements of the specifications the Highway Tank is constructed to, or the requirements of this Quality Control Manual.

When a nonconformity or a quality control problem happens or is probable to happen, it will be reported to the national quality system manager, who makes sure the specified root cause analysis and the related corrective / preventive action(s) are taken to avoid repetition of the nonconformity.

#### 14.1 Identification of Nonconformities

It is the duty of all employees to report non-conformities to their supervisors. Non-conforming condition shall be notified to the national quality system manager. All corrective actions start with an investigation to determine the root cause(s) of the problem. A thorough analysis of all related processes, operations, quality records, and specifications, which may have contributed to the deficiency, is conducted by the responsible personnel. All potential corrective actions are identified and the action(s) most likely to eliminate the problem and to prevent recurrence is selected. The investigation and analysis of the root cause and preventive measures shall be documented in Non Conformance Corrective and Preventative Action Report form (Form No. NEE-FRM-017). The analysis shall include review of all applicable data to determine the extent and cause of the problem and analysis of trends in processes or performance of work to prevent nonconformities.

All problems are evaluated in terms of potential impact on quality, performance, reliability, safety, and customer satisfaction. Resolutions to all corrective and preventive actions are to a degree appropriate to the magnitude and the risk of the problem. Resolutions are reviewed and approved by the national quality system manager **or** his designated representative.

#### 14.2 Examples of Tank Nonconformities

- Routine maintenance Items when the non-conformity is of a routine maintenance nature (eg. leaking gasket, seized remote release, performed tests by an uncelebrated gauge, etc.)

- Any non-conformance that is discovered related to Test and Inspection activities shall be brought to the attention of the Process Owner. The non-conformance shall be reviewed.

#### 14.3 Retest

Upon correction of any tank non-conformity, the tank shall be re-tested in accordance with the tank's requirements.

#### 14.4 Calibrated Equipment

Any non-conformity discovered in the Calibrated Equipment shall be resolved in accordance with Section 16 (Calibration) of this Manual.

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 30 of 63

# 14.5 Reference

- NEE-FRM-017 Nonconformance corrective and preventative action report form (See 21.1)

SECTION - 15 Welding control

NA

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620	
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01	
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi	
Date of Issue: 2018/02/25	Page Number: 31 of 63	

#### SECTION - 16 Calibration

#### 16.1 General

All test and inspection equipment used in Inspection and Testing procedures of this Manual shall be calibrated in accordance with this section.

The Process Owner is responsible for maintaining all equipment in calibration.

Calibration may be performed by the Process Owner, or a qualified individual who has been assigned to the task and trained,

Pressure gauges or digital manometer used for pressure tests are calibrated to a certified calibrated master gauge weekly, or when there is reason to question their accuracy. The master gauge shall also be re-calibrated and re-certified annually and the certificate keep on file. All gauge calibrations shall be documented on the Gauge Calibration Log (Form No. NEE-FRM-014). All equipment calibrations shall be documented on the Equipment Calibration Log (Form No. NEE-FRM-015)

The frequency of calibration for other equipment is as recommended by the equipment manufacturer or from experience with the equipment.

When equipment requiring calibration is found to be out of calibration it shall be removed from the work area, fixed, re-calibrated or replaced.

All items checked without calibration equipment shall be considered as non-conforming until the Process Owner verifies that they meet all Specification requirements or, the items have been re-checked with appropriately calibrated equipment.

#### 16.2 Procedure

References

16.3

Connect the gauge to be calibrated to the master gauge and pressure source.

Apply the pressure to the gauge to be calibrated in increments over the full range of the gauge.

Compare the value of pressure indicated by the master gauge with the corresponding value of the pressure indicated by the gauge being calibrated for each pressure increment. The values should be same.

If necessary, adjust the gauge and repeat the above paragraph until the both values are same.

After three trials, if the values are not same, the gauge is rejected and shall be removed from the work area.

-	NEE-FRM-014	Gauge Calibration Log	(See 21.1)
-	NEE-FRM-015	Equipment Calibration Log	(See 21.1)

NATIONAL ENERGY
EQUIPMENT INC.

**Document Number:** NEE-QCM-QC-001

Prepared by / Approved by:

Page Number: 32 of 63

Arash Navidan / Zanyar Farhadi

**Revision Number: 01** 

Date of Issue: 2018/02/25

# SECTION - 17 Quality Audits

# 17.1 General

National quality system manager is responsible for coordinating with Process Owners of facilities to plan a regular quality audit and closure corrective actions required to eliminate the recorded nonconformities based on the internal audits and the Non Conformance Corrective and Preventative Action Report form (From No.: NEE-FRM-017).

Forms and related documents which are listed in 'Mandatory document list' shall be completed in accordance with the related process.

Where these audits indicate that tanks may be out of compliance, those tanks shall be recalled and brought into conformance.

Where re-work is required, the effectiveness of the re-work shall be verified by performing the appropriate tests and inspections after work is completed.

Where these audits reveal repeated non-conformance, the relevant procedures in this manual shall be reviewed and where required, training initiated to eliminate non-conformance.

The national quality system manager shall annually review the complete process to ensure it is in conformance with this Quality Control Manual in the management review meeting. This meeting shall include but not limited to:

## • Results of audits

- Facility Registration documents
- Material procurement and control
- Quality Control process performance
- Status of non conformities, preventive and corrective actions
- Follow-up actions from previous management review meeting
- Recommendations for improvement

#### 17.2 References

- NEE-FRM-017 Nonconformance corrective and preventative action report

(See 21.1)

- Mandatory Document List

(See 21.1)



**Document Number:** NEE-QCM-QC-001

Revision Number: 01

Prepared by / Approved by:

Date of Issue: 2018/02/25

Page Number: 33 of 63

Arash Navidan / Zanyar Farhadi

# SECTION - 18 Registration – Facilities and Personnel

# 18.1 Facility Registration

Facility registration is the responsibility of the National quality system manager (NQSM).

NQSM is responsible for ensuring the certificate of registration is current and covers all inspection, test and retest of highway tanks performed by the registered NEEI facility with the registration number of **25-xxxx**, located at **8909 Henri-Bourassa Blvd Est.**, **Anjou**, **PQ**, **H1E 1P4**.

For the scope of the registered facility, refer to the section one (1) of this quality control manual.

# 18.2 Personnel Registration

It is the responsibility of the Process Owner to ensure that all personnel are qualified based on their experience and after a proper training. After verification of their qualifications, they will get the 'Certificate of qualification' for only those functions, which they have been qualified. Employee qualification records must be retained throughout the duration of employment and for five (5) years after the end of employment. The minimum qualification requirements of CSA B620 Clause 8 as follows:

## Tank Inspector

Tank inspector shall have

(a) the knowledge and ability to determine if a tank conforms to a particular specification; and

(b) education and experience in the construction, inspection, testing, or retesting of tanks of that specification, as follows:

(i) an engineering degree or professional engineer status in a province of Canada, and one year of experience;

(ii) a technical diploma and two years of experience;

(iii) a high-school diploma and three years of experience; or

(iv) five years of experience or more.

## Tester

Every tester shall

(a) be familiar with the specification tank on which the test is performed;

(b) be familiar with the test procedure and pass/fail criteria;

(c) have at least one year of experience performing the test; and

(d) be trained and experienced in the use of the testing equipment.

<b>NATIONAL ENERGY</b> EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 34 of 63

Every tester and inspector shall have training in product and hose safety, quality control manual, inspection/ test procedures, and the related rejection criteria.

## **18.3** References

- Certificate of qualification

(See 21.1)



<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 35 of 63

## SECTION - 19 Mobile Units

#### 19.1 General

- a) Mobile units and related equipment shall be controlled by the process owner from the registered facility **25-xxxx**, located at **8909 Henri-Bourassa Blvd Est.**, **Anjou**, **PQ**, **H1E 1P4**.
- b) All the documentation like records of Mobile Inspection and Testing shall be maintained and keep at the registered facility 25-xxxx, located at 8909 Henri-Bourassa Blvd Est., Anjou, PQ, H1E 1P4. Note: documentation will be carried with the mobile unit too.
- c) There is at least one dedicated enclosed field service mobile unit (Ford E350, Dodge R/T or trailer approximately 7 ft wide x 16 ft long) properly licensed with the provincial government.

## **19.2 Mobile Equipment**

# a) Description of Equipment Carried with Service Unit

- Laptop, used to record inspection
- Air compressor with lines and couplers
- Calibrated pressure gauges of approximate range
- Test fittings and adapters10" Fill Betts Test Lid Hose tester
- Hydrostatic pressure test pump
- Soap solution / spray bottles
- Ladder (to reach top of tank)
- Harness and safety tie for ladder
- TANK UNDER PRESSURE Sign x 2
- Hose Inspection tags and Tank Inspection stickers
- Measuring tape, brushes, flash lights, zip ties
- Basic hand tools (wrenches, screwdrivers, etc.)
- Other general tools

Aforementioned equipment shall be stored in a waterproof equipment case, but the equipment maybe transferred to a different container depending on transporting requirements.

# b) Description of Customer Equipment and Services in the field necessary for the mobile unit to function

- Water is required for the hose testing.
- Pressure washer might be required in case that the inspector found an uncleaned spot on the tank. Please note that tanks shall be cleaned by the customer or its subcontractor.



**Document Number:** NEE-QCM-QC-001

Revision Number: 01

Prepared by / Approved by:

Arash Navidan / Zanyar Farhadi

Page Number: 36 of 63

Date of Issue: 2018/02/25

# SECTION - 20 Records Retention

#### 20.1 General

# Records referred to in this manual may be maintained and stored electronically.

The Process Owner shall review all records referred to in this manual for completeness prior to filing.

All following records shall be retained on NEEI property for a period of at least 20 years. They shall be circulated as described in the documents, where applicable.

- 1) Copy of the identification plate by the facility installing the plate
- 2) Inspection and test reports by the inspector or tester facility
- 3) Hose test reports,
- 4) Calibration records,

The national quality system manager is responsible for ensuring that above mentioned records, quality control manual, certificates and other related documents required by CSA B620 and applicable codes are properly circulated and retained for the required periods.

In the event of a change in ownership, retention by the prior Owner of non-fading copies of the records shall be deemed to satisfy the requirements of the above mentioned items.

The Job File, with all contents, shall be delivered at the time of sale by the seller of a tank to the purchaser, with non-fading copies of the contents being retained by the seller.

The Owner and the motor carrier, if they are not the Owner must each retain a copy of the test and inspection reports until the next major inspection.

On delivery of a tank, a copy of the test and inspection report (Form No.: NEE-FRM-007), Hose assembly test and inspection report (Form No.: NEE-FRM-012) shall be provided to the Owner or Owner's designate, who shall retain them throughout the ownership of the tank and for at least one year thereafter.

## 20.2 References

-	NEE-FRM-007-406	Test and Inspection Report for TC406/TC(MC)306 tanks	(See 21.1)
-	NEE-FRM-007-407	Test and Inspection Report for TC407/TC(MC)307 tanks	(See 21.1)
-	NEE-FRM-007-331	Test and Inspection Report for TC(MC)331 tanks	(See 21.1)
-	NEE-FRM-012	Hose assembly test and inspection report	(See 21.1)

Z	TIONAL ENERGY UIPMENT INC.	Y	Quality Control Manual in accordance with CSA B620			
Document Number: NEE-QCM-QC-001			Revision Number: 01			
Prepared by / Approved by:			Arash Navidan / Zanyar Farhadi			
Date of Issue: 20	018/02/25		Page Number: 37 of 63			
<u>SECTION -</u>	21 Exhibits					
21.1 Refer	ence forms and documents					
21.1.1	NEE-FRM-007-406	Test a	nd Inspection Report for TC406/TC(MC)306 tanks			
21.1.2	NEE-FRM-007-407	Test a	nd Inspection Report for TC407/TC(MC)307 tanks			
21.1.3	NEE-FRM-007-331	Test a	nd Inspection Report for TC(MC)331 tanks			
21.1.4	NEE-FRM-012	Hose a	assembly test and inspection report			
21.1.5	NEE-FRM-014	Gauge	uge Calibration Log			
21.1.6	NEE-FRM-015	Equip	ment Calibration Log			
21.1.7	NEE-FRM-017	Nonco	onformance corrective and preventative action report			
21.1.8	Mandatory Document List					
21.1.9	Certificate of qualification					
21.1.10	Table 7.1 of CSA B620	Period	ic inspection and test intervals			
21.1.11	Table 7.3 of CSA B620	Pressu	res for periodic retesting			
21.1.12	Required information on the	Identifi	cation Plate checklist			

NATIONAL ENERGY	
EQUIPMENT INC.	

Document Number: NEE-QCM-QC-001

**Revision Number:** 01

Prepared by / Approved by:

Arash Navidan / Zanyar Farhadi

Page Number: 38 of 63

21.1.1

orm Number:NEE-	FRM-007-406	Revision: 1				
Facility Name: N	ational Energy Equipment Inc					
Address:	allonar Energy Equipment inc.	TEST DATE:				
Telephone:	Fax:	Facility Re	egistration No.:	25-		
Tank Owner: Address:		=				
Telephone:		-				
OWNERS UNIT N	o;	SERIAL No.	ê.			
MANUFACTURER	· · · · · · · · · · · · · · · · · · ·	MAWP:	-			
CERT. DATE:	MATERIAL:	-	TAN	K SPEC:	2	
COMP CAPACITY		IG/L 3	10/	r		
COMP. CAPACITI	4 IG/L 5	IG/L 6	IG/	L		
EXTERNAL VISUA	L INSPECTION "V"					
Item inspected	d	QC Man. Ref.	Complies	Reject	Retest Complies	
Data plate and other r	narkings, present and legible	12.2		E.		
Shell & Heads corrosi	on, abrasion, dents, overlay patches, leaks, defect	12.2				
welds, loose bolts and Structural members, d	a nuts on any flanged/blank connection, etc. putriggers, cross members etc.	12.2		Ē		
Piping and valves for	leakage, damage, corrosion	12.2	Ē	ō	Ē.	
Remote closures, the	mal devices	12.2				
Hoses for defects, ide	ntification and test dates	12.2				
Tank attachments to f area that can be inspe	rame or running gear, elements of the UC assembly acted without dismantling	12.2				
All switches and valve	es, work properly	12.2	님		H	
Fill covers manways, tr	op of the tank, and etc.	12.2	H	H	H	
Relief valves and ven ank in service where	ts inspected and properly operative and leaking it lading corrosive to relief device)	12.2		E	Ë	
Accident damage pro	rection	12.2				
Inspector	SignatureDate_		After Retest Sig	gnature		
Note: Rejection Crit Less than r Any dent w Any dent w Any weld d Any structu Any source Any repairs Defective, r	eria for External Visual Inspections minimum material thickness under any cut, dig or goug ith a depth greater than '&' where it includes a weld ith a depth greater than 10% of the length of the dent efect including a crack, pinhole, or incomplete fusion or ral defect of leakage made to liquid-retaining components using overlay pa unidentified or out of test Hose Assemblies	e If the weld atches				

 NATIONAL ENERGY	r
EQUIPMENT INC.	

Document Number: NEE-QCM-QC-001

**Revision Number:** 01

**Prepared by / Approved by:** 

Page Number: 39 of 63

Arash Navidan / Zanyar Farhadi

Form Number:NEE-FRM-007-406				Revision: 1				
Address:	ii Energy E	quipmei	nt Inc.	TEST DATE:	-	_		
Telephone:	Fax:			Facility Registra	ation No. 2	25-		
Tank Owner: Address:				_				
Telephone:								
OWNERS UNIT No:			S	SERIAL No.				
MANUFACTURER:	-	6467	M	IAWP:	050		<u> </u>	
CERT. DATE:					EC:			
COMP. CAPACITY 1 4			G/L 2	IG/L 3 IG/L 6	IG/L			
LEAKAGE TEST "K"	(QC Mar	nual Ref	erence 12.5)					
TEST PRESSURE	, h, di		(80% of MAWF	MIN) TEST MEDIUM	-			
Item Tested	Pass	Fail	Retest Complies	Item Tested	Pass	Fail	Retest Complies	
Compartment No. 1		E		Compartment No. 1 piping				
Compartment No. 3		H		Compartment No. 2 piping	H	H		
Compartment No. 4	ā		ō	Compartment No. 4 piping				
Compartment No. 5 Compartment No. 6				Compartment No. 5 piping Compartment No. 6 piping				
o on particular in the o		Ц	Ш	ooniparanon (10, o piping			цц.	
Tank tester	Signatu	ire		DateAfter I	Retest Sig an	nature d Date	_	

NATIONAL ENERGY
EQUIPMENT INC.

Document Number: NEE-QCM-QC-001

**Revision Number:** 01

Prepared by / Approved by: Date of Issue: 2018/02/25

Page Number: 40 of 63

Arash Navidan / Zanyar Farhadi

rm Number:NEE-FRM-0	007-406	Revi	Revision: 1					
Facility Name: Nationa	I Energy Equipment Inc.	TEST		-				
Tulashara	-	T-sill						
Telephone:	Facili	y Registr	ation No.	25-				
Tank Owner: Address:								
Telephone:								
OWNERS UNIT No:		SERIAL No.:					÷	
CERT. DATE:	MATERIAL		TANK S	PEC:			÷	
		- Terr						
COMP. CAPACITY 1	IG/L 2	IG/L 3			/L /L			
					-			
NSPECTION AND TEST	CONCLUSION:							
FESTS PERFORMED	"V"	"К" 🔲						
lo defect or damage was	discovered on tank	YES 🗍 NO						
Description of the locat fixing or replacement, a	ion, nature, and severity of da and the results of any subsequ	amage or defects found, Jent test or inspection	how the	y were dis	scovered	, and the	nature of	any
Tank successfully reteste	ion, nature, and severity of da and the results of any subsequ d after fixing ngs removed Removed from Service	amage or defects found, uent test or inspection YES YES	how the	NO NO		, and the	L C	any
Tank successfully reteste	ion, nature, and severity of da and the results of any subsequ d after fixing ngs removed Removed from Service Safety Mark (Specification In	Image or defects found, Jent test or inspection YES YES	how the	NO NO		, and the		any
Tank successfully reteste Expired Inspection Markir	ion, nature, and severity of da and the results of any subsequ d after fixing ngs removed Removed from Service Safety Mark (Specification In Returned to Service	amage or defects found, uent test or inspection YES YES ndication) removed	how the	NO NO		, and the	L C	any
Tank successfully reteste Expired Inspection Markings appli	ion, nature, and severity of da and the results of any subsequ d after fixing ngs removed Removed from Service Safety Mark (Specification In Returned to Service ied	Armage or defects found, Jent test or inspection YES YES ndication) removed YES	how the	NO NO		, and the		
Tank successfully reteste Expired Inspection Markings appli FAILED INSPEC	ion, nature, and severity of da and the results of any subsequ d after fixing ngs removed Removed from Service Safety Mark (Specification II Returned to Service ied	Image or defects found, Jent test or inspection YES YES ndication) removed YES	how the	NO NO NO		, and the		
Tank successfully reteste Tank successfully reteste Expired Inspection Markings appli FAILED INSPEC Inspector	ion, nature, and severity of da and the results of any subsequed d after fixing ngs removed Removed from Service Safety Mark (Specification lu Returned to Service ied CTION	Int test or inspection VES YES ndication) removed YES	how the	NO NO NO Date_		, and the		

## Z NATIONAL ENERGY EQUIPMENT INC.

# Quality Control Manual in accordance with CSA B620

,	
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 41 of 63

21.1.2

	MENT INC.	For TC407/TC(MC)307 tanks Revision: 1					
orm Number:NEE-FR	М-007-407						
Facility Name: Natio Address:	onal Energy Equipment Inc.	TEST DA	re)				
Telephone:	Fax:	Facility Re	egistration No.:	25-			
Tank Owner: Address:		=					
Telephone:		<u> </u>					
OWNERS UNIT No:		SERIAL No.	0				
MANUFACTURER	-	MAW/P					
CERT. DATE:	MATERIAL:	-	TAN	SPEC:			
	104 2	10/1 2	101				
COMP. CAPACITY 1	IG/L 2 IG/L 5		IG/I				
EXTERNAL VISUAL I	VSPECTION "V"						
ltem inspected		QC Man.	Complies	Reject	Retest		
Data plate and other mark	rings, present and legible	12 2	Ē.				
Shell & Heads corrosion, welds, loose bolts and nu	abrasion, dents, overlay patches, leaks, defect ts on any flanged/blank connection, etc.	12.2			E		
Structural members, outri	ggers, cross members etc.	12.2					
Piping and valves for leak	age, damage, corrosion	12.2		旦			
Remote closures, therma	devices	12.2					
Hoses for defects, identifi Tank attachments to fram area that can be inspecte	cation and test dates e or running gear, elements of the UC assembly d without dismantling	12.2		븝			
All switches and valves, w	vork properly	12.2					
Ladders, walkways, trop o	of the tank, and etc.	12.2					
Fill covers, manways and Relief valves and vents in tank in service where ladi	closure devices, are operative and leaktight spected and properly operative (replace or test if no corrective to relief device)	12.2 12.2			H		
For insulated tanks, check	couter jacket for the condition of attachments	12.2					
dents, digs, scrapes, gou Accident damage protecti	ge, loose sheets and fastening devices on	12.2					
Inspector	SignatureDate_	$\longrightarrow$	Atter Retest Sig	nature d Date			
Note: Rejection Criteria Less than mini Any dent with a Any weld defec Any structural Any source of	for External Visual Inspections mum material thickness under any cut, dig or goug a depth greater than ½" where it includes a weld a depth greater than 10% of the length of the dent t including a crack, pinhole, or incomplete fusion o defect eakage ide to liquid-retaining components using overlay pa entified or out of test Hose Assemblies	e fthe weld stches					

EQUIPMEN	L ENE	RGY C.	Qu in ac	uality corda	Cont nce w	rol Manual vith CSA B62	
t Number: NEE-QCM	-QC-001		Revision Number:	01			
by / Approved by:			Arash Navidan / Zanyar Farhadi				
sue: 2018/02/25			Page Number: 42 of 63				
	NALE	NERGY INC.	Te Fc	est and or TC407	Inspect 7/TC(M0	tion Report C)307 tanks	
Form Number:NEE-FRM-	007-407		Revision: 1				
Facility Name: Nation	al Energy Equi	pment Inc.	TEST DATE:	-		1	
Telephone:	Fax:		Facility Registr	ation No. 2	25-		
Tank Owner: Address:							
Telephone:							
OWNERS UNIT No: MANUFACTURER: CERT. DATE:		MATERIAL:	SERIAL No. IAWP:	PEC:			
COMP. CAPACITY 1 4		IG/L 2 IG/L 5	IG/L 3 IG/L 6	IG/L			
LEAKAGE TEST "K"	(QC Manua	I Reference 12.5) (80% of MAWF	9 MIN) TEST MEDIUM				
Item Tested	Pass Fa	ail Retest Complies	Item Tested	Pass	Fail	Retest Complies	
Compartment No. 1 Compartment No. 2 Compartment No. 3 Compartment No. 4 Compartment No. 5 Compartment No. 6			Compartment No. 1 piping Compartment No. 2 piping Compartment No. 3 piping Compartment No. 4 piping Compartment No. 5 piping Compartment No. 6 piping				
Tank tester	Signature_		Date After	Retest Sig an	nature d Date		

EQUIPMEN 1	in accordance with CSA B62							
Number: NEE-QCM-QC	-001	Revision Nu	mber: 01					
y / Approved by:	Arash Navidan / Zanyar Farhadi							
<b>ie:</b> 2018/02/25		Page Numb	<b>er:</b> 43 of 63					
Z PATIONA EQUIPME	AL ENERGY	Test and Inspection Report For TC407/TC(MC)307 tanks						
Form Number:NEE-FRM-007-	407	Revi	sion: 1					
Facility Name: National En	ergy Equipment Inc.	TEOT	DATE:					
Address:	Fair	TEST Equilit		10.25				
Tank Owner:	Fax.	Facili	y Registration	VU. 23-				
Address:							0.0	
Telephone:								
		SERIAL No.:				÷		
CERT. DATE:	MATERIAL	₩₩ <b>₩₩</b> ₩₩	TANK SPEC:			÷.,		
	10/1 0			10/		1		
COMP. CAPACITY 1	IG/L 2	IG/L 3 .		IG/L				
4	IG/L 5	10/1 0						
4		(G/E 0						
4	DNCLUSION:							
4 INSPECTION AND TEST CC TESTS PERFORMED No defect or damage was dis Description of the location, fixing or replacement, and	NCLUSION: "V" □ covered on tank YE nature, and severity of dam the results of any subseque	"K"  S NO nage or defects found, nt test or inspection	D how they were	discovered	i, and the	nature o	fany	
INSPECTION AND TEST CC TESTS PERFORMED  No defect or damage was dis  Description of the location, fixing or replacement, and  Tank successfully retested af Expired Inspection Markings TANK DISPOSITION	IONCLUSION:     "V" □     noture, and severity of dam the results of any subseque ter fixing removed emoved from Service afety Mark (Specification Ind	"K"   NO Tage or defects found int test or inspection YES YES YES	how they were	discovered	d, and the	nature o	fany	
4 INSPECTION AND TEST CC TESTS PERFORMED No defect or damage was dis Description of the location, fixing or replacement, and Tank successfully retested af Expired Inspection Markings TANK DISPOSITION Re Sa Re Inspection Markings applied	IBL 5	"K"   S   NO rage or defects found nt test or inspection YES YES lication) removed YES	how they were		i, and the	nature o	fany	
4 INSPECTION AND TEST CC TESTS PERFORMED No defect or damage was dis Description of the location, fixing or replacement, and Description of the location, fixing or replacement, and Tank successfully retested aff Expired Inspection Markings TANK DISPOSITION Ref Sa Ref Inspection Markings applied FAILED INSPECTIO	IBL 3	"K"   S   NO rage or defects found nt test or inspection YES YES VES VES SSED INSPECTION	how they were		i, and the	nature o	fany	
4 INSPECTION AND TEST CC TESTS PERFORMED No defect or damage was dis Description of the location, fixing or replacement, and Tank successfully retested af Expired Inspection Markings TANK DISPOSITION Ref Sa Ref Inspection Markings applied FAILED INSPECTIO	I UNCLUSION:	"K"   NO Tage or defects found int test or inspection YES YES VES VES SSED INSPECTION	how they were	discovered	d, and the		fany	

# Z NATIONAL ENERGY EQUIPMENT INC.

# Quality Control Manual in accordance with CSA B620

,	
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 44 of 63

21.1.3

Facility Name: National Energy Equipment Inc. Address: Telephone: Fax:	TEST DA Facility Re	1 TE:		
Facility Name: National Energy Equipment Inc. Address: Telephone: Fax:	TEST DA	TE:		
Address: Telephone: Fax:	Facility Re	ie:		
Telephone: Fax:	Facility Re			
and a first sector of the sect		egistration No.:	25-	
Address:	=			
Telephone:	-			
OWNERS UNIT No:	SERIAL No	ni -		
MANUFACTURER:	MAW	P:		
CERT. DATE: MATERIAL:		TANK	SPEC:	
It is constructed of quenched and tempered steel (QT)	other than query	ched and temps	red steel (N	
				····
4 IG/L 2	- IG/L 5	IG/		
EXTERNAL VISUAL INSPECTION "V"				
Item inspected	QC Man.	Complies	Reject	Retest
Data plate and other markings, present and legible	Ret.	Ξ.		Complies
Shell & Heads corrosion, abrasion, dents, overlay patches, leaks, defect	12.2	H	H	E
welds, loose bolts and nuts on any flanged/blank connection, etc.	12.2	8		
Piping and valves for leakage, damage. corrosion	12.2		H	H
Remote closures, thermal devices	12.2	Ξ	Ē	ō
Hoses for defects, identification and test dates	12.2			
Tank attachments to frame or running gear, elements of the UC assembly	12.2			
Inspect underneath tank for dents, corrosion, leaks, cracks on outriggers /	12.2			
cross members, make sure voids are not capped, pipes for dents/rubbing, hydraulics, excessive play in PTO shaft (check or shear section on Outlet valve)				
Inspect on top of tank for dents, corrosion, fall protection functions (if equipped), anti-slip grating insecure or wearing tank, obvious signs of laskane	12.2			
All switches and valves, work properly	12.2			
Ladders, walkways, trop of the tank, and etc.	12.2			
Fill covers, manways and closure devices, are operative and leaktight Relief valves and vents inspected and properly operative (replace or test il tank in service where lading corrosive to relief device)	12.2 f 12.2			
Accident damage protection	12.2			
InspectorSignatureDat	e,	After Retest Sig	inature	
Note: Rejection Criteria for External Visual Inspections Less than minimum material thickness under any cut, dig or gou Any dent with a depth greater than ½" where it includes a weld Any dent with a depth greater than 10% of the length of the den Any weld defect including a crack, pinhole, or incomplete fusion Any structural defect Any source of leakage Any repairs made to liquid-retaining components using overlay Defective, unidentified or out of test Hose Assemblies	uge It I of the weld patches	an	d Date	
Related to Inspection and Testing (IT)			12	Page 1 of 4

NATIONAL ENERGY	
EQUIPMENT INC.	

Document Number: NEE-QCM-QC-001

**Revision Number:** 01

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2018/02/25

Page Number: 45 of 63

orm Number:NEE-F	RM-007-331	Re	Revision: 1					
Facility Name: Na Address:	tional Energy Equipment Inc.	TE	ST DAT	re:				
Telephone:	Fax:	Fac	ility Re	gistration No.:	25-			
Tank Owner: Address:								
Telephone:								
OWNERS UNIT No: MANUFACTURER:	M4	ERIAL No.				<u> </u>		
It is constructed of a		or other than		hed and temps	ared steel (1			
COMP. CAPACITY		IG/L 3	quenu	IG/I		·×·/⊔		
	4 IG/L 5	IG/L 6	-	IG/	<u>e</u>			
TEST OF EMERGE	NCY DISCHARGE CONTROL							
Item inspected		QC R	Vlan. ef.	Complies	Reject	Retest Complies		
Have Emergency disch	arge controls, except designed to transport (	Class 2.2, 12	2.2					
non-flammable and nor	-toxic gases.	u 1:	2.2					
emergency shut down s emergency shut down s For tanks that are 13,24 shutdown system. With product running at activate the off-truck Er the flow and close the in sooner. No meter creep both ON and OFF truck For non-metered tanks, Each emergency disch- shall be operated to em shall be operated to em closed position. Once a downstream piping sha atmospheric temperatu for 30 seconds to ensure	normal flow rate throughout the metering system and either 'a monitoring feature' or 'a ystem', 50L or less, inspect and test off-truck emerge normal flow rate throughout the metering sy nergency shutdown system. The meter shound the state of the system of the system and the shound or after 5 seconds. The same process shall be applications. all internal self closing (ISC) valves shall be arge control remote actuator (on- truck and or sure each ISC valve indicator has moved to a IISC valves are closed, all of the material in II ISC valves are closed, all of the material in the evacuated, and the piping shall be return re and pressure. The outlet shall then be more re that there is no detectable leakage.	passive passive ency vstem, ild stop onds or e used on e open. off truck) the off truck) the n the med to onitored						
When the Emergency s reactivated remotely.	hutdown has been activated, the ISC canno	t be 1.	2.2					
The emergency shut do	wn system shall function reliably at a distan	ce of 46 1.	2.2					
in (reeny.	Signature	Date	/	After Retest Sig	inature			
Tank tester	Ognature	Marcal of A			d Data			

ent N	umber: NEE-OCM-	OC-001			Revision Number	01			
d by	Annroved hy:				Arash Navidan / Zanyar Farhadi				
з <u>и Бу</u> т	7 Approved by.								
Issue	e: 2018/02/25				Page Number: 46 o	of 63			
		YAL		RGY C.	Т	est and For TC	Inspect (MC)33	ion Report 1 tanks	
F	orm Number:NEE-FRM-0	007-331			Revision: 1				
ſ	Facility Name: Nationa	l Energy	Equipme	nt Inc.					
	Address:				TEST DATE:	-	Ç.		
Ш	Telephone:	Fax	:		Facility Registr	ation No. 2	5-		
	Tank Owner: Address:								
	Telephone:								
	OWNERS UNIT No.			S	ERIAL No.				
6	MANUFACTURER:	_		M/	AWP:				
1	CERT. DATE:		MA	TERIAL:	TANK S	PEC: -			
	It is constructed of quenc	hed and t	empered	l steel (QT)	or other than quenched	and tempe	red steel (	NQT)	
	COMP. CAPACITY 1 4	_		G/L 2 G/L 5	IG/L 3 IG/L 6	IG/L IG/L			
	LEAKAGE TEST "K"	(QC Ma	anual Re	ference 12.5)					
1	TEST PRESSURE			(80% of MAWP	MIN) TEST MEDIUM				
	The test pressure shall	be the r	naximu	m normal oper	ating pressure of the tank	and no le	ss than 6	0 PSI	
	Item Tested	Pass	Fail	Retest Complies	Item Tested	Pass	Fail	Retest Complies	
	Compartment No. 1				Compartment No. 1 piping			P	
	Compartment No. 2		Ë		Compartment No. 3 piping				
	Compartment No. 3		E .	Ē	Compartment No. 4 piping				
	Compartment No. 3 Compartment No. 4		<u> </u>						
	Compartment No. 3 Compartment No. 4 Compartment No. 5				Compartment No. 5 piping				
	Compartment No. 3 Compartment No. 4 Compartment No. 5 Compartment No. 6				Compartment No. 5 piping Compartment No. 6 piping				
	Compartment No. 3 Compartment No. 4 Compartment No. 5 Compartment No. 6	□ □ □ _ Signat			Compartment No. 5 piping Compartment No. 6 piping Date After	Retest Sig			

EGUIIMENT INC		in accordance with CSA B620						
nt Number: NEE-QCM-QC-001	R	Revision Nur	nber:	01				
l by / Approved by:	А	Arash Navidan / Zanyar Farhadi						
ssue: 2018/02/25	Р	age Numbe	<b>r:</b> 47 o	of 63				
RATIONAL EN EQUIPMENT IN	ERGY IC.		Ţ	est and For T	l Inspe C(MC)	ection F 331 tar	Report Iks	p
Form Number:NEE-FRM-007-331		Revisi	on: 1					
Facility Name: National Energy Equipm	ent Inc.	TEST						
Telenhone: Eav		Facility	Registr	ation No.	25-			
Tank Owner: Address:			riogioti	adon res.				
Telephone:	SERIAI	L No :						_
	MAWP:		TANKS	PEC:			1	
It is constructed of quenched and tempere	d steel (QT)∏ o	r other than qu	enched	and temp	ered ste	el (NQT)[	1	
COMP. CAPACITY 1	IG/L 2	IG/L_3		IG IG	/L /L			
4	IG/L 5							
	IG/L 5	_ 10/2 0 _						
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V"	П "К"	_ 10,200 _						
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and	IG/L 5 ank YES [ severity of damage or of	NO defects found, I	D how the	y were dis	scovered	, and the	nature of	fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and fixing or replacement, and the results of	□ "K" ank YES [ severity of damage or of any subsequent test of	NO defects found, I	D how the	y were dis	scovered	, and the	nature o	fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and fixing or replacement, and the results of	Severity of damage or of any subsequent test of	D NO defects found, I or inspection	D now the	y were dis	scovered	, and the	nature of	fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and fixing or replacement, and the results of Tank successfully retested after fixing Expired Inspection Markings removed	"K" ank YES [ severity of damage or of any subsequent test of	YES	now the	y were dis	scovered	, and the	nature of	fany
4         INSPECTION AND TEST CONCLUSION:         TESTS PERFORMED       "V"         No defect or damage was discovered on the location, nature, and a fixing or replacement, and the results of	Service	YES YES		y were dis	scovered	, and the	nature of	fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and a fixing or replacement, and the results of fixing or replacement, and the results of Tank successfully retested after fixing Expired Inspection Markings removed TANK DISPOSITION Removed from Safety Mark (S Returned to Se	Service	YES YES		y were dis	scovered	, and the	nature o	fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and fixing or replacement, and the results of fixing or replacement, and the results of Tank successfully retested after fixing Expired Inspection Markings removed TANK DISPOSITION Removed from Safety Mark (S Returned to Se Inspection Markings applied	Service	YES YES YES	how the	y were dis		, and the		fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and the results of fixing or replacement, and the results of Tank successfully retested after fixing Expired Inspection Markings removed TANK DISPOSITION Removed from Safety Mark (S Returned to Se Inspection Markings applied FAILED INSPECTION	Service	YES YES YES YES		y were dis		, and the		fany
4 INSPECTION AND TEST CONCLUSION: TESTS PERFORMED "V" No defect or damage was discovered on ta Description of the location, nature, and the results of fixing or replacement, and the results of Tank successfully retested after fixing Expired Inspection Markings removed TANK DISPOSITION Removed from Safety Mark (S Returned to Se Inspection Markings applied FAILED INSPECTION Inspector	Service	YES YES YES YES		y were dis		, and the		fany

		in accordance with CSA B620		
Document Nu	amber: NEE-QCM-QC-001	Revision Number: 01		
Prepared by	/ Approved by:	Arash Navidan / Zanyar Farhadi		
Date of Issue	: 2018/02/25	Page Number: 48 of 63		
21.1.4	RATIONAL ENERGY EQUIPMENT INC.	Hose assembly test and inspection report		
	Form Number:NEE-FR-L-012	Revision: 0		
	FACILITY NAME: ADDRESS:	TEST DATE: FACILITY REG. NO.:		
	UNIT#			
	ADDRESS:			
	HOSE SERIAL #			
	VISUAL INSPECTION	COMPLIES COMPLIES		
	EXPOSED REINFORCEMENT	YES NO YES NO YES NO		
	PERMANENTLY DEFORMED WIRE BRAID SOFT SPOTS WHEN NOT UNDER PRESSURE, BULGING UNDER PRESSURE OR LOOSE OUTER	YES NO YES NO YES NO YES NO YES NO YES NO		
	COVERING DAMAGED, SLIPPING OR EXCESSIVELY WORN HOSE COUPLINGS			
	FASTENINGS ON BOLTED HOSE COUPLING ASSEMBLIES DETERIORATED LEGIBILITY OR			
	ABSENCE OF SERIAL OR ID			
	HOSE PRESSURE TEST			
	HOSE SERIAL # HAWP (PSI)	TEST PRESSURE (PSI) TEST MEDIUM PASS FAIL		
	TESTER NAME:			
	SIGNATURE: DATE:			

# Z NATIONAL ENERGY EQUIPMENT INC.

# **Quality Control Manual** in accordance with CSA B620

Document Number: NEE-QCM-QC-001

**Revision Number: 01** 

Prepared by / Approved by:

Arash Navidan / Zanyar Farhadi

Form Number:NEE-FR-L-014					Revision: 0			
Mobile ga	auges for B6	20						
Gauge #	Date	Method	Pass	Fail	Next Due Date	dot		
-								
-								
	-			-				
1				-				
				-				
1	-							
1								
-								
1	-							
-	-							
-		-		-				

	NATIONAL ENERGY
70	FOUIPMENT INC

Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 50 of 63

# 21.1.6

orm Number:NEE-FR-L-015			Revision: 0		
I.D. Number	Description	Calibration Date	Due Date	Calibrated By	Result
- 14 V			1		1
		-	5		-
			· · · · · · · · · · · · · · · · · · ·		-
			1 - 1		
		-			-
-		_			-
			· · · · ·		
					1.0
		-			-
			/ / a		-
			1		
			à		

	AI IO PUIPA	NAL ENERCI MENT INC.	iΥ	in acco	ordance with CSA B620		
ocument Number: NEE-QCM-QC-001		]	Revision Number: 01				
Prepared by / Approved by:			Arash Navidan / Zanya	ar Farhadi			
Date of Issue:	2018/02/25		]	Page Number: 51 of (	53		
21.1.7							
	2	NATIONAL EL	NERGY INC.	Nonconf prevent	formance corrective and ative action report form		
	Form Nu	mber:NEE-ER-1-017		Pavision: 0			
	Formina	mbel.NEE-FR-E-017		Revision. 0			
	11.0	-	Туре	e of action/Status			
		Corrective Action		Preventive Action	1441 / Ferrer		
		Job #		- <u>.</u>			
		Issued To					
		Reference Highway Tank/ Portable Tank					
		Reference Area/Process					
		Documents					
		Name of Initiator:	Signature:	1	Date:		
	1.1.1		-				
		Nonconformity					
		Description of Nonconformity:					
				Contraction of the second			
		Root Cause           Corrective Action         Preventive Action					
		Determination of Root Cause:					
		Description of Implemented Ad	ction:				
			1				
		Signature:	Position/T	itle:	Date:		
			Evidence F	Reviewed and Conclusions			
		Follow up	P. P	And Close			
	1.1	Is the Action Effective?					

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.		ENERGY T INC.	Quality Control Manual in accordance with CSA B620	
Docume	nt Number: NEE-QCM-Q	C-001	Revision Number: 01	
Prepare	d by / Approved by:		Arash Navidan / Zanyar Farhadi	
Date of I	<b>Issue:</b> 2018/02/25		Page Number: 52 of 63	
21.1.8	;			
	Mandatory Docume	nt List		
-	NEE-FRM-007-406	Test and Inspection Report for TC406/TC(MC)306 tanks Related Section:12 Inspection and testing - examination		
-	NEE-FRM-007-407	Test and Inspection Report for TC407/TC(MC)307 tanks Related Section:12 Inspection and testing - examination		
-	NEE-FRM-007-331	Test and Inspection Report for TC(MC)331 tanks Related Section:12 Inspection and testing – examination		
-	NEE-FRM-012	Hose Assembly Test and Inspection Report Related Section:12 Inspection and testing - examination		
-	NEE-FRM-014	Gauge Calibration Log Related Section:16 Calibration		
-	NEE-FRM-015	Equipment Calibration Log Related Section:16 Calibration		
-	NEE-FRM-017	Nonconformance corrective and preventative action report Related Section: 14 Nonconformities - Corrective action, 17 Quality audits		



# **Quality Control Manual**<br/>in accordance with CSA B620Document Number: NEE-QCM-QC-001Revision Number: 01Prepared by / Approved by:Arash Navidan / Zanyar Farhadi

Page Number: 54 of 63

Date of Issue: 2018/02/25

21.1.10

Table 7.1 of CSA B620

#### Periodic inspection and test intervals

(See Clauses 7.1.1, C.1, C.2,	and C.6 of CSA-B620.)
-------------------------------	-----------------------

Description of tank	Clause 7.2.1 External inspection	Clause 7.2.2 Internal inspection <sup>(1)</sup>	Clause 7.2.3 Lining inspection	Clause 7.2.5 Leakage test	Clause 7.2.7 Pressure test, hydrostatic or pneumatic	Clause 7.2.11 Structural inspection
TC 306 or TC 406 tanks	l year	5 years <sup>(2)</sup>	—	l year	5 years <sup>(3)</sup>	_
TC 306 Crude or TC 406 Crude tanks	2.5 years	5 years	_	2.5 years	5 years <sup>(3)</sup>	
TC 307 or TC 407 tanks	l year	5 years	_	l year	5 years	_
TC 312 or TC 412 tanks	l year	5 years	_	l year	5 years <sup>(3)</sup>	_
TC 423 tanks	l year	l year	_	l year	5 years	5 years
TC 350 tanks	6 months	l year	_	l year	2 years	_
TC 350 Crude tanks	l year	l year	_	l year	2 years	_
TC 331 tanks	l year	5 years	_	l year <sup>(4)</sup>	5 years <sup>(4)</sup>	_
TC 338 tanks	l year	_	_	_	5 years	_
TC 341 tanks <sup>(5)</sup>	l year	10 years	—	_	10 years	_
TC 11 portable tanks	l year	10 years <sup>(6)</sup>	—	l year	5 years	_
TC 44 portable tanks	l year	5 years	_	l year	5 years	_
TC 51 portable tanks <sup>(9)</sup>	2.5 years <sup>(7)</sup>	5 years	5 years	_	5 years	_
TC 56 and 57 portable tanks <sup>(8)</sup>	2.5 years		_	_	2.5 years	_
TC 60 portable tanks	2 years	Initial: 4 years Next 8 years: every 2 years After 12 years: annually	Initial: 4 years Next 8 years: every 2 years After 12 years: annually		Initial: 4 years Next 8 years: every 2 years After 12 years: annually	_

#### Notes:

- (1)Where a tank, other than a TC 341 tank, is not equipped with a manhole or inspection ports, a hydrostatic or pneumatic pressure test shall be performed at the interval for internal inspections. See also Note 5.
- (2)Highway tanks used only to refuel aircraft and that operate only on airport property shall be exempt from internal inspection, provided that they are clearly marked "Restricted to Use on Airport Property" in letters not less than 25 mm (1 in) high in a contrasting colour on each side of the tank where they will be clearly visible from the ground.
- (3)For TC 306, TC 406, TC 306 Crude, TC 406 Crude, TC 312, or TC 412 tanks, the pressure tests specified in Clause 7.2.7 shall not be required for uninsulated lined tank trucks and trailers with a design pressure or MAWP of *103 kPa* (15 psi) or less, if an external inspection and a lining inspection have been performed annually.

<b>Z</b> NATIONAL ENERGY EQUIPMENT INC.	Quality Control Manual in accordance with CSA B620
<b>Document Number:</b> NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 55 of 63

- (4)TC 331 tanks in chlorine service shall be leak tested as specified in Clause 7.2.5 and pressure tested as specified in Clause 7.2.7 every two years. Pressure tests shall not be required on TC 331 tanks when in sodium metal service.
- (5)As an alternative to the inspection and test requirements of this Table for TC 341 tanks, owners may perform the tests and inspections described in Annex C.
- (6)The internal inspections specified in Clause 7.2.2 do not apply to TC 11 tanks that are less than 2350 L (620 US gal) and that do not have inspection openings.
- (7)The external inspection period may be extended to 3 years following a pressure test for tanks described in CSA B622, Clause 6.3, Specific Requirement 55.
- (8)TC 56 and TC 57 tanks shall be inspected and retested in accordance with Section 7 of CAN/CGSB-43.146.
- (9)A TC 51 portable tank that is loaded and off-loaded without being removed from the vehicle shall be inspected and tested according to the requirements for TC 331 tanks specified in this Table.
- (10) The pressure test period for tanks described in CSA B622, Clause 6.3, Specific Requirement 54 and Specific Requirement 55, is three years
- (11) TC 331 and TC 51 tanks shall be subjected to an internal inspection by the wet fluorescent magnetic particle method in accordance with Clause 7.2.8 when the conditions of Clause 7.2.8(a) are met.

NATIONAL ENERGY
EQUIPMENT INC.

Document Number: NEE-QCM-QC-001		Revision Number: 01
Prepared by / Approved by:		Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25		Page Number: 56 of 63
21.1.11 Table 7.3 of CSA B620	Test pressures (See Clauses 5.2.5, 5.5.2.4	I, 7.2.7.7, and 7.2.7.8.)
Tank specification	<u>Pressure, kPa (psi)</u>	
TC 306 or MC	21 kPa (3 psi) or design	pressure, whichever is greater
TC 307 or MC 307	275 kPa (40 psi) or 1.5 >	design pressure, whichever is greater
TC 312 or MC 312	21 kPa (3 psi) or 1.5 × d	esign pressure, whichever is greater
TC 331, MC 330, or MC 331	$1.5 \times design pressure$	
TC 406	34.5 kPa (5 psi) or $1.5 \times$ MAWP, whichever is greater	
TC 407	275.8 kPa (40 psi) or $1.5 \times$ MAWP, whichever is greater	
TC 412	$1.5 \times MAWP$	
TC 423	$1.5 \times MAWP$	
TC 338	According to calculation in Clause 5.2.5	
TC 341	According to calculation in Clause 5.5.2.4	
TC 350	155 kPa (22.5 psi) or 1.5	$5 \times MAWP$ , whichever is greater
TC 11	According to calculation in Clause 6.4.11(c)	
TC 44	27 kPa (4 psi) or 1.5 × M	MAWP, whichever is greater
TC 51 or DOT 51	$1.5 \times design pressure$	
TC 60 or DOT 60	415 kPa (60 psi)	
TC Type 1, 2, and 3	$1.5 \times MAWP$	



Document Number: NEE-QCM-QC-001

Arash Navidan / Zanyar Farhadi

Prepared by / Approved by: Date of Issue: 2018/02/25

Page Number: 57 of 63

**Revision Number: 01** 

21.1.12

#### **Required information on the Identification Plate checklist**

The following information shall appear on the plate(s) (parenthetical abbreviations are authorized): **Note:** *This information may be provided and marked in accordance with the ASME* Code.

- (a) tank manufacturer (Tank mfr.);
- (b) date of tank manufacture month and year (Date of mfr.);

(c) assembler;

- (d) completion and certification date month and year (Cert. date);
- (e) original test date month and year (Orig. Test Date);
- (f) TC Specification (TC Spec.);
- (g) Transport Canada Registration Number (TCRN);<sup>(1)</sup>
- (h) Manufacturer's Design Identification Number (MDIN);<sup>(2)</sup>
- (i) tank serial number (Ser. No. or S/N);
- (j) vehicle identification number (VIN);
- (k) tank maximum allowable working pressure in kPa (MAWP);
- (l) tank test pressure in kPa (Test P);
- (m) tank design temperature range \_\_\_\_°C to \_\_\_\_°C (Design temp. range);
- (n) maximum design density of lading in kilograms per litre (Max. lading density);
- (o) vessel material specification number<sup>(3)</sup> all numbers to be marked where the material for the shell is different from the material for the heads (Shell & Head Matl. yyy zzz or Shell Matl. yyy zzz and Head Matl. yyy zzz, where "yyy" is replaced by the alloy designation and "zzz" by the alloy type);
- (p) weld material (Weld Matl.);<sup>(3)</sup>
- (q) minimum allowable thickness of shell in millimetres (Min. shell thick.). When minimum shell thicknesses are not the same for different areas, mark variances (Top ...... Side...... Bottom.......);
- (r) minimum allowable thickness of heads in millimetres (Min. head thick.);
- (s) manufactured thickness of shell in millimetres (Mfd. shell thick.);<sup>(4)</sup>
- (t) manufactured thickness of heads in millimetres (Mfd. head thick.);<sup>(4)</sup>
- (u) exposed surface area in square metres;
- (v) volumetric capacity in litres (Cap. Litres);
- (w) maximum product load in kilograms (Max. payload);
- (x) maximum loading rate in litres per minute and optionally in US gallons per minute [Max load. rate, L/min (US GPM) at maximum loading pressure XX kPa (psi)];<sup>(5)</sup>
- (y) maximum unloading rate in litres per minute and optionally in US gallons per minute [Max. unload. rate, L/min (US GPM) at maximum unloading pressure XX kPa (psi)];<sup>(5)</sup>

#### Annotations:

(1)Required for all tanks including: (a) TC 331; (b) TC 407 with a MAWP greater than 240 kPa (35 psi) or designed to be loaded by vacuum,

- (2)Required for all tanks other than those outlined in above.
- (3)For FRP tanks, "NA" shall be marked.
- (4)Required when additional material is provided for corrosion allowance
- 5)Does not apply to TC 331 highway tanks.



**Revision Number: 01** 

Page Number: 58 of 63

Arash Navidan / Zanyar Farhadi

**Document Number:** NEE-QCM-QC-001

#### Prepared by / Approved by:

Date of Issue: 2018/02/25

## **<u>21.2</u>** Equipment, signs and decals

Equipment:

Test Gauge Calibration Devices:

- 15# Gauge
- 300# Gauge
- Air Pressure Regulator
- Hose Testing Test Tee



10" Fill Test Fixture

16" and 20" Manway Bench Test Fixture

12"x16" Elliptical Manhole Bench Test Adapter r

Hydrostatic Test Pump













NATIONAL ENERGY
EQUIPMENT INC.

Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 59 of 63

Assorted Hose Test Adapters

Air Compressor





TANK UNDER PRESSURE

Tank Under Pressure Signs

Test and Inspection Decals

Calibration Decal

# CALIBRATION

Date: \_\_\_\_\_

Technician: \_\_\_\_\_

Due: \_\_\_\_\_

<b>Z</b> EQUIPMENT INC.	in accordance with CSA B620
Document Number: NEE-QCM-QC-001	Revision Number: 01
Prepared by / Approved by:	Arash Navidan / Zanyar Farhadi
Date of Issue: 2018/02/25	Page Number: 60 of 63

#### 21.3 Samples of actual completed documents

The following documents are SAMPLES only. Latest quality control manual must be followed to complete the forms. Please refer to facilities' completed records for more samples.

acility Name: National Energy Equipmen	nt Inc	TEST	XXXXXXX	K, 115	
aaress: XXXXXXX,		IEST D.		113	
elephon XXXX	477	Facility R	egistration	: XX-XXX	ζ
ank Ow John Doe XXXXXXXXX, XXXX ddress:	-	Owners S	Signature _		-
elephon		Date:			
WNERS UNIT N : XXX IANUFACTUREI XXX	SERIAL No	: XXX-2	XXX-XXX	5	
IFG DATE: 11/89 MATER	RIAL: 5454	T.	ANK SPEC:	TC 306	
1C/TC331 & TC51 QT 🗌	NQT	F			
COMP. CAPACITY 1 2000 L IG/L 4 4500 L IG/L	2 <u>3600 L</u> IC 5 2400 L IC	G/L 3 <u>550</u> G/L 6	IG	/L /L	
ESTS PERFORMED "V"	"I" 🛛 "K" 🕅	"P" 🛛	"Т"	"U/C"	
XTERNAL VISUAL INSPECTION "V"					
Item inspected		QC Man	Complies	Reject	Retest
ata plate, present and legible		8.1.3			
hell & Heads, corrosion abrasion dents overlay	patches leaks etc	8.1.4	$\boxtimes$		
tructural members, outriggers, crossmembers e	tc	8.1.5		$\boxtimes$	$\boxtimes$
iping and valves for leakage, damage, corrosior	1	8.1.7	X		
emote closures, thermal devices		8.1.7		$\boxtimes$	$\boxtimes$
oses for defects, identification and test dates		8.1.8			
ank attachments to frame or running gear		8.1.9	X	Н	H
adders, walkways etc		8111			
ni covers, manways and closure devices elief valves and vents (replace or test if tank in t	service where	8.1.12	H	X	
ding corrosive to relief device)		0.1.12	2		
ccident damage protection	- 9	8.1.13	$\boxtimes$		
nspector- Tom T Sig	nature	IX	Date-	Nov 30 20	15
NTERNAL VISUAL INSPECTION "I"					-
Item inspected		QC Man	Complies	Reject	Retest
terior surface corrosion distortion overlay pate	hes, cracking etc.	8.2.2			
iterior welds for defects, cracking etc		8.2.3	X	П	П
ternal supports and attachments		8.2.4	$\boxtimes$		
ternal valves, piping and vents for leakage, dan	nage, etc 🕺	8.2.4		$\boxtimes$	$\boxtimes$
nspector- Tom T Sig	gnature	×	Date	Nov 30 20	15
lote: Rejection Criteria for Visual Inspection	5				
Any of the following conditions shall cau	use the tank to be rej	ected			
Less than minimum material thickness Any dent with a depth greater than ½" v Any dent with a depth greater than 10% Any weld defect including a crack, pinh Any structural defect or any source of le Any repairs made using overlav patche	under any cut, dig or where it includes a we 6 of the length of the ole, or incomplete fus eakage s	gouge Id dent ion of the we	ld		

- Lyn	TIONA JIPME	L EN NT II	IERO NC.	3 <b>Y</b>	Quality Control Manual in accordance with CSA B620						
ment Numbe	er: NEE-QCM	1-QC-001			Revision Number: 01 Arash Navidan / Zanyar Farhadi						
ared by / Apj	proved by:										
of Issue: 201	8/02/25				Page Number: 61 of 63						
Test	t and Inspec	tion Rep	ort in A	Accordanc	e with CSA B620	Pag	Page 2 of 3				
UPPI	ER COUPLER	INSPECTIO	ON "U/C"	' (QC Manua	l Reference 8.1.5 and 8.1 C	. <i>6)</i> omplies	Reject	Retest			
Ur	oper coupler remo	oved from ta	ink and ins	spected (includ	ling tank areas above)			Complies			
Ur	oper coupler insp	ected in plac	ce			П					
Inspe	ector-			Signature		Date-		-			
LEA	AGE TEST "K	QC M	lanual Re	eference 8.3)							
TEST	T PRESSURE	2.4 PSI	(	80% of MAW	P MIN) TEST MEDIUM	AIR					
	Item Tested	Pass	Fail	Retest	Item Tested	Pass	Fail	Retest			
Co	ompartment No. 1				Compartment No. 1 piping	$\boxtimes$					
Co	ompartment No. 2	2	$\boxtimes$	$\boxtimes$	Compartment No. 2 piping	$\boxtimes$					
Co	ompartment No. 3				Compartment No. 3 piping						
	ompartment No. 5		H	H	Compartment No. 5 piping		H	H			
					oonpartmont no. o piping						
Co	ompartment No. 6				Compartment No. 6 piping						
Cc Tank THIC Thick devic	ompartment No. 6 Tester- Tom T CKNESS TEST kness Tester Ca ce	"T" <i>(</i> QC M alibrated in	lanual Re accordar	Signature eference 8.5) nce with instr	Compariment No. 6 piping 2 uctions provided by the m $S \square NO$	Date-	Nov 30 20	IS esting			
Cc Tank THIC Thick devic	Compartment No. 6 Tester- Tom T CKNESS TEST cness Tester Ca ce	T" (QC M alibrated in	lanual Re	Signature eference 8.5) nce with instr YES	Compartment No. 6 piping	Date-	Nov 30 20 er of the to	LS esting HEAD			
Cc Tank THIC Thick devic	Tester- Tom T KNESS TEST KNESS TEST Kness Tester Ca ce	T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature eference 8.5) nce with instr YE:	Compartment No. 6 piping	Date-	Nov 30 20 er of the to FRONT	IS esting HEAD			
Cr Tank THIC Thick devic	Tester- Tom T KNESS TEST kness Tester Ca 22 12:00	T" (QC M alibrated in FRONT	lanual Re accordar	Signature eference 8.5) nce with instr YES	Unperformed to provide provided by the model of the second	Date-	Nov 30 20	IS esting HEAD			
Tank THIC Thick devic	Tester- Tom T CKNESS TEST CRNESS TEST CRNESS Tester Ca CR 12:00	T" (QC M alibrated in FRONT 3:00	lanual Re accordar 6:00	Signature eference 8.5) nce with instr YE:	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S NO HEAD 1 2	Date-	Nov 30 20 er of the to FRONT	HEAD			
Cc Tank THIC Thick devic	Tester- Tom T KNESS TEST CRISS TEST CRISS Tester Ca 22 12:00	T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature eference 8.5) nce with instr YES	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S NO HEAD 1 2 3	Date-	Invov 30 20 er of the to FRONT	HEAD			
Cc Tank THIC Thick devic	Tester- Tom T KNESS TEST kness Tester Ca 22 12:00	T" (QC M alibrated in FRONT 3:00	lanual Re accordar 6:00	Signature eference 8.5) nce with instr YES	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S NO HEAD 1 2 3 4	Date-	Nov 30 20	HEAD			
Cc Tank THIC Thick devic	Tester- Tom T KNESS TEST Kness Tester Ca 22 12:00	"T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature eference 8.5) nce with instr YE:	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S D NO HEAD 1 2 3 4 5 6	Date-	Nov 30 20 er of the to	HEAD			
Cc Tank THIC Thick devic	Tester- Tom T KNESS TEST kness Tester Ca 12:00	T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature eference 8.5) nce with instr YES	Compartment No. 6 piping uctions provided by the m S NO HEAD 1 2 3 4 5 6 7	Date-	Invov 30 20 er of the to FRONT	HEAD			
Tank THIC Thick devic	Tester- Tom T KNESS TEST kness Tester Ca 12:00	"T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S NO HEAD 1 2 3 4 5 6 7 8	Date-	Nov 30 20 er of the to	IS esting HEAD			
Co Tank THIC Thick devic	Tester- Tom T KNESS TEST CRNESS Tester Ca 22 12:00	*T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature eference 8.5) nce with instr YE: 9:00	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m NO HEAD 1 2 3 4 5 6 7 8 9		Nov 30 20 er of the to	HEAD			
Cc Tank THIC Thick devic	Tester- Tom T KNESS TEST kness Tester Case	T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature eference 8.5) nce with instr YES	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S D NO HEAD 1 2 3 4 5 6 7 8 9 10 14		REAR H	LS esting HEAD			
Cc Tank THIC Thick devic 1 2 3 4 5 6 7 8 9 10 11	Tester- Tom T KNESS TEST kness Tester Ca 12:00	*T" (QC M alibrated in FRONT 3:00	lanual Re accordar	Signature	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S D NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD	Date-	Nov 30 20 er of the to FRONT	LIS esting HEAD			
Cc Tank THIC Thick devic 1 2 3 4 5 6 7 8 9 10 11	Tester- Tom T CKNESS TEST CRESS Tester Case	*T" (QC M alibrated in FRONT 3:00	Elanual Re accordar	Signature eference 8.5) ince with instr YES 9:00 9:00 9:00	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD		Nov 30 20 er of the to FRONT	IS esting HEAD			
Co Tank THIC Thick device 1 2 3 4 5 6 7 8 9 10 11	Tester- Tom T CKNESS TEST cness Tester Case	*T" (QC M alibrated in FRONT 3:00 3:00 REAR	lanual Re accordar	Signature	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S D NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD	Date-	Nov 30 20 er of the to FRONT	IS esting HEAD			
Co Tank THIC Thick devic 1 2 3 4 5 6 7 8 9 10 11	Tester- Tom T KNESS TEST Aness Tester Case	T" (QC M alibrated in FRONT 3:00 3:00 REAR	lanual Re accordar	Signature	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD		Nov 30 20 er of the to FRONT	IS esting HEAD			
Co Tank THIC Thick devic	Tester- Tom T KNESS TEST cress Tester Case	T" (QC M alibrated in FRONT 3:00 3:00 REAR	lanual Re accordar	Signature eference 8.5) nce with instr YES 9:00 9:00	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m S NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD		Nov 30 20 er of the to FRONT	LS esting HEAD			
Co Tank THIC Thick device	Tester- Tom T KNESS TEST cress Tester Case	T" (QC M alibrated in FRONT 3:00 3:00 REAR	lanual Re accordar	Signature	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD		Nov 30 20 er of the to FRONT	IS esting HEAD			
Co Tank THIC Thick devic	12:00	T" (QC M alibrated in FRONT 3:00 3:00 REAR	lanual Re accordar	Signature	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD 10 11 HEAD		Nov 30 20 er of the to FRONT	IS esting HEAD			
Co Tank THIC Thick devic	A Tester- Tom T KNESS TEST cress Tester Case	T" (QC M alibrated in FRONT 3:00 3:00 REAR	lanual Re accordar	Signature eference 8.5) nce with instr YES 9:00 9:00 9:00	Compartment No. 6 piping Compartment No. 6 piping uctions provided by the m NO HEAD 1 2 3 4 5 6 7 8 9 10 11 HEAD NO NO NO NO NO NO NO NO NO NO		Nov 30 20 er of the to FRONT	LS esting HEAD			

nt Number: N	PMEN	Quality Control Manual in accordance with CSA B620									
	Revision Number: 01         Arash Navidan / Zanyar Farhadi										
d by / Approv											
<b>Issue:</b> 2018/02	Page I	Page Number: 62 of 63									
Test an PRESSU Test Pres (Refer to Test Pres Iter Compa Compa	Id Inspection RE TEST "P" ssure (Tank) Table 7.3 of ( ssure (Piping) m Tested artment No. 1 artment No. 2	ON Report in Accordance (QC Manual Reference 8.4) 3 PSI CSA B620-2003 for appropriat 2.4 PSI (80% Tank Test) Pass Fail Retest Complies			ate test pres te compartn Compartn Compartn	SSA B6 ssure) Test M m Tester nent No. 1 nent No. 2	20 Aedium d piping piping	AIR Pass	Pa Fail	age 3 of 3 Retest Complies	
Compa Compa	Compartment No. 3 🛛 🗍					Compartment No. 3 piping Compartment No. 4 piping					
Compa	rtment No. 5	Compartm	ient No. 5	piping							
Weld c Repair Repair	racks on left re emergency rele roll over rail or	ar frame c ace for in n right sid	over rear e iternal val e for dents	nds ves s and cracks							
Tank suc Written r TANK DI	cessfully rete epair weld ins SPOSITION	sted afte pection r Remov	r repair eport atta /ed from	YES 🖄 ached Y Service	] ES ⊠	NO NO		N/A N/A			
Tank suc Written r TANK DI	ccessfully rete epair weld ins SPOSITION	sted afte pection r Remov Safety Return	er repair report atta ved from Mark (Sp ied to Se	YES ached Y Service pecification rvice	] ES ⊠ □ Indication)	NO NO removed		N/A N/A			
Tank suc Written r TANK DI TC/MC33 & TC 51	ccessfully rete epair weld ins SPOSITION 30/331 PWH ONLY	sted afte pection r Remov Safety Return HT AFTE IF YES	r repair eport atta ved from Mark (Sp ied to Se R REPAI	YES ached Y Service pecification rvice IRS Y FULL	] ES Indication) ] ES ] LOC	NO NO removed NO	IYES	N/A N/A	□ □ NO		

# **Z** EQUIPMENT INC.

# Quality Control Manual in accordance with CSA B620

Document Number: NEE-QCM-QC-001

Revision Number: 01

Prepared by / Approved by:

Arash Navidan / Zanyar Farhadi Page Number: 63 of 63

Date of Issue: 2018/02/25

# SECTION - 22 Revision Control Sheet

Раде		Revision Number and Latest Issue Date							Revision Number and Latest Issue Date						
J.	0	1	2	3	4	5	6	J	0	1	2	3	4	5	6
	Jan 2018	Feb 2018							Jan 2018	Feb 2018					
1	Х	X						51	Х	X					
2	Х	Х						52	Х	Х					
3	Х	Х						53	Х	Х					
4	Х	X						54	Х	Х					
5	Х	X						55	Х	X		ļ			
6	X	X						56	Х	Х					
7	X	X						57	X	X					
8	X	X						58	X	X					
9	X	X						59	X	X					
10	X	X						60	X	X					
11	X	X						61	X	X					
12	X	<u>X</u>						62	X	X					
13	X	X						63	X	X					
14	X	X						64	X					-	
15	X 							60	X						
10	^ 							67						+	
17								68							
10	X	X						69							
20	x	X						70							
20	X	X						70				-		+	
22	X	X						72				+		+	
23	X	X						73						+	
24	X	X						74					``		
25	X	X		1				75				1	1	1	
26	X	Х						76							
27	Х	Х						77							
28	Х	Х						78							
29	Х	Х						79							
30	Х	Х						80							
31	Х	X						81							
32	Х	X						82							
33	Х	X						83							
34	X	X						84							
35	X	X						85							
36	X	X						86						+	
	X	X						87						-	
38	X 							88							
39								89 00						+	
40	X	X						90						+	
41	X	X						91							
42	X	X						92				ļ	ļ	<b>.</b>	
43	Х	X						93							
44	Х	X						94							
45	Х	Х						95							
46	Х	Х						Signatu	ro						
47	X	X		ļ				Signatu	10.						
48	X	Х													
49	Х	X						Date:							
50	Х	X						2							